

70

**POWER SYSTEM RELIABILITY ANALYSIS
Volume 2**

Composite Power System Reliability Evaluation

Prepared by CIGRE Task Force 38.03.10 - 1992



DOCUMENT STRUCTURE

| | <u>Page</u> |
|---|-------------|
| TABLE OF CONTENTS | i |
| LIST OF TABLES | iii |
| LIST OF FIGURES | iv |
| ACKNOWLEDGEMENTS | iv |
| LIST OF MEMBERS CIGRE WORKING GROUP 38-03 | v |
| LIST OF PARTICIPANTS CIGRE TASK FORCE 38-03-10 | vi |
| EXECUTIVE SUMMARY | viii |
| SECTION A - INTRODUCTION | 1-1 |
| 1.0 A RELIABILITY OVERVIEW | 1-1 |
| 1.1 Background | 1-1 |
| 1.2 Reliability Concepts | 1-1 |
| 1.3 Adequacy | 1-3 |
| 1.4 Security | 1-3 |
| 1.5 Calculation Methods and Modelling Issues | 1-4 |
| 1.6 Scope of This Study | 1-4 |
| 2.0 DESCRIPTION OF THE NEW BRUNSWICK POWER SYSTEM | 2-1 |
| 2.1 Geography Overview | 2-1 |
| 2.2 In Province Loads | 2-1 |
| 2.3 River Systems and Hydro Generation | 2-2 |
| 2.4 Thermal Generation System | 2-3 |
| 2.5 Maintenance Scheduling | 2-4 |
| 2.6 Interconnection and Contracts | 2-4 |
| 2.6.1 Contractual Transfers | 2-4 |
| 2.6.2 Interconnected System Support | 2-4 |
| 2.7 Transmission System | 2-6 |
| SECTION B - DETERMINISTIC METHODOLOGIES | 3-1 |
| 3.0 RESERVE MARGIN METHOD | 3-1 |
| 3.1 Time Interval of Application | 3-1 |
| 3.2 Reserve Margin or Reserve Megawatts | 3-2 |
| 3.2.1 Reserve Criterion for Peak Capability | 3-2 |
| 3.2.2 Reserve Criterion for Sustained Capability | 3-2 |
| 3.2.3 Reserve Megawatts Calculations | 3-2 |
| 3.3 System Load | 3-3 |
| 3.4 Generating Capacity | 3-3 |
| 3.5 Results | 3-4 |

| Table of Contents Cont'd | Page |
|---|------|
| 3.6 Adequacy and Security in the Reserve Margin Method | 3-5 |
| 4.0 SELECTED BASE AND INCIDENTS METHOD | 4-1 |
| 4.1 General Procedure | 4-1 |
| 4.2 N-1 Criterion | 4-1 |
| 4.3 Incidents | 4-1 |
| 4.4 Results | 4-1 |
| 4.5 Extensions Beyond the N-1 Criterion..... | 4-3 |
| 4.6 Adequacy and Security in the Selected Base and Incidents Method. | 4-3 |
| SECTION C - PROBABILISTIC METHODS FOR GENERATION (HL1) | 5-1 |
| 5.0 DATA AND MODELLING FOR PROBABILISTIC ANALYSIS OF GENERATION | 5-1 |
| 5.1 Modelling Issues | 5-1 |
| 5.2 The Concept of the Peak Load Analysis | 5-1 |
| 5.3 Complete Year HL1 Modelling Details | 5-2 |
| 5.3.1 Unit Forced Unavailabilities | 5-2 |
| 5.3.2 Load Models | 5-2 |
| 5.3.3 Hydro Generation Energy Limitations | 5-2 |
| 5.3.4 Contractual Interconnection Transfers | 5-2 |
| 5.3.5 Interconnection System Support | 5-2 |
| 5.3.6 Interruptible Load | 5-3 |
| 5.3.7 Maintenance | 5-3 |
| 5.4 Peak Load Analysis HL1 Modelling Details | 5-3 |
| 6.0 STATE ENUMERATION | 6-1 |
| 6.1 Complete Year HL1 Analysis by NB Power | 6-1 |
| 6.1.1 Capacity Availability Table | 6-1 |
| 6.1.2 Reliability Indices Used | 6-1 |
| 6.1.3 Consideration of Contracts and Interconnection Support .. | 6-1 |
| 6.1.4 NB Power Complete Year State Enumeration Results | 6-2 |
| 6.2 Constrained Peak load HL1 Analysis by International Participants | 6-3 |
| 7.0 MONTE CARLO | 7-1 |
| 7.1 Complete Year HL1 Analysis by NB Power | 7-1 |
| 7.2 Constrained Peak Load HL1 Analysis by International Participants | 7-2 |
| 7.3 Simulation Parameters | 7-2 |
| 8.0 DISCUSSION AND COMPARISON OF PROBABILISTIC GENERATION RESULTS | 8-1 |
| 8.1 Comparison of Probabilistic Generation Results | 8-1 |
| 8.2 Discussion of Results by Methodology | 8-1 |
| SECTION D - PROBABILISTIC METHODS FOR COMPOSITE SYSTEM RELIABILITY (HL2). | 9-1 |
| 9.0 INPUT DATA AND MODELLING ISSUES FOR COMPOSITE RELIABILITY STUDIES ... | 9-1 |
| 9.1 Complete Year HL2 Modelling Details | 9-1 |
| 9.1.1 Network Configuration | 9-1 |
| 9.1.2 Interconnection Equivalents | 9-1 |

Table of Contents Cont'd

Page

| | |
|---|-------------------|
| 9.1.3 Load Modelling Issues | 9-2 |
| 9.1.4 Common Mode, Hydro and Weather Issues | 9-3 |
| 9.1.5 Modelling Summary | 9-4 |
| 9.2 Constrained Peak Load Modelling Details for HL2 | 9-5 |
| 9.3 Data Preparation | 9-5 |
| 9.4 Generation Dispatch and Load Curtailment Philosophy | 9-5 |
| 10.0 COMPOSITE SYSTEM RELIABILITY RESULTS | 10-1 |
| 10.1 Brief Summary of HL2 Cases | 10-1 |
| 10.2 Composite System Reliability Indices | 10-3 |
| 10.2.1 Overview of Indices | 10-3 |
| 10.2.2 Adequacy Indices Based on the Load Flow | 10-3 |
| 10.3 System Wide Reliability Indices | 10-5 |
| 10.4 Overloaded Transmission Lines | 10-6 |
| 10.5 Load Point Indices | 10-7 |
| 10.6 Additional Results | 10-8 |
| 10.7 Future Considerations | 10-9 |
| APPENDICES | |
| I Generic System Data | I-1 to I-15 |
| II Monthly Load Duration Curve Data | II-1 |
| III Base Case Load Flow Results | III-1 to III-12 |
| IV ENEL Report | IV-1 to IV-10 |
| V Electricidade de Portugal Report | V-1 to V-9 |
| VI Électricité de France Report | VI-1 to VI-7 |
| VII University of Manchester Report | VII-1 to VII-12 |
| VIII National Grid Company Report | VIII-1 to VIII-13 |
| IX University of Saskatchewan Report | IX-1 to IX-16 |
| X Power Technology Inc. Report | X-1 to X-10 |

LIST OF TABLES

| <u>Table</u> | <u>Title</u> | <u>Page</u> |
|--------------|--|-------------|
| 1* | Summary of Participating Groups and Models | viii |
| 2* | Summary of Results - Expected Energy Not Served | ix |
| 2.1 | System Study Load Forecast | 2-2 |
| 2.2 | Hydro Generating Station Capabilities | 2-2 |
| 2.3 | Monthly Available Hydro Energies (GWh) | 2-3 |
| 2.4 | Thermal Generating Station Capabilities | 2-3 |
| 2.5 | Maintenance Schedule | 2-4 |
| 2.6 | Contractual Power Transfers | 2-4 |
| 2.7 | Interconnection Support in MW | 2-6 |
| 3.1 | Peak Capability Criteria | 3-4 |
| 3.2 | Sustained Capability Criteria | 3-5 |
| 3.3 | Comparison of Peak and Sustained Criteria Surplus/(Deficit) in MW | 3-5 |
| 4.1 | Buses with Voltages Out of Limits | 4-2 |
| 4.2 | Lines Which Are Overloaded | 4-2 |
| 5.1 | Nova Scotia System Representation | 5-3 |

* These tables are in the Executive Summary

| Table of Contents Cont'd | | Page |
|--------------------------|--|------|
| 5.2 | Nova Scotia Two-Unit Equivalent | 5-3 |
| 5.3 | New England, Quebec, and Prince Edward Island Representation .. | 5-3 |
| 5.4 | Summary of Generation Only HL1 Cases Studied | 5-4 |
| 6.1 | Results of State Enumeration | 6-1 |
| 6.2 | Results for Reliability Indices for Isolated NB Power System .. | 6-2 |
| 6.3 | Reliability Indices Including Capability of All Interconnections | 6-2 |
| 6.4 | Comparison of Results | 6-2 |
| 6.5 | State Enumeration Results by International Participants | 6-3 |
| 7.1 | Monte Carlo Evaluations by NB Power | 7-1 |
| 7.2 | Monte Carlo Results by Participants | 7-2 |
| 7.3 | Results for Different Simulation Parameters | 7-2 |
| 8.1 | Summary of NB Power Complete Year HL1 Results | 8-1 |
| 8.2 | Peak Load HL1 Evaluation | 8-1 |
| 10.1 | Summary of Composite System HL2 Case Studies | 10-2 |
| 10.2 | HL2 Analysis EENS Results | 10-5 |
| 10.3 | HL2 Analysis LOLE Results | 10-6 |
| 10.4 | Marginal EENS Gain and Ranking for Overloaded Lines | 10-7 |
| 10.5 | Load Point Energy of Curtailment and Ranking | 10-8 |

LIST OF FIGURES

| <u>Figure</u> | <u>Title</u> | <u>Page</u> |
|---------------|---|-------------|
| 1.1 | Reliability Application Guide Methodologies | 1-2 |
| 2.1 | Geographical Location | 2-1 |
| 2.2 | River Systems of New Brunswick | 2-2 |
| 2.3 | Major Transmission Lines | 2-5 |
| 2.4 | One Line Diagram of NB Power System | 2-7 |
| 3.1 | Peak Shaving the Load with Hydro Energies | 3-3 |
| 4.1 | Representation of the Coleson Cove - Courtenay Bay - Norton Area | 4-2 |
| 4.2 | Representation of the Millbank - Newcastle Area | 4-3 |
| 9.1 | Load Duration and Chronological Load Models | 9-2 |
| 10.1 | Transmission Improvements in the Coleson Cove - Courtenay Bay - Norton Area | 10-1 |

ACKNOWLEDGEMENTS

The genesis of CIGRE Task Force 38-03-10 lies with the many people who wanted to see the various power system reliability methodologies applied to, and compared on, an operating power system. However, special acknowledgement must go to David H. Thorne of NB Power who secured the use of the NB Power data for this task, and who was involved in the organization of the work in the early stages. Special thanks are extended to the NB Power Corporation for supporting the project, and to all members of the Task Force for their significant contributions.

CIGRE WG 38-03

LIST OF MEMBERS

Donald T. McGillis - Chairman
Hydro-Québec, Canada

Ronald N. Allan
UMIST
United Kingdom

P. Toby Manning
NGC
UK

Oswaldo Bertoldi
ENEL
Italy

William K. Marshall
New Brunswick Power Corporation
Canada

Murty P. Bhavaraju
Public Service Electric
and Gas Co.
USA

Joseph Mastrocola
Hydro-Quebec
Canada

Roy Billinton
University of Saskatchewan
Canada

P. Jeff Palermo
CSA Energy Consultants
USA

John Endrenyi
Ontario Hydro
Canada

R. Joao Ricardo
EDP
Portugal

E.F. Hill
University of New Brunswick
Canada

Robert J. Ringlee
Power Technologies Inc.
USA

Angelo Invernizzi
ENEL
Italy

Luigi Salvaderi
ENEL
Italy

Juan Kariger
Hidroelectrica Espanola S.A.
Spain

Sergio Scalcino
ENEL
Italy

Bo Krantz
KGS
Sweden

David Thorne
New Brunswick Power Corporation
Canada

Mark Lauby
EPRI
USA

Wolfram Wellssow
FGH
Germany

CIGRE TASK FORCE 38-03-10

LIST OF PARTICIPANTS AND ASSOCIATED SOFTWARE

- (a) Italy, ENEL, program called SIRET
Mr. Osvaldo Bertoldi
ENEL
Direzione Studi E Ricerche
Centro Di Ricerca Elettrica
Via A. Volta 1
20093 Colongo Monzese MI
Italy
Mr. Sergio Scalcino
Mr. Luigi Salvaderi
ENEL
Via Torino 6
00184 Roma
Italy
- (b) Portugal, EDP, program called ZANZIBAR
Mr. Joao Pedro da Silva Ricardo
Electricidade de Portugal
Empresa Publica
Av. Casal Ribeiro, 50
1000 Lisboa
Portugal
Dr. Paulo Barcia
Universidade Nova de Lisboa
Faculdade de Economia
Travessa Estevao Pinto
1000 Lisboa
Portugal
- (c) U.K., NGC, program called ESCORT
Mr. P. Toby Manning
The National Grid Company
National Grid House
Sumner Street
London, SE1 9JU
U.K.
- (d) Canada, University of Saskatchewan, programs called COMREL, MECORE
Dr. Roy Billinton
Department of Electrical Engineering
University of Saskatchewan
Saskatoon, S7N 0W0
Canada
- (e) U.K., UMIST, programs called COMPASS and RELACS
Professor R.N. Allan
Department of Electrical Engineering and Electronics
PO Box 88
Manchester, M6C 1QD
U.K.
- (f) France, Électricité de France, program called MEXICO
Mr. F. Broussolle
Scientific Advisor
Optimization and Simulation Methods Department
Direction des Études et Recherches
1, Avenue du Général de Gaulle
Clamart 92141 France

- (g) U.S.A., Power Technologies Inc., programs called TPLAN and MAREL
Mr. Dag Reppen
Mr. W.R. Puntel
1482 Erie Boulevard
Schnectady N.Y.
U.S.A.
- (h) Canada, NB Power
Mr. W.K. (Bill) Marshall (Co-Chairman)
Mr. Ed Y. Yao
Planning and Development Division
NB Power
P.O. Box 2000
Fredericton, E3B 4X1
Canada
- University of New Brunswick
Dr. Eugene Hill (Co-Chairman)
Department of Electrical Engineering
University of New Brunswick
P.O. Box 4400
Fredericton, E3B 4P4
Canada
- (i) Mr. Jeff Palermo
CSA Energy Consultants
1901 North Fort Myer Drive
Arlington, VA 22209
USA
- (j) Mr. John Endrenyi
Ontario Hydro
Canada
- (k) Mr. Bo Krantz
KGS
Sweden
- (l) Mr. Don McGillis
Hydro Quebec
Canada

EXECUTIVE SUMMARY

In 1988, CIGRE Study Committee 38 published the Power System Reliability Analysis Application Guide. This Guide described various methodologies for power system reliability analysis in use or being developed around the world. The Guide described the approaches, techniques and data requirements for a wide-range of methods. This report supplements that work as an example and comparison of results for combined generation and transmission network reliability evaluations. The key new materials presented here are the results of combined transmission and generation reliability analysis of an actual operating power system. The report presents a complete example, including the data required, the assumptions to be made, and the techniques available for the analysis. Results of the various methods are compared.

CIGRE Task Force 38-03-10 coordinated the development of this example based on the New Brunswick Power Corporation and its forecast conditions for 1996. The Task Force coordinated the analyses made by eight different groups using a variety of computer models to evaluate the New Brunswick system.

The example demonstrates how these techniques and their results may be used to evaluate power system plans. The example presents numeric results from the different models which should be useful in establishing the range of numeric results which may be suitable for setting planning criteria with these models. The example also demonstrates the variety of indices produced by these types of models.

Models Utilized

There were eight participating groups who provided models to evaluate the New Brunswick system. These models use either of two major reliability calculation techniques—State Enumeration or Monte Carlo as summarized in Table 1. Inherent in the models are differences in the way they handle various system components such as hydro generation, loads and interconnections. These are based largely on the different corporate objectives for the various models when they were being developed and written.

Table 1
Summary of Participating Groups and Models

| <u>Group</u> | <u>Country</u> | <u>Model</u> | <u>Methodology*</u> |
|------------------|----------------|-----------------|---------------------|
| ENEL | Italy | SICRET | MC |
| EDP | Portugal | ZANZIBAR | MC |
| USask | Canada | COMREL | SE |
| | | MECORE | MC |
| National Grid | UK | ESCORT | MC |
| UMIST | UK | COMPASS | MC |
| | | RELACS | SE |
| EDF | France | MEXICO | MC |
| PTI | USA | MAREL/ TPLAN | SE |
| NB Power | Canada | NB HL1 | SE/MC |

*Note MC - Monte Carlo, SE - State Enumeration

Cases Evaluated

The New Brunswick system data provided for use by each of the models required transmission reinforcements by 1996. New Brunswick Power provided an appropriate group of transmission network reinforcements. Each of the models was used to evaluate the reliability of the New Brunswick system with and without these network reinforcements.

To help in comparing the various methods, several cases were evaluated for the purpose of making comparisons of the results. First, each of the models was used to evaluate a generation-only reliability case (HL1). Results with all of the models for this analysis were nearly identical. The second series of cases was developed with each of the models evaluating generation and transmission reliability assuming that the peak load exists for the entire year. These cases demonstrated the capabilities for combined generation and transmission reliability analysis (HL2) while maintaining consistency among all the methods in handling hydro-electric dispatch throughout the year, allocation of interconnection power and energy, the number of hours to be considered, scheduling of maintenance and the impact of weather on transmission outages in a full-year analysis. The third series of cases was developed with each of the models which

considered the various load levels throughout the year. The number of load levels, and how they and other system components were handled, was somewhat different in each of the models and therefore these cases demonstrated the most significant differences.

Principal Results

All of the models give reasonably consistent results for the basic measure of system reliability, Expected Energy Not Served (EENS). Differences in the modelling techniques and output indices make comparisons between other measures more difficult. All of the models identified the same facilities as being most critical in the initial system and showed the reliability improvements of the transmission reinforcements.

The EENS for the various models are given in Table 2. The results in the generation-only case are nearly identical. The results for the combined generation and transmission analyses have larger variations. The relative changes due to the transmission enhancements are fairly consistent.

Other Results

Many of the models are capable of identifying the cost of redispatching generation as a result of various generation or

transmission contingencies. The results of these types of models are especially useful for identifying the relative benefits of strengthening specific circuits or network elements within the system. Some of the models are also capable of showing the improvement in the magnitude, frequency and duration of the outages at specific buses as the network is strengthened. Several of the models are capable of providing additional information for individual circuits such as histograms for the magnitude, frequency, and duration of curtailing interruptible customers.

Limitation of the Evaluation

The techniques used for this evaluation are based on steady-state conditions only. The models evaluate the impact on reliability of various outages within the transmission network and of generation equipment by comparing the steady-state conditions. No analysis is made as to whether the system can survive the transition from one steady-state condition to another. For each of the contingency conditions, the system is redispatched and adjusted so that all elements will be within normal limits after the contingency. The generation redispatch is adjusted to correct any circuit loading and voltage conditions in a simple manner based on a generation dispatch order. In all cases, customer interruptions are the method of last resort.

Table 2
Summary of Results - Expected Energy Not Served
(GWh)

| Model | <u>Generation Only Case (HL1)</u> | | <u>Generation and Transmission Cases (HL2)</u> | | | |
|-----------------|-----------------------------------|---------------|--|------|----------------------------------|-----|
| | Peak Load | Complete Year | <u>Peak Load</u> | | <u>Complete Year</u> | |
| | | | <u>Transmission Enhancements</u> | | <u>Transmission Enhancements</u> | |
| | | | No | Yes | No | Yes |
| SICRET | 15.5 | 0.28 | 72.4 | 17.7 | 3.5 | 1.9 |
| ZANZIBAR | 15.1 | 1.50 | 50.8 | 17.4 | 5.4 | 2.1 |
| COMREL | -- | -- | 46.7 | 20.6 | -- | -- |
| MECORE | 14.7 | 0.20 | 52.9 | 16.4 | 1.1 | 0.5 |
| ESCORT | 13.1 | -- | 93.4 | 15.4 | -- | -- |
| COMPASS | 15.7 | 0.12 | 75.3 | 16.8 | 0.8 | 0.2 |
| RELACS | 15.2 | -- | 38.1 | -- | -- | -- |
| MEXICO | 15.2 | 0.80 | 69.1 | 16.6 | 6.1 | 3.1 |
| MAREL/ TPLAN | 13.6 | -- | -- | -- | -- | -- |
| NB HL1 | 14.5 | 0.31 | -- | -- | -- | -- |

Table 2.3
Monthly Available Hydro Energies (GWh)

| <u>Month</u> | <u>Average</u> | <u>Adverse</u> |
|--------------|----------------|----------------|
| January | 144.3 | 62.9 |
| February | 122.1 | 41.5 |
| March | 158.2 | 44.1 |
| April | 389.1 | 44.8 |
| May | 502.7 | 392.8 |
| June | 245.1 | 151.5 |
| July | 169.1 | 79.1 |
| August | 151.8 | 46.2 |
| September | 151.2 | 43.2 |
| October | 190.8 | 52.4 |
| November | 218.0 | 76.4 |
| December | 210.3 | 62.4 |
| Annual Total | <u>2656.7</u> | <u>1371.3</u> |

2.4 Thermal Generation System

The total generating capacity is 4320 MW. This is made up of 13 conventional thermal units with a capacity of 2265 MW, one nuclear unit with a capacity of 635 MW and 7 combustion turbine peaking units with a capacity of 550 MW in addition to the 24 hydro units with a capacity of 870 MW. The thermal generation system capabilities are given in Table 2.4.

Table 2.4 Thermal Generating Station Capabilities

| <u>Plant</u> | <u>Unit</u> | <u>Fuel</u> | <u>Capacity (MW)</u> | <u>DAFOR</u> | <u>Location</u> |
|---------------|-------------|-------------|----------------------|--------------|---|
| Belledune | 1 | Coal | 450.0 | 0.12 | North coast on Bay of Chaleur |
| Chatham | 2 | Coal/Oil #6 | 20.0 | 0.10 | East coast on Miramichi Bay |
| Coleson Cove | 1 | Oil #6 | 335.0 | 0.10 | South coast on Atlantic Ocean |
| | 2 | Oil #6 | 335.0 | 0.10 | |
| | 3 | Oil #6 | 335.0 | 0.10 | |
| Courtenay Bay | 1 | Oil #6 | 44.5 | 0.10 | South coast on Atlantic Ocean |
| | 2 | Oil #6 | 12.3 | 0.10 | |
| | 3 | Oil #6 | 100.0 | 0.10 | |
| | 4 | Oil #6 | 97.0 | 0.10 | |
| Dalhousie | 1 | Oil #6 | 103.0 | 0.10 | North coast on Bay of Chaleur |
| | 2 | Coal/Oil #6 | 203.0 | 0.12 | |
| Grand Lake | 8 | Coal | 60.0 | 0.12 | Center of Province near coal fields |
| | 9 | Coal | 170.0 | 0.12 | |
| Grand Manan | 10 | Oil #2 | 25.0 | 0.10 | Island, off south westerly area of Province |
| Moncton | 1 | Oil #2 | 25.0 | 0.10 | South eastern area |
| Millbank | 1 | Oil #2 | 100.0 | 0.10 | East Coast on Miramichi Bay |
| | 2 | Oil #2 | 100.0 | 0.10 | |
| | 3 | Oil #2 | 100.0 | 0.10 | |
| | 4 | Oil #2 | 100.0 | 0.10 | |
| Point Lepreau | 1 | Nuclear | 635.0 | 0.12 | South coast on Atlantic Ocean |
| Ste Rose | 1 | Oil #2 | <u>100.0</u> | 0.10 | East Coast on Miramichi Bay |
| | | | 3449.8 | | |

SECTION A - INTRODUCTION

- (a) A RELIABILITY OVERVIEW in Chapter 1.0 provides an overview of the reliability methodologies.
- (b) DESCRIPTION OF THE NEW BRUNSWICK POWER SYSTEM in Chapter 2.0 addresses the characteristic nature of the NB Power system as it has been defined for this comparison exercise.

1.0 A RELIABILITY OVERVIEW

1.1 Background

In the flow of events sense, and also in the flow of power sense, there is a logic to the patterns which take place in a power system. Power is generated in generators, it is transmitted in bulk over transmission lines, it is distributed in somewhat smaller blocks over the electrical distribution system, and it is utilized in even smaller blocks by individual customers (the GIDU pattern).

The same patterns apply in reliability analysis, and these patterns have been given names.

- (a) When the reliability analysis includes only generation, it is called Hierarchical Level 1 (HL1).
- (b) When the reliability analysis includes generation and transmission, it is called composite system reliability and also Hierarchical Level 2 (HL2).
- (c) When the reliability analysis includes generation, transmission and distribution, it is called Hierarchical Level 3 (HL3).

CIGRE Working Group 38-03, in 1987, published a document entitled Power System Reliability Analysis Application Guide (hereafter referred to as the Application Guide). This comprehensive document, which focused primarily on HL1 and HL2 reliability, covered many aspects of power system reliability including:

- (a) Concepts, principles, objectives and criteria
- (b) Reliability indices
- (c) Methodologies

- (d) Generation equipment outage data collection and processing
- (e) Transmission equipment outage data collection and processing
- (f) Dependency concepts
- (g) Weather modelling
- (h) Substation modelling

The objective of this present document is to apply the various methodologies with sample calculations for an operating power system. The Application Guide outlines four fundamental methodologies which can be applied for HL1 and HL2 reliability evaluations.

- (a) A deterministic generation method called Reserve Margin (HL1).
- (b) A deterministic generation and/or transmission method called the Selected Base and Incidents method (HL2).
- (c) A probabilistic generation and/or transmission method called State Enumeration (HL1 and HL2).
- (d) A probabilistic generation and/or transmission system method called Monte Carlo Simulation (HL1 and HL2).

Based on material taken from the Application Guide, a flow sheet has been prepared which shows the important features of the methodologies. They are contained in Chapter 3 of the Application Guide and given here as Figure 1.1.

1.2 Reliability Concepts

Reliability is a general term which can be applied to any physical system. Often it can be used in a very crisp sense, such as stating the probability that a certain combination of generators and lines is available. Other times it needs added definition, such as saying how stable a power system is given that a specific combination of generators and lines is available. The latter is particularly important in power systems for a number of very good reasons. These include the physical distances involved in transmission lines, the electrical strength of the transmission lines, the rotational nature of the generators, the usual operating limitations on devices, and finally the vast number of acceptable combinations of generator outputs for any given load depending on the




Figure 1.1 - Reliability Application Guide Methodologies

emphasis placed on cost, stability, security or other like factors.

As a result, and keeping in mind that it has taken tens of years of research and development to get there, it has become

standard practice to use three terms to properly establish the reliability concepts associated with an electric power system. These are reliability, adequacy, and security. The definitions of these terms very closely follows those given in the Application Guide.

Reliability is a general term encompassing all the measures of the ability of the system, generally given as numerical indices, to deliver electric energy to all points of utilization within acceptable standards and in the amounts desired.

It is necessary to put the reliability work in a historical context. It has evolved over a period of more than forty years. With the evolution of the theory, and more particularly with the availability of the computational power to carry out the studies, it became clear that it was necessary to describe two attributes of power system reliability. These are adequacy and security. It is not unnatural, because of the evolutionary development process, that the indices which were historically referred to as reliability indices now became known as adequacy indices and that, using the now available computer power, security indices would be additionally defined and computed.

1.3. Adequacy

Adequacy is a measure of the ability of the power system to supply the electric power and energy requirements of the customers within component ratings and voltage limits, taking account of planned and unplanned outages of system components. Adequacy measures the capability of the power system to supply the load in all the steady states in which the power system may exist.

The state of a power system is one combination of loads, available generators, and available transmission lines. The first step in any adequacy evaluation is to produce the states of the power system one at a time. This can be done by a simple, exhaustive listing of states as in the State Enumeration method, or the states can be listed by a process which is weighted or controlled by the statistics of their availability as in the Monte Carlo method. It is worth emphasizing that the states of the power system which have been produced are steady states.

The load flow is the basic study which is carried out in the steady state. An adequacy evaluation based on the load flow normally consists of the following three steps.

- (a) For each state of the power system run a load flow, or equivalent such as a d-c load flow or transportation solution. (This means running as many load flows as there are states produced, often in the thousands).
- (b) If a given state of the power system is not able to supply the load power and energy, or if some transmission lines are overloaded, invoke a Load Curtailment Philosophy and re-run the load flow.
- (c) After all the states have been produced, determine adequacy indices such as Loss of Load Expectation, Expected Energy Not Served, frequency of line overloads, frequency of low voltage occurrences, and the like.

1.4 Security

Security is a measure of the electric power system to withstand sudden disturbances such as electric short circuits or unanticipated loss of system components (together with consideration of operating constraints).

Security means taking the power system in each of the states for which an adequacy evaluation has been carried out, and evaluating how successfully and securely it might have got to that state, how successfully and securely it might move to another state, and how successfully it might withstand sudden disturbances such as electric short circuits.

For immediate illustrative purposes consider briefly a small power system which has three generators and two transmission lines. Assume that an adequacy evaluation has been carried out for the following state of the power system:

- G1 - available
- G2 - available
- G3 - unavailable
- L1 - available
- L2 - unavailable

- (a) It is possible to get to this state from an $N \pm 1$ state by one of the following:
- Adding G1
 - Adding G2
 - Losing G3
 - Adding L1
 - Losing L2
- (b) It is possible to move away from this state to an $N \pm 1$ state by one of the following:
- Losing G1
 - Losing G2
 - Adding G3
 - Losing L1
 - Adding L2

On the generally true assumption that the addition of a component will make the system more secure, the security of moving to and from a state for which an adequacy examination has been carried out can be satisfactorily evaluated by looking at the loss of available generators and lines one at a time.

As discussed earlier, adequacy examines the performance of the power system one state at a time. Security takes the system in each of the adequacy states, and looks at its behaviour upon the loss of one component.

(This, of course, means running potentially thousands of load flows for each of the potentially thousands of states for which adequacy has been evaluated).

This work is in the development state. A concise example of one process for various Test Systems is given in a paper by Billinton and Khan entitled "Security Considerations in Composite Power System Reliability Evaluation" and appearing in IEE Conference Proceedings No. 338 Probabilistic Methods Applied to Electric Power Systems (PMAPS), July 1991. Simply put, this method defines five classes of states in which the power system can exist namely Normal, Alert, Restorative, Emergency and Extreme Emergencies, and it counts the number of times that the power system lies in each class thus establishing a relative frequency or probability for each class.

For each of the adequacy states, it is useful to arrive at a measure of the system to withstand sudden disturbances such as electric short circuits or unanticipated loss of

system components. This can be done by starting with the power system in each of the adequacy states and seeing how it survives the loss of any one component. (This, of course, means running potentially thousands of stability runs for each of the potentially thousands of states for which adequacy has been evaluated). Simply put, such a process is the exhaustive version of the Selected Base and Incidents method and might appropriately be called the Exhaustive Base and Incidents method.

1.5 Calculation Methods and Modelling Issues

As the report evolves, it will be clear that a distinction must be made between calculation methods and modelling issues. Figure 1.1 shows that the probabilistic calculation methods are State Enumeration and Monte Carlo simulation. In applying either of the calculation methods it is necessary to address many specific modelling issues such as load and hydro system representation. These modelling issues are often considered in very different ways in different software packages and may influence the resulting reliability indices.

A consequence of this is the virtual impossibility of making valid comparisons of the adequacy standards of different countries simply by comparing their reliability indices.

All of the calculations of this work apply specifically to the NB Power system and great care has been taken to provide consistent models so that the results of the different software packages may be as comparable as possible.

1.6 Scope of This Study

The output of this study will be the adequacy risk indices which describe the ability of the system to supply energy under various contingencies. It should be noted that the methodologies used involve only adequacy considerations: they do not verify the ability of the system to pass from one state to another nor do they assess the security of the new state. Evidently any security assessment would involve load flow and stability and would limit the population of contingencies to be considered and thus the whole probabilistic approach. Nevertheless it is expected that one day we will be able to include this aspect so as to complete the reliability story.

2.0 DESCRIPTION OF THE NEW BRUNSWICK POWER SYSTEM

This section provides a general technical overview of the NB Power system. An attempt has been made to make it both introductory, and complementary, to the Input Data which is required for the various reliability methodologies.

The NB Power system is a useful one for study for different reasons.

- (a) For its size, it has relatively large generating units.
- (b) It is small and computationally manageable, yet it has an interesting blend of hydro, conventional thermal, nuclear, and combustion turbine generation.
- (c) While it is small, its geographical location has allowed it to serve in a power broker capacity. It is interconnected with six utilities within Canada and the United States.
- (d) It has successfully adopted developing technologies including the first solid state High Voltage Direct Current link in Canada, a large Candu nuclear plant, and a Static Var Compensator on a major 345 kV interconnection to the USA.

2.1 Geography Overview

The Province of New Brunswick is located in eastern Canada as shown in Figure 2.1. It has a population of 725,000 people, an area of 100,000 square kilometres. At the south-east, it is connected to the Province of Nova Scotia which is served by the provincially owned Nova Scotia Power Corporation. Offshore to the east, Prince Edward Island is served by a privately owned utility called Maritime Electric Company Limited. At the north the Province of Quebec is served by the provincially owned Hydro Quebec. To the west the state of Maine in the United States is served by four privately owned utilities.

2.2 In-Province Loads

The in-Province peak load including losses for the study system is projected to be




Figure 2.1
Geographical Location

3156 MW with a total consumption of 16035 GWh. Included in this total is 52 MW of load which is normally supplied at high load factors, but which can be interrupted when needed by the utility for firm customers.

Because of the relative severity of the winters, and the amount of electric heating in homes, the peak load occurs during the cold winter months; December, January or February (which are also, unfortunately, periods of low hydro flow). Quantitatively, the peak demand for July is about 60% of the peak demand for January. Energy consumption for January and July proportionally have the same relationship.

The electrical demand for New Brunswick is made up of a number of sectors. The industrial sector is the largest single component of load making up about 25% of the peak demand and 40% of the total energy consumption. Of this, the forest industry is the largest and mining is second. These power intensive industries account for a higher proportion of the NB Power total load than is the case for most utilities.

Combining the effects of winter electric heat and industrial base load we can say that:

- (a) The daily load factor for the system is quite high (80 - 90%).
- (b) The annual load factor for the system is much lower (60%).

Table 2.1 provides a forecast of the monthly peak loads and energy requirements for the study system.

Table 2.1
Study System Load Forecast

| <u>Month</u> | <u>Energy Requirements (Gwh)</u> | <u>Peak Load (MW)</u> |
|--------------|----------------------------------|-----------------------|
| April | 1341 | 2432 |
| May | 1206 | 2209 |
| June | 1095 | 1942 |
| July | 1021 | 1767 |
| August | 1062 | 1854 |
| September | 1074 | 1962 |
| October | 1233 | 2199 |
| November | 1424 | 2550 |
| December | 1631 | 2913 |
| January | 1754 | 3156 |
| February | 1590 | 2960 |
| March | 1605 | 2887 |




Figure 2.2
River Systems of New Brunswick

2.3 River Systems and Hydro Generation

The major river in the Province is the Saint John. It is approximately 400 km long. It has its source in the United States and in the upper reaches, occurring in the north western part of the Province, it forms the border between New Brunswick and the state of Maine. Following this section, the river generally flows from north to south. At about the 200 km point, the river turns in a somewhat easterly direction and it empties into the Atlantic Ocean at about the mid point of the southern end of the Province. At about the 125 km point, a river called the Tobique flows into the east side of the Saint John river. The Tobique river in turn has a feeder river called the Sisson.

There are two other small rivers which are also involved in hydro generation. The Saint Croix river forms the boundary between New Brunswick and Maine at the south-western end of the Province. Approximately halfway between the Saint John and the Saint Croix is a short river called the Musquash. Figure 2.2 shows these river systems within the Province.

The hydro generation system experiences low flows in winter and summer with very high flows during the spring snow melt season. These flows are also subject to variation in each month dependent on weather impacts. Most analysis can be conducted by using long term average hydro generation energies. Extreme low energy production under adverse conditions can

be used to define the lower limit of the hydro system.

The monthly low available hydro energy is based on 95% available flow, that is low values of flows which will be available 95% or more of the time. These monthly energies are determined from analysis of historical records.

A summary of hydro station capabilities and energies are provided in Table 2.2 and Table 2.3.

Table 2.2
Hydro Generating Station Capabilities
Annual Energy

| <u>Plant</u> | <u>Unit</u> | <u>Capacity (MW)</u> | <u>Average (Gwh)</u> | <u>Adverse (Gwh)</u> |
|--------------------|-------------|----------------------|----------------------|----------------------|
| Grand Falls | 1 | 15.2 | 437 | 260 |
| | 2 | 15.2 | | |
| | 3 | 15.2 | | |
| | 4 | 15.2 | | |
| Beechwood | 1 | 36.0 | 478 | 257 |
| | 2 | 36.0 | | |
| | 3 | 40.0 | | |
| Mactaquac | 1 | 110.0 | 1597 | 770 |
| | 2 | 110.0 | | |
| | 3 | 110.0 | | |
| | 4 | 110.0 | | |
| | 5 | 110.0 | | |
| | 6 | 110.0 | | |
| Tobique | 1 | 10.0 | 94 | 54 |
| | 2 | 10.0 | | |
| Sisson | 1 | 8.4 | 19 | 9 |
| Musquash | 1 | 5.2 | 16 | 11 |
| Hilltown | 1-7 | 3.6 | 17 | 10 |
| TOTAL HYDRO | | 870.1 | 2657 | 1371 |

Table 2.3
Monthly Available Hydro Energies (GWh)

| <u>Month</u> | <u>Average</u> | <u>Adverse</u> |
|--------------|----------------|----------------|
| January | 144.3 | 62.9 |
| February | 122.1 | 41.5 |
| March | 158.2 | 44.1 |
| April | 389.1 | 44.8 |
| May | 502.7 | 392.8 |
| June | 245.1 | 151.5 |
| July | 169.1 | 79.1 |
| August | 151.8 | 46.2 |
| September | 151.2 | 43.2 |
| October | 190.8 | 52.4 |
| November | 218.0 | 76.4 |
| December | 210.3 | 62.4 |
| Annual Total | <u>2656.7</u> | <u>1371.3</u> |

2.4 Thermal Generation System

The total generating capacity is 4320 MW. This is made up of 13 conventional thermal units with a capacity of 2265 MW, one nuclear unit with a capacity of 635 MW and 7 combustion turbine peaking units with a capacity of 550 MW in addition to the 24 hydro units with a capacity of 870 MW. The thermal generation system capabilities are given in Table 2.4.

Table 2.4 Thermal Generating Station Capabilities

| <u>Plant</u> | <u>Unit</u> | <u>Fuel</u> | <u>Capacity (MW)</u> | <u>DAFOR</u> | <u>Location</u> |
|---------------|-------------|-------------|----------------------|--------------|---|
| Belledune | 1 | Coal | 450.0 | 0.12 | North coast on Bay of Chaleur |
| Chatham | 2 | Coal/Oil #6 | 20.0 | 0.10 | East coast on Miramichi Bay |
| Coleson Cove | 1 | Oil #6 | 335.0 | 0.10 | South coast on Atlantic Ocean |
| | 2 | Oil #6 | 335.0 | 0.10 | |
| | 3 | Oil #6 | 335.0 | 0.10 | |
| Courtenay Bay | 1 | Oil #6 | 44.5 | 0.10 | South coast on Atlantic Ocean |
| | 2 | Oil #6 | 12.3 | 0.10 | |
| | 3 | Oil #6 | 100.0 | 0.10 | |
| | 4 | Oil #6 | 97.0 | 0.10 | |
| Dalhousie | 1 | Oil #6 | 103.0 | 0.10 | North coast on Bay of Chaleur |
| | 2 | Coal/Oil #6 | 203.0 | 0.12 | |
| Grand Lake | 8 | Coal | 60.0 | 0.12 | Center of Province near coal fields |
| | 9 | Coal | 170.0 | 0.12 | |
| Grand Manan | 10 | Oil #2 | 25.0 | 0.10 | Island, off south westerly area of Province |
| Moncton | 1 | Oil #2 | 25.0 | 0.10 | South eastern area |
| Millbank | 1 | Oil #2 | 100.0 | 0.10 | East Coast on Miramichi Bay |
| | 2 | Oil #2 | 100.0 | 0.10 | |
| | 3 | Oil #2 | 100.0 | 0.10 | |
| | 4 | Oil #2 | 100.0 | 0.10 | |
| Point Lepreau | 1 | Nuclear | 635.0 | 0.12 | South coast on Atlantic Ocean |
| Ste Rose | 1 | Oil #2 | <u>100.0</u> | 0.10 | East Coast on Miramichi Bay |
| | | | 3449.8 | | |

2.5 Maintenance Scheduling

NB Power takes advantage of low summer loads to do most of its maintenance. This leaves the entire generation system available to meet the winter peak which is expected in January.

For the study system the maintenance schedule employed is given in Table 2.5.

Table 2.5
Maintenance Schedule

| <u>Units</u> | <u>Outage Length</u> | <u>Months</u> |
|------------------------|----------------------|---------------|
| <u>Nuclear/Thermal</u> | | |
| Lepreau 1 | 4 weeks | May |
| Coleson | 7 weeks/unit | June-October |
| Dalhousie 1 | 5 weeks | April |
| Dalhousie 2 | 4 weeks | June |
| Courtenay | | |
| Bay 3/4 | 6 weeks/unit | April-June |
| Courtenay | | |
| Bay 1 | 6 weeks/unit | March-April |
| Grand Lake 8 | 4 weeks | April |
| Grand Lake 9 | 4 weeks | August |
| Belledune | 4 weeks | July |
| Tracadie | 4 weeks | May |
| Millbank | 4 weeks/unit | June-Sept. |
| <u>Hydro</u> | | |
| Grand Falls | 1 week/unit | Feb.- March |
| Tobique | 1 week/unit | March |
| Mactaquac | 2 weeks/unit | June-August |
| Beechwood | 1½ week/unit | August |

2.6 Interconnections and Contracts

NB Power has interconnections with Canadian and United States utilities as shown in Figure 2.3. The power flows across these interconnections influence the operation and reliability of the NB Power system. These flows may generally be categorized as a contractual transfer, interruptible economy energy interchange and emergency interconnection support. For analysis purposes of system reliability the economy interchange may be ignored, but both contractual transfers and emergency interconnection support must be included.

2.6.1 Contractual Transfers

NB Power has contractual transfers which may be described as participation and/or joint ownership contracts. In this type contract, NB Power sells all or part of the output of a unit to an industry or to a neighbouring utility. If the unit is available the sale is made, but if the unit is not available the sale is interrupted. A summary of the contracts assumed to be in place for the test system is provided in Table 2.6.

Table 2.6
Contractual Power Transfers

| <u>Purchaser</u> | <u>Units</u> | <u>Expected Capacity MW</u> | <u>Capacity Factor</u> |
|----------------------|---------------|-----------------------------|------------------------|
| New England | Pt. Lepreau | 230 | 80% |
| Prince Edward Island | Dalhousie #2 | 20 | 80% |
| | Belledune | 40 | 80% |
| Hydro Quebec | Millbank #1-4 | 400 | 6% |
| | Total | 690 | |

These contracts totalling 690 MW constitute 16% of the total NB Power generation capacity of 4320 MW. All the contracts are base load and tied specifically to their respective generating unit except for the Hydro Quebec 400 MW. In this contract when the Millbank units are not required by Hydro Quebec they are available for NB Power. Conversely if a Millbank unit is not available NB Power will still supply the contract from the rest of the system and interrupt only prior to not supplying in-Province customer firm load.

2.6.2 Interconnected System Support

The support available from an external interconnected system depends upon the availability of surplus generation resources in that system and upon the transmission delivery capability within the external system and through the interconnection. Since in most cases it is not possible or practical to include the total external system in the calculations, it is then necessary to develop some equivalent model for each external system. This is a complex issue which is discussed in




Figure 2.3 - Major Transmission Lines

more detail in Chapter 5.0. However at this stage, Table 2.7 defines the different interconnected systems and estimates the amount of capacity support available to NB Power.

Table 2.7
Interconnection Support in MW

| <u>External System</u> | <u>Transmission Maximum</u> | <u>Possible Support</u> |
|------------------------|-----------------------------|-------------------------|
| Nova Scotia | 700 | 400 |
| Prince Edward Island | 150 | 20 |
| Hydro Quebec | 1000 | 500 |
| Maine Public Service | 100 | 20 |
| New England Pool | 1000 | 400 |

2.7 Transmission System

There are 7000 km of transmission circuits. Figure 2.3 geographically shows that the basic transmission voltage level of 138 kV makes three loops within the Province with radial feeds to some areas. This is overlaid by a tree of 230 kV lines, which is contained within a grid or ring of 345 kV lines around the perimeter of the Province. The 69 kV system is basically a distribution network but in some cases closes a loop between otherwise radial 138 kV lines.

The objective of this work is to illustrate the application of reliability methods to an operating power system. To do this, some adjustments to the transmission system can make the problem much more manageable with little impact on the final result. Three simplifications have been made to the actual NB Power system to produce a study system for evaluation purposes.

- (1) The system configuration has been simplified somewhat. The 69 kV system has been dropped and all loads and generators moved to appropriate 138 kV nodes. Also distributed loads tapped from 138 kV lines have been lumped together. These changes make the system computationally more manageable.
- (2) A phase shifting transformer at the Norton 138 kV node has been removed. This will ease the modelling requirements, and more importantly provide a network weakness in the Coleson Cove-Courtenay Bay - Norton area that can be detected by the reliability analysis.
- (3) The Newcastle - Millbank 138 kV transmission line is rated at the nominal 138 kV rating of 140 MVA. This is insufficient capacity for certain contingency situations and so provides a second weakness to be detected in the analysis.

Figure 2.4 is a one line diagram of the complete NB Power base study system configuration. As shown in the lower right, the diagram is color coded according to voltage level and generation type. Included on the diagram are transmission line lengths, transformer ratings and the interconnection system support generation. Detailed system data, for the base study system including transmission and transformer data, is given in Appendix I.


The dashed boxes indicate the areas of transmission weakness. They are discussed in detail in Sections 4 and 10 along with proposed transmission improvements.



THE NEW BRUNSWICK
POWER CORPORATION
POWER TRANSMISSION SYSTEM
FOR
CIGRE RELIABILITY STUDY

- THERMAL
 - NUCLEAR
 - HYDRO
 - INTERRUPTIBLE LOAD
- 138 KV
230 KV
345 KV

DATE: SEPT. 1991



SECTION B - DETERMINISTIC METHODOLOGIES

(a) RESERVE MARGIN METHOD appearing in Chapter 3.0 inherently handles only generation.

(b) SELECTED BASE AND INCIDENTS METHOD appearing in Chapter 4.0 allows any incident to occur although the major emphasis is on transmission.

3.0 RESERVE MARGIN METHOD

The load on a power system normally grows according to some regularly shaped trend line. Generation, on the other hand, is installed on a system in megawatt blocks. The result of this is that just after the installation of new generation the installed generation greatly exceeds the system load. As time passes, the two quantities move closer together.

One criterion which specifies the limit of how close the load should be allowed to come toward installed capacity is the reserve margin. The reserve margin is equal to the ratio of the installed or available capacity to the maximum annual load, minus one.

Another way of expressing the criterion based on reserve margin is through a power inequality expression:

$$\text{CAPACITY} - \text{LOAD} \geq \text{RESERVE MEGAWATTS}$$

The criterion based on reserve margin can be established and developed by asking four simple questions about this inequality expression.

1. In what time interval(s) should this power inequality expression be checked, and be required to hold? As a first response, if the maintenance patterns were always perfectly uniform then possibly it should be checked only once a year.
2. What is in the definition of the term "reserve megawatts", and what should be its numerical value? As a first response, Table 3.1 of the Application Guide shows that in 1987 Finland used a numerical value of 17% of load while the United Kingdom used a numerical value of 23% of load.

3. What components go together to make up the system load? As a first response, it might be only the in-Province or in-country load if the interconnections are interruptible by terms of a contract.
4. What components go together to make up the system capacity? As a first response, a conservative approach would be to ignore any capacity benefits from interconnections.

In the remainder of this section, we will examine the approach which New Brunswick Power has taken in answering these questions for an operating power system.

3.1 Time Interval of Application

The time interval over which the power inequality expression is applied in developing capacity installation patterns depends exclusively on the future period for which a utility has an acceptable level of confidence in its load forecasting capabilities. NB Power employs a 15 year period.

The time interval in which the power inequality expression is applied depends largely on three factors.

- (a) The variability of hydro unit capability with time interval. A month with a high load demand might not be a cause of concern with respect to reserve megawatts if there is high hydro energy and capacity available to met the high load demand. Unfortunately, this is not the case in New Brunswick.
- (b) The required timing for, and duration of, units on maintenance, and the size of the units on maintenance. In New Brunswick the 635 MW Point Lepreau nuclear unit requires an annual maintenance period of one month, and this can only logically be done during the high river flow months of April and May.
- (c) Any variation in interconnection contracts (either purchases or sales) by time interval.

For these reasons, New Brunswick Power has chosen to evaluate the power inequality expression in intervals of one month.

3.2 Reserve Margin or Reserve Megawatts

NB Power has chosen to define reserve megawatts according to two criteria. These are a Criterion for Peak Capability and a Criterion for Sustained Capability. The most restrictive condition possible is chosen in that both criteria must be met in any month in order for any proposed capacity installation pattern to be considered satisfactory.

3.2.1 Reserve Criterion for Peak Capability

For this criterion, generating capacity is determined as the sum of hydro and thermal generation with 100% availability at rated capacity, and no reliance is placed on interconnections.

The numerical value of reserve megawatts is the capacity of the largest unit used on the system or 20% of the firm load, whichever is greater.

3.2.2 Reserve Criterion for Sustained Capability

For this criterion, the thermal generation is taken with 100% availability at rated capacity. The hydro is taken as the maximum capacity the total hydro generating units can supply when the total available hydro energy at 95% probable conditions (that is, low flows) is fitted under the load duration curve for each month. (This is a process called peak shaving with hydro, and it is discussed in more detail in the later section on generating capacity.)

The numerical value of reserve megawatts is more complicated in the criterion for sustained capability. This is an energy based criterion which requires that the so-called Maritime system, consisting of New Brunswick, Nova Scotia and Prince Edward Island, be able jointly to withstand the sustained loss of the larger of 10% of the interconnected system load or the largest unit on the interconnected system under conditions of historically low available hydro energy (that is, 95% probability conditions on the flow) on the NB Power system.

The above value of reserve megawatts is for the systems jointly. It is necessary to specify the proportion of the reserve megawatts which each system must meet.

- (a) If the size of the largest unit is less than or equal to 10% of the interconnected system load, then each individual utility maintains 10% of their forecast load as the reserve requirement.
- (b) If the size of the largest unit is greater than 10% of the interconnected load, each utility maintains a reserve equal to 10% of their forecast load with the utility owning the largest unit being responsible for the remainder.

There is one more factor. Because NB Power has strong interconnections to Quebec and the New England states, it relies on these interconnections for 25% of the total sustained reserve requirements.

3.2.3 Reserve Megawatts Calculations

We are going to illustrate these calculations for the study system as described in Chapter 2. With the Participation Sales included, the quantity of 230 MW generated at Point Lepreau goes directly as a sale. It nets to zero, and leaves the effective maximum capacity of Point Lepreau at $635 - 230 = 405$ MW. This makes Belledune the largest unit with a capacity of $450 - 40 = 410$ MW after its sale to PEI is subtracted.

- (a) Reserve Criterion for Peak Capability

| | |
|--|--------|
| Largest generating unit on NB Power System | 410 MW |
| 20% of N.B. firm load 0.2×3104 | 621 MW |
| Greater of these two: | |
| Peak Capability Reserve | 621 MW |

- (b) Reserve Criterion for Sustained Capability

| | |
|--|---------------|
| N.B. forecast firm peak demand | 3104 MW |
| N.S. forecast firm peak demand | 2188 MW |
| P.E.I. forecast firm peak demand | <u>150 MW</u> |
| Total Maritime interconnected firm load | 5442 MW |
| 10% of total Maritime Firm Load | 544 MW |
| Largest generating unit on NB Power | 410 MW |
| Because 10% of the Maritime load is larger than the largest unit the rule is proportional sharing. | |
| Maritime interconnected reserve | 544 MW |
| N.B. share of interconnected system reserve $\frac{3104 \times 544}{5442}$ | 310 MW |

Less 25% contribution from Quebec - 136 MW
and New England (0.25 x 544)

Sustained Capability Reserve 174 MW

3.3 System Load

The load for which a reserve margin is needed is the firm, in-Province load. This load is equal to the total forecast for each month less all interruptible load. The amount of interruptible load is 52 MW which, being associated with power intensive industries, is constant in all months. For the peak month of January:

| | |
|-------------------------|--------------|
| N.B. forecast peak load | 3156 MW |
| Interruptible load | <u>52 MW</u> |
| N.B. firm peak load | 3104 MW |

For the Peak Capability evaluation the only requirements are for the peak loads by month for the study year. For Sustained Capability evaluation, the peak loads by month are also required. However, in addition it is also necessary to take into account the energy and shape of each monthly load. This is given by means of the Load Duration Curves specified in 2% time intervals with 51 load points. The shape of the L.D.C. is adjusted to be consistent with the forecasted load energy for each month of the study period.

3.4 Generating Capacity

In evaluating the criterion for Peak Capability, the following factors are considered for determining the generation capacity available:

- (a) The thermal generation is present with 100% availability at rated capacity. That is, no probability of forced outage is considered.
- (b) The hydro generation is present with 100% availability at rated capacity. No consideration of energy limitations is included.
- (c) No reliance is placed on interconnections except for inclusion of firm contract capacity which is netted from the generation.

- (d) All hydro and thermal generating units are placed on maintenance according to the annual long term maintenance schedule.

In evaluating the criterion for Sustained Capability, the following factors are considered for determining the generation capacity available::

- (a) The thermal generation is present with 100% availability at rated capacity. No forced outages are considered.
- (b) For the hydro generation, the determination of available capacity is much more involved. The hydro energies are fitted under their respective load duration curves according to a process called peak shaving, in order to determine the hydro capacity credit. This process is illustrated in Figure 3.1. A certain amount of the monthly hydro energy must be run as base hydro, that is for 100% of the time. The remainder of the hydro energy is fitted into the peak of the Load Duration Curve.




Figure 3.1
Peak Shaving the Load with Hydro Energies

- (c) There is one additional effect present, and that is annual cycle storage hydro which is available in the Saint John river system. It is in fact just hydro energy which is controlled in a special way. This stored energy is released during the months of December - March, so that the storage will be empty to absorb as much as possible of the snow melt run off which begins in April. The stored energy is released in a manner which attempts to levelize the remaining thermal load across the four month period December - March. For simplification of the analysis, this storage energy has already been allocated and is included in the monthly hydro energies.
- (d) All firm contracts are considered by netting the sale capacity from the generation. Interconnection support from Quebec and New England is included by reducing the reserve margin required by 25%.
- (e) Maintenance of thermal units is included as scheduled. Hydro unit maintenance is

not included. This is because the hydro system capacities are those derated values determined after consideration of energy limitations. Since hydro maintenance is scheduled in periods of low water the effect of the maintenance outages is already included in the energy limited hydro capacity.

3.5 Results

The results of the reserve margin analysis reflect the inequality:

$$\text{CAPACITY} - \text{LOAD} \geq \text{RESERVE MEGAWATTS}$$

or

$$\text{CAPACITY} - \text{LOAD} - \text{RESERVE MEGAWATTS} \geq 0$$

Results of the reserve margin analysis are given in Table 3.1 and Table 3.2 respectively for the Peak and Sustained Criteria. In addition to the reserve MW surplus or deficit values, calculation of the amount of percentage capacity reserve in excess of the firm load is included for the Peak Criterion.

TABLE 3.1
PEAK CAPABILITY CRITERIA

| | APR | MAY | JUN | JUL | AUG | SEP | OCT | NOV | DEC | JAN | FEB | MAR |
|-------------------------------------|------|------|------|------|------|------|------|------|------|------|------|------|
| CAPACITY: | | | | | | | | | | | | |
| 1 HYDRO | 870 | 870 | 870 | 870 | 870 | 870 | 870 | 870 | 870 | 870 | 870 | 870 |
| 2 NUCLEAR | 635 | 635 | 635 | 635 | 635 | 635 | 635 | 635 | 635 | 635 | 635 | 635 |
| 3 THERMAL | 2815 | 2815 | 2815 | 2815 | 2815 | 2815 | 2815 | 2815 | 2815 | 2815 | 2815 | 2815 |
| 4 LESS MAINTENANCE | 305 | 835 | 845 | 995 | 750 | 435 | 435 | 0 | 0 | 0 | 7 | 34 |
| 5 PARTICIPATION | 690 | 460 | 670 | 550 | 590 | 590 | 590 | 690 | 690 | 690 | 690 | 690 |
| 6 AVAILABLE CAPACITY (1+2+3-4-5) | 3325 | 3025 | 2805 | 2775 | 2980 | 3295 | 3295 | 3630 | 3630 | 3630 | 3623 | 3596 |
| LOAD: | | | | | | | | | | | | |
| 7 NB FORECAST LOAD | 2432 | 2209 | 1942 | 1767 | 1854 | 1962 | 2199 | 2550 | 2913 | 3156 | 2960 | 2887 |
| 8 LESS: INTERRUPTIBLE | 52 | 52 | 52 | 52 | 52 | 52 | 52 | 52 | 52 | 52 | 52 | 52 |
| 9 TOTAL FIRM LOAD (7-8) | 2380 | 2157 | 1890 | 1715 | 1802 | 1910 | 2147 | 2498 | 2861 | 3104 | 2908 | 2835 |
| RESERVE: | | | | | | | | | | | | |
| 10 NB RESERVE | 621 | 621 | 621 | 621 | 621 | 621 | 621 | 621 | 621 | 621 | 621 | 621 |
| 11 SURPLUS/(DEFICIT): (6-9-10) | 324 | 247 | 294 | 439 | 557 | 764 | 527 | 511 | 148 | (95) | 94 | 140 |
| 12 RESERVE MARGIN | 40% | 40% | 48% | 62% | 65% | 73% | 53% | 45% | 27% | 17% | 25% | 27% |

TABLE 3.2
SUSTAINED CAPABILITY CRITERIA

| | APR | MAY | JUN | JUL | AUG | SEP | OCT | NOV | DEC | JAN | FEB | MAR |
|-------------------------------------|------|------|------|------|------|------|------|------|------|------|------|------|
| CAPACITY: | | | | | | | | | | | | |
| 1 HYDRO | 870 | 870 | 575 | 404 | 333 | 357 | 418 | 487 | 508 | 715 | 568 | 508 |
| 2 NUCLEAR | 635 | 635 | 635 | 635 | 635 | 635 | 635 | 635 | 635 | 635 | 635 | 635 |
| 3 THERMAL | 2815 | 2815 | 2815 | 2815 | 2815 | 2815 | 2815 | 2815 | 2815 | 2815 | 2815 | 2815 |
| 4 LESS MAINTENANCE | 305 | 835 | 735 | 885 | 605 | 435 | 435 | 0 | 0 | 0 | 7 | 22 |
| 5 PARTICIPATION | 690 | 460 | 670 | 550 | 590 | 590 | 590 | 690 | 690 | 690 | 690 | 690 |
| 6 AVAILABLE CAPACITY (1+2+3-4-5) | 3325 | 3025 | 2620 | 2419 | 2588 | 2782 | 2843 | 3247 | 3268 | 3475 | 3321 | 3246 |
| LOAD: | | | | | | | | | | | | |
| 7 NB FORECAST LOAD | 2432 | 2209 | 1942 | 1767 | 1854 | 1962 | 2199 | 2550 | 2913 | 3156 | 2960 | 2887 |
| 8 LESS: INTERRUPTIBLE | 52 | 52 | 52 | 52 | 52 | 52 | 52 | 52 | 52 | 52 | 52 | 52 |
| 9 TOTAL FIRM LOAD (7-8) | 2380 | 2157 | 1890 | 1715 | 1802 | 1910 | 2147 | 2498 | 2861 | 3104 | 2908 | 2835 |
| RESERVE: | | | | | | | | | | | | |
| 10 NB RESERVE | 174 | 174 | 174 | 174 | 174 | 174 | 174 | 174 | 174 | 174 | 174 | 174 |
| 11 SURPLUS/(DEFICIT): (6-9-10) | 771 | 694 | 556 | 530 | 612 | 698 | 522 | 575 | 233 | 197 | 239 | 237 |

Table 3.3
Comparison of Peak and Sustained Criteria
Surplus/(Deficit) in MW

| Month | Peak | Sustained | Most Restrictive |
|-----------|------|-----------|------------------|
| April | 324 | 771 | Peak |
| May | 247 | 694 | Peak |
| June | 294 | 556 | Peak |
| July | 439 | 530 | Peak |
| August | 557 | 612 | Peak |
| September | 764 | 698 | Sustained |
| October | 527 | 522 | Sustained |
| November | 511 | 575 | Peak |
| December | 148 | 233 | Peak |
| January | (95) | 197 | Peak |
| February | 94 | 239 | Peak |
| March | 140 | 237 | Peak |

Results show that the NB Power system is deficient under the Peak Criterion in the month of January by 95 MW. This coincides with a reserve margin of 17% which is below the

desired 20%. There is sufficient capacity in all other months under the Peak Criterion. Under the Sustained Criterion, in Table 3.2, there is surplus capacity in all months. The amount of surplus is greater than the peak surplus in all months except September and October. This is shown in Table 3.3 which summarizes the results by month and indicates which criterion is the most restrictive.

3.6 Adequacy and Security in the Reserve Margin Method.

The Reserve Margin method is very weak in the examination of adequacy. It, in essence, has one generation schedule except that it examines the loads by month. Its principal short-coming is that it ignores any quantification of plant forced outages, so that, for example, there is no way to show the benefit of improved forced outage rates.

The Reserve Margin method attempts to do nothing in the examination of security.

4.0 SELECTED BASE AND INCIDENTS METHOD

Up to the present time many utilities, and particularly the interconnected utilities operating under Coordinating Councils, continue to use deterministic criteria to evaluate transmission system reliability. This is so because the use of probabilistic indices for the reliability evaluation of large transmission systems calls for sophisticated models, and powerful software packages together with the associated hardware.

4.1 General Procedure

The general procedure for the application of the deterministic Selected Base and Incidents methodology has two steps:

1. Select one or several base cases. These should correspond to operating conditions which are considered difficult based on the experience of planning and operating personnel.
2. Subject each case to a series of generation and or transmission incidents and examine how the system withstands the incidents from the following points of view:
 - (a) Flows through system components kept within permissible limits.
 - (b) Voltage changes at network nodes kept within permissible limits.

It is clear that the major analytical tool of the Selected Base and Incidents Method is the load flow.

4.2 N-1 Criterion

The N-1 criterion consists of the simulated loss of one network component such as a line, transformer, cable or even a reactive power component. The loss of a generator may also be considered, although few countries take into account generation outages.

4.3 Incidents

The starting point is the Base Study System under peak load conditions. This system was introduced in Section 2.7 and reference

should also be made to modelling considerations discussed in Chapter 9, the One Line Diagram shown in Figure 2.4, the Generic System Data given in Appendix I, and the Base Case Load Flow Results given in Appendix III. Clearly the Base Case is one in which all line flows and all node voltages are normally within acceptable limits. There are two factors to be considered.

- (a) The system is an operating system, and N-1 contingencies should not normally cause a problem on it.
- (b) As described in Section 2.7, two transmission weaknesses have been built into the Generic Data set.

The system was subjected to a series of incidents, all of them being at the N-1 level and all of them involving the loss of a line or transformer. The following is a list of the element losses to which the system was subjected given in terms of bus terminations:

1. IRVREF-1681 to C.BAY1-1813
2. KESWK3-1803 to LEFRAU-1843
3. KESWK3-1803 to STAND3-1868
4. MACTQC-1809 to KESWK1-1827
5. C.COV3-1836 to C.COV1-1837
(Loss of Transformer 2 of two parallel transformers)
6. C.COV3-1836 to NORIN3-1900
7. SALER3-1850 to NORIN3-1900
8. BELDUN-1913 to BATHS3-1915
9. C.COV1-1837 to MILD47-1860

4.4 Results

The impact of the transmission incidents on the system is discussed in relation to the two areas of transmission weakness.

- (a) Coleson Cove - Courtenay Bay - Norton area

This area as shown in Figure 4.1 is one which has received full study by NB Power. Without the phase shifting transformer between nodes 1836 and 1900, problems can arise. Four of the nine transmission incidents (#1, #6, #7 and #9) cause line overloads and/or voltage problems in the Coleson Cove - Norton area while incident #4 overloads line 1809-1861 out of the Mactaquac plant. The other incidents cause no problems.




Figure 4.1 - Representation of the Coleson Cove - Courtenay Bay - Norton Area

It must be noted that problems caused by four of the five incidents can be overcome by altering the system dispatch. While this altered dispatch would incur an economic penalty it is still preferable to curtailing load. But incident #6, even after altered dispatch, incurs the voltage and line overload problems given in Table 4.1 and 4.2. Note that the low voltage at node 1712 already existed in the base case. This occurs because of the simplification of lumping distributed loads at this particular node. Note also that the overloaded lines in Table 4.2 also show up later in the composite reliability evaluation.

No N-1 incidents on the Base Case Load flow cause any problems in this area. However double and triple contingencies could cause problems as detected later in the composite analysis.

Table 4.1
Buses With Voltage Out of Limits
(per unit)

| <u>Bus</u> | <u>Pre Event Voltage</u> | <u>Post Event Voltage</u> |
|--------------|--------------------------|---------------------------|
| 11356EQ-1712 | 0.935 | 0.917 |

(b) Millbank - Newcastle area

The second area of potential transmission weakness as shown in Figure 4.2 is much more subtle. When generation conditions require dispatch of the 200 MW of combustion turbines at Millbank, then the resultant flow towards Newcastle would exceed the 140 MVA rating of the transmission line if line 1969-1928 were not available. Other transmission incidents could also influence those flows - but redispach of Millbank to below 140 MVA would always avoid the problem.

Table 4.2
Lines Which Are Overloaded

| <u>From Bus</u> | <u>To Bus</u> | <u>Percent Overload</u> |
|-----------------|---------------|-------------------------|
| IRVREF-1681 | LAKED-1717 | 103.2 |
| IRVREF-1681 | C.BAY4-1813 | 164.4 |
| C.BAY1-1813 | MILD47-1860 | 105.3 |
| C.BAY1-1813 | MILD65-1862 | 114.9 |
| C.COV1-1837 | MILD47-1860 | 123.3 |
| C.COV1-1837 | MILD65-1862 | 115.0 |




Figure 4.2 - Representation of the Millbank-Newcastle Area

4.5 Extensions Beyond the N-1 Criterion

NB Power is part of the Northeast Power Coordinating Council (NPCC) within North America. Power system planning within the Coordinating Councils may involve extensions to the N-1 criterion including:

- (a) Examination of transient or dynamic stability during a fault or faults.
- (b) Performance under extreme contingencies.
- (c) Operation of Special Protection Systems.

The N-2 criterion is not used directly by NB Power in system planning. However it is included in some of the extreme contingencies referred to above. Clearly if an N-2 criterion were used there are weaknesses in other areas which would appear, and the situation in the Coleson Cove - Courtenay Bay area, as described in Section 4.3.2, would be exacerbated.

4.6 Adequacy and Security in the Selected Base and Incidents Method

The Selected Base and Incidents method is relatively weak in the examination of adequacy. This is so because there is normally a relatively small number of Selected Base

Cases. Further, the Base Cases are selected deterministically usually based on planning and operational experience. In addition all of the Selected Base Cases are assumed to be equally likely events, since no probabilities are assigned to any of them. As will be seen later, this is in contrast to the State Enumeration process which exhaustively selects states (or Base Cases) while at the same time calculating the probability associated with being in that state. It is also in contrast to the Monte Carlo simulation which selects the states (or Base Cases) on a probabilistic basis thus capturing the ones which are most likely to occur.

The Selected Base and Incidents method is, on the other hand, relatively strong in the examination of security. This is inherent in the definition of the method, since it attempts to look at the effects of Incidents of specific sudden disturbances such as electric short circuits or unanticipated loss of system components. It is strong in the security area from two points of view. First, the state resulting from an unanticipated event such as a short circuit on a major bus is examined in the steady state by means of the load flow to detect voltage and line overload problems. Second, a transient stability analysis might also be carried out to see if the power system can securely transiently arrive at the state resulting from an unanticipated event such as a short circuit on a major bus.

SECTION C - PROBABILISTIC METHODS FOR GENERATION (HL1)

The two probabilistic methods of State Enumeration and Monte Carlo Simulation are, in this section, applied to the generation system by itself (HL1 analysis). The intent is to provide a comparison base for the later composite system reliability analysis.

5.0 DATA AND MODELLING FOR PROBABILISTIC ANALYSIS OF GENERATION

The major issue for probabilistic modelling of generation (the HL1 analysis) is the handling of generator unavailabilities, especially forced unavailabilities. In addition, stochastic treatment of loads and of hydro energy is also possible. Indeed, the calculation method utilized to handle the stochastic treatment defines the two probabilistic methodologies:

- (a) State Enumeration
- (b) Monte Carlo

But before they are considered in detail, it is necessary to look at the system to be studied and describe it in some manner that can be analyzed by application of either method. This requires the reduction of the actual system to a series of manageable models. There are many areas which must be considered, and different approaches which can be taken in each.

5.1 Modelling Issues

The following modelling issues need to be addressed:

1. Unit Forced Unavailabilities
 - Single State (*)
 - Multi State
2. Load Models
 - Load Period
 - annual
 - seasonal
 - monthly (*)
 - weekly
 - Load Shape
 - chronological
 - load duration curve (*)
 - Load Forecast Uncertainty

3. Hydro Generation Energy Limitations
 - peak shaving (*)
 - equivalent thermal
 - energy availability
4. Contractual Interconnection Transfers
 - net from generation (*)
 - add as load
5. Interconnection Support
 - equivalent 100% available generator
 - multi state system equivalent
 - multi unit equivalent (*)
6. Interruptible Load
 - reduce to firm load
 - add 100% available generator(*)
7. Maintenance
 - include in the forced outage rate
 - pre-scheduled outages or derations (*)

The modelling approaches marked by an asterisk (*) are the preferred ones utilized by NB Power engineers for the analysis of their system. However they are not necessarily available within all reliability software packages.

5.2 The Concept of the Peak Load Analysis

The objective of the CIGRE work is to demonstrate the various probabilistic methodologies on an operating power system. As visualized from the outset, the final stage of the work was to use the New Brunswick Power data as input to various international software packages for probabilistic composite system analysis (HL2). As the work progressed, it became evident that all software packages contained the same fundamental probabilistic base structures. However there were differences in handling various components of the power system such as load models and interconnections, largely based on varied but clearly understood corporate objectives for the various software packages when they were being developed and written. These variations in models could cause variations in results.

It is true that it might be possible to reconcile the results from the various international software packages by detailed qualitative arguments. However, this is difficult to do because of the large number of programs used and modelling variations present.

A decision was collectively made by the Working Group to initially constrain the New Brunswick Power operating conditions to a peak load analysis. This hopefully would facilitate clear quantitative comparisons from the various probabilistic methodologies, before proceeding to a more detailed complete year analysis of the NB Power system. The specific modelling details of the complete system are presented in Section 5.3 followed by the simplifications required for the constrained peak load system in Section 5.4.

5.3 Complete Year HLL Modelling Details

Most of the modelling issues outlined in Section 5.1 are examined in more detail.

5.3.1 Unit Forced Unavailabilities

The forced unavailabilities of the thermal units have been given in Table 2.4. These are deration adjusted equivalent unavailabilities that provide for a simple two state model of generation availability.

5.3.2 Load Models

The load model is based on monthly load duration curves. Table 2.1 shows the peak load in MW by month and the energy which must be fitted into the load duration curve. The data to define the shape of the monthly load duration curves is given in Appendix II.

5.3.3 Hydro Generation Energy Limitations

The hydro units, as such, are assumed to be 100% available. However, the MW production level for each time interval under the energy limitations is determined by the peak shaving process. The peak shaving process has already been introduced in the discussion of the Reserve Margin methodology, and it is illustrated in Figure 3.1.

The states, represented by MW production levels, of the hydro generation are basically those determined when using the Sustained Capability Criterion of the Reserve Margin methodology, except that here the monthly

available hydro energies are based on average or 50% availability flows rather than the low or 95% availability flows.

5.3.4 Contractual Interconnection Transfers

The manner in which contract transfers are modelled can greatly alter the results of the reliability calculations. This is especially true for NB Power because the 690 MW total amount of transfer as previously defined in Table 2.6 is large compared to the system size. Because contract transfers are tied specifically to particular generating units the best way to handle them is to net each from their respective generation.

This is easily done for generation only analysis. But when the transmission system is included it is necessary to include the contracts at their proper load point in order to maintain realistic transmission line power flows. This is properly done in load flow studies, but for reliability studies it requires that the load be interrupted when the respective generation is not available. This modelling feature is not available with the large composite system reliability software packages, but it has been done in the in-house programs written for State Enumeration and Monte Carlo methodologies for consideration of the generation system only.

To illustrate the importance of this modelling issue the generation only calculations are being presented both with the contracts netted out from generation and with the contracts included as load.

5.3.5 Interconnection System Support

Table 2.7 shows an estimate of the capacity support to NB Power over the interconnections. Detailed models are now developed for each of the interconnections.

The Nova Scotia Power system is considered in detail to determine the support available to NB Power for the critical month of January. The monthly available hydro energies within the Nova Scotia system are used to peak shave the Nova Scotia in-Province load. This leaves a thermal equivalent load for the Nova Scotia system. A capacity outage table is created for the thermal units on the Nova Scotia system. Any of the capacity states which are greater than the peak of the thermal equivalent load are available to contribute to the NB Power system. When the peak of the

thermal equivalent load is subtracted from each state, a new capacity table for supply to the New Brunswick system is created.

The next step is to handle the interconnection transmission flow limit. In the new capacity table for supply to the New Brunswick system referred to above, any capacity state which is greater than the assumed 400 MW interconnection capacity is assigned a capacity value equal to the interconnection capacity limit and all the associated probabilities are added together. This then provides a final capacity availability and probability table for Nova Scotia as a support over the interconnection to New Brunswick. This support for January is assumed constant in all months. This is given as Table 5.1.

Many modelling programs do not have the capability to handle an interconnection equivalent in such detail. To overcome this problem, a further simplification was made by building a two-generator equivalent system which provides a simplified capacity availability in place of the detailed representation of Table 5.1. This two-unit equivalent is given Table 5.2.

Table 5.1
Nova Scotia System Representation

| Assisting Capacity (MW) | Probability | Cumulative Probability |
|-------------------------|-------------|------------------------|
| 400 | .16165 | .16165 |
| 350 | .20883 | .37048 |
| 300 | .13649 | .50697 |
| 250 | .14397 | .65094 |
| 200 | .13381 | .78475 |
| 150 | .10651 | .89126 |
| 100 | .06898 | .95024 |
| 50 | .03206 | .98230 |
| 0 | .00770 | 1.00000 |

Table 5.2
Nova Scotia Two-Unit Equivalent

| Unit | Capacity (MW) | Probability Available |
|-------|---------------|-----------------------|
| NS #1 | 150 | 0.90 |
| NS #2 | 150 | 0.90 |

New Brunswick also has interconnections east to Prince Edward Island, north-west to

Quebec and south-west to the New England states of the United States. Table 5.3 shows the two-unit equivalents for the four separate systems involved in these interconnections. These representations are not based on any detailed evaluation of these systems. Rather they are a simple estimate.

Table 5.3
New England, Quebec and Prince Edward Island Representation

| Unit | Capacity (MW) | Probability Available |
|----------------------------|---------------|-----------------------|
| New England NE #1 | 250 | 0.90 |
| NE #2 | 250 | 0.90 |
| Maine Public Service MP #1 | 10 | 0.90 |
| Hydro HQ #1 | 300 | 0.95 |
| Quebec HQ #2 | 100 | 0.95 |
| Prince Edward Island PE #1 | 10 | 0.90 |

5.3.6 Interruptible Load

If a load can be interrupted at any time, then this is equivalent on the system to having the same amount of generation available. As a result the interruptible loads are modelled as 100% available generators.

5.3.7 Maintenance

Table 2.5 shows the maintenance schedule for both the hydro generators and the thermal generators. Thermal generator maintenance is modelled in each month as scheduled. When a unit is on maintenance for a portion of a month, it is placed on maintenance for the entire month but at an equivalent derated capacity.

Hydro maintenance is not included because it is scheduled in the low flow months when the limited hydro energy peak shaving makes it redundant.

5.4 Peak Load HLL Modelling Details

The idea was introduced in Section 5.2 of defining a constrained peak load system such that the results could be obtained and compared in order to establish the equivalency of the fundamental probabilistic processes, but

without the encumbrances of any one specific planning objective being structured into the software.

The constrained peak load system HLI analysis was based on the complete year system modelling details described in Section 5.3, with three additional constraints.

- (a) The load at each bus was assumed to exist at the peak level for each of the 8760 hours of the year.
- (b) The hydro was prescheduled at a power value corresponding to the available hydro energy for the year. In essence, the hydro units were treated as 100% available thermal units at a capacity of 650 MW.

(c) Maintenance was not considered.

Since most of the international participants utilized a full composite system reliability software package for the HLI analysis, they also utilized the full composite system data with some minor adjustments to reduce it to HLI requirements. The loads and generation resources used are summarized in Section 9.1.5. Finally it is perhaps useful to state an additional obvious constraint. An HLI analysis is achieved in a composite software package by making all transmission components have 100% availability, and setting their transmission capacity limits to very high values. A summary of conditions of the two HLI cases studied is given in Table 5.4.

**Table 5.4
Summary of Generation Only HLI Cases Studied**

| System Condition or Variable | Peak Load Analysis (done by International Participants) | Complete Year Analysis (done by NB Power) |
|--------------------------------------|---|--|
| Thermal unit forced unavailabilities | Two state deration adjusted | Two state deration adjusted |
| Load conditions | Peak load for 8760 hours | Monthly Load Duration Curves |
| Hydro production | Prespecified at constant 650 MW | Actual production determined by monthly peak shaving |
| Generating unit maintenance | No | Yes |
| Interruptible load | Yes | Yes |
| Contract transfers | Firm loads | Modelled both as firm loads and as unit specific loads |
| Interconnection support | Yes | Yes |
| <u>Arising from HLI</u> | | |
| Transmission line availability | 100% | Not present |
| Transmission line capacity | System peak load | Not present |

6.0 STATE ENUMERATION

For an HLI evaluation the transmission system is considered 100% available with no flow limitations. Consequently, we will only look at all the states in which the generation can exist, and at all the states in which the load can exist.

6.1 Complete Year HLI Analysis by NB Power

The HLI analysis carried out by NB Power was done with a generation only software package which was written in house. The methods employed and results obtained are described in detail.

6.1.1 Capacity Availability Table

Based on the probabilities of unavailability, one can proceed to develop a capacity availability or capacity outage table. In developing a capacity availability or capacity outage table, there are two points to note.

- (a) There must be a logical way to identify all possible states, and this is done with the usual recursive relationship.
- (b) To prevent the number of states from becoming too large, especially when small units are involved, capacity rounding is used. This is shown to be a valid approach in the technical literature. NB Power chose a capacity increment of 20 MW.

Table 6.1 shows sample results of enumerating all of the states in which the thermal generating units can exist (with parts of the table left out).

Table 6.1
Results of State Enumeration

| <u>Capacity Available (MW)</u> | <u>Probability</u> | <u>Cumulative Probability</u> |
|--------------------------------|--------------------|-------------------------------|
| 2920 | 0.14054 | 0.14054 |
| 2900 | 0.08017 | 0.22071 |
| 2880 | 0.04020 | 0.26091 |
| ---- | ----- | ----- |
| 1620 | 0.00107 | ----- |
| 1600 | 0.00104 | ----- |
| ---- | ----- | ----- |
| 20 | 0.00000 | 1.00000 |
| 0 | 0.00000 | 1.00000 |

(NOTE: In the computer, probability values are carried out to 10 places after the decimal).

6.1.2 Reliability Indices Used

Four reliability indices are used to express the state of the reliability of the NB Power system.

1. Loss of Load Expectation (LOLE) in Hours for each month, and a total for the year.
2. Expected Energy Not Served (EENS) in GWh
3. Average Megawatts of Dependence (AMD) which is the EENS in MWh divided by the LOLE in Hours.
4. System Minutes which is the EENS in MWh divided by the Peak Load for the Year and then expressing the resultant hours in minutes.

6.1.3 Consideration of Contracts and Interconnection Support

Contract obligations to external systems are as significant to NB Power as the emergency support which the external system can provide. They influence reliability both for a theoretically isolated system evaluation and for an interconnected system evaluation. For evaluation of the NB Power system by itself in an isolated state, there are two possible interpretations:

Case 1: Contract obligations are made by netting out the sales from the proper generators and no interconnection support is considered available. This is the theoretical worst case system.

Case 2: The interconnections are all opened so that no external support is available, but the contracted capacity cannot be delivered so it is available within New Brunswick. This is a case that could potentially happen.

Results are shown in Table 6.2 for the NB Power system under the assumption that it is an isolated system with no interconnection

Table 6.2
Results of Reliability Indices For Isolated
NB Power System

| Month | Case 1 | | Case 2 | |
|-------------|-----------------|---------------|-----------------|---------------|
| | LOLE (Hours) | EENS (GWh) | LOLE (Hours) | EENS (GWh) |
| April | 0.2 | 0.02 | 0.1 | 0.01 |
| May | 0.3 | 0.03 | 0.2 | 0.02 |
| June | 0.6 | 0.05 | 0.5 | 0.05 |
| July | 0.8 | 0.06 | 0.6 | 0.05 |
| August | 0.2 | 0.02 | 0.2 | 0.02 |
| September | 0.1 | 0.01 | 0.1 | 0.01 |
| October | 0.2 | 0.02 | 0.2 | 0.02 |
| November | 0.5 | 0.06 | 0.4 | 0.04 |
| December | 30.2 | 4.86 | 2.2 | 0.33 |
| January | 104.2 | 22.27 | 10.5 | 1.91 |
| February | 87.8 | 16.92 | 9.0 | 1.41 |
| March | 46.1 | 7.56 | 3.4 | 0.54 |
| Total | 271.2 | 51.87 | 27.4 | 4.40 |
| AMD in MW = | | 191 | | 161 |
| System | | | | |
| Minutes = | | 985 | | 84 |

Table 6.3
Reliability Indices Including Capability
Of All Interconnections

| Month | Case 3 | | Case 4 | |
|-------------|-----------------|---------------|-----------------|---------------|
| | LOLE (Hours) | EENS (GWh) | LOLE (Hours) | EENS (GWh) |
| April | 0.00 | 0.00 | 0.00 | 0.00 |
| May | 0.00 | 0.00 | 0.00 | 0.00 |
| June | 0.00 | 0.00 | 0.00 | 0.00 |
| July | 0.00 | 0.00 | 0.00 | 0.00 |
| August | 0.00 | 0.00 | 0.00 | 0.00 |
| September | 0.00 | 0.00 | 0.00 | 0.00 |
| October | 0.00 | 0.00 | 0.00 | 0.00 |
| November | 0.00 | 0.00 | 0.00 | 0.00 |
| December | 0.02 | 0.00 | 0.16 | 0.02 |
| January | 0.23 | 0.03 | 0.63 | 0.15 |
| February | 0.25 | 0.02 | 0.23 | 0.11 |
| March | 0.04 | 0.00 | 0.02 | 0.03 |
| Total | 0.44 | 0.05 | 2.23 | 0.31 |
| AMD in MW = | | 114 | | 139 |
| System | | | | |
| Minutes = | | 1 | | 6 |

support. With interconnections the contracts could be considered in two different ways:

Case 3: Contract obligations are made by netting out the sales from the proper generator and interconnection support is included by adding the interconnection equivalent generators to the calculation. This case represents the truest indication of the reliability of the system.

Case 4: Contract obligations are considered by adding firm load to the system load to be met by the combined total of NB Power and interconnection resources. This case is slightly pessimistic because the contract load must be met even when its respective generator is unavailable.

The results of the reliability evaluations for the NB Power system including interconnection support are shown in Table 6.3.

6.1.4 NB Power Complete Year State Enumeration Results

Table 6.4 summarizes the results of all of these cases.

Table 6.4
Comparison of Results

| Reliability Index | NB Power Isolated Case 1 | Interconnections Case 2 | Case 3 | Case 4 |
|-------------------|--------------------------|-------------------------|--------|--------|
| LOLE (Hours) | 271.2 | 27.4 | 0.44 | 2.23 |
| EENS (GWh) | 51.87 | 4.40 | 0.05 | 0.31 |
| AMD (MW) System | 191 | 161 | 114 | 139 |
| Minutes | 985 | 84 | 1 | 6 |

As expected the results show that the NB Power system is much more reliable when its large interconnections are included than it is when considered an isolated system. This is generally true for almost all utilities but not usually to the degree illustrated here. Results are also influenced significantly by the method employed to consider NB Power's external contracts. While arguments can be presented to consider each case as a valid

measure of the NB Power system, Case 3 provides the truest measure from the NB Power point of view.

6.2 Constrained Peak Load HLI Analysis by International Participants

As described in Section 5.4., this analysis assumes that the peak load level exists for each of the 8760 hours of the year, hydro is pre-dispatched at 650 MW and no maintenance is considered. Although Case 3 provides the truest reliability measure of the NB Power system, not all international software packages possess the required capability to model the contract sales properly for this case. Therefore the contract obligations and the capacity interconnection benefits for this constrained system analysis are those of Case 4 from the NB Power complete year analysis.

The results of the State Enumeration methodology for the constrained peak load HLI

analysis are given in Table 6.5. For ease of comparison, only LOLE and EENS indices are reported. Note that for the UMIST evaluation RELACS #1 includes up to 7 generators on outage while #2 includes up to 11.

**Table 6.5
State Enumeration Results by International Participants**

| Participant | Program | Reliability Index | |
|----------------------|--------------|-------------------|---------------|
| | | LOLE (Hours) | EENS (GWh) |
| USask | F&D | -- | 14.7 |
| (Canada) | SEGMENTATION | -- | 16.2 |
| UMIST (UK) | RELACS #1 | 73 | 11.0 |
| | RELACS #2 | 88 | 15.2 |
| | HLI | 86 | 16.2 |
| PTI (USA) | MAREL | 81 | 13.6 |
| NB Power (Canada) | NB HLI-S | 82 | 14.5 |

7.0 MONTE CARLO

The Monte Carlo simulation is based on the idea that the decision as to whether a unit is, or is not, operating can in the simulation be determined by a uniform random number generator.

A random number is generated for each element in the simulated system that is subject to random unavailability. Any element whose number falls in its unavailability range is disconnected from the system for that particular simulation. This process is repeated many times to determine the true operation of the system.

7.1 Complete Year HLI Analysis by NB Power

The HLI analysis using Monte Carlo was carried out by NB Power similarly to that for State Enumeration. The program was written in house to incorporate the same modelling features as the NB Power State Enumeration program.

The many modelling issues discussed in Chapter 5 apply to both the State Enumeration and Monte Carlo methodologies. To eliminate potential errors in the results because of modelling decisions, the system data and modelling approach for the Monte Carlo simulations were made identical to that used for the State Enumeration analysis.

The same hydro generation schedules determined by the peak shaving process in the State Enumeration were applied to the load duration curves. This schedule was assumed 100% available and after dispatch produced a remaining load curve which had to be supplied by the thermal system. The Monte Carlo calculations were applied to this same thermal equivalent system as were the State Enumeration calculations.

The load time interval for Monte Carlo simulation was set equal to the load step size (50 intervals per month) used to define the load duration curves. The same monthly maintenance schedule was applied, which uses the deration principle for capacity on maintenance for only part of a month.

By modelling the system as described, only the probabilistic calculation methodologies applied to the unavailabilities of thermal generators were different. For such a calculation, theoretically the Monte Carlo results should be identical to the State Enumeration results.

The impact of interconnection modelling on the reliability of the NB Power system is clearly illustrated in Chapter 6. This analysis was repeated for the Monte Carlo methodology with similar results as given in Table 7.1.

Table 7.1
Monte Carlo Evaluations by NB Power

| | Case 1 | | Case 2 | | Case 3 | | Case 4 | |
|-----------|-----------------|---------------|-----------------|---------------|-----------------|---------------|-----------------|---------------|
| | LOLE (HOURS) | EENS (GWH) | LOLE (HOURS) | EENS (GWH) | LOLE (HOURS) | EENS (GWH) | LOLE (HOURS) | EENS (GWH) |
| April | 0.2 | 0.03 | 0.2 | 0.03 | 0.0 | 0.00 | 0.0 | .00 |
| May | 0.2 | 0.03 | 0.2 | 0.02 | 0.0 | 0.00 | 0.0 | .00 |
| June | 0.5 | 0.06 | 0.5 | 0.05 | 0.0 | 0.00 | 0.0 | .00 |
| July | 0.7 | 0.05 | 0.5 | 0.04 | 0.0 | 0.00 | 0.0 | .00 |
| August | 0.1 | 0.02 | 0.1 | 0.02 | 0.0 | 0.00 | 0.0 | .00 |
| September | 0.1 | 0.01 | 0.1 | 0.01 | 0.0 | 0.00 | 0.0 | .00 |
| October | 0.1 | 0.01 | 0.1 | 0.01 | 0.0 | 0.00 | 0.0 | .00 |
| November | 0.4 | 0.06 | 0.4 | 0.04 | 0.0 | 0.00 | 0.0 | .00 |
| December | 30.5 | 4.97 | 2.4 | 0.34 | .01 | 0.00 | 0.2 | .02 |
| January | 103.8 | 22.16 | 11.3 | 1.98 | .31 | 0.04 | 1.0 | 0.18 |
| February | 91.4 | 18.51 | 8.7 | 1.47 | .17 | 0.02 | 0.8 | .12 |
| March | 45.0 | 7.57 | 3.9 | 0.54 | .03 | 0.01 | 0.3 | .03 |
| Total | <u>273.2</u> | <u>53.49</u> | <u>28.5</u> | <u>4.55</u> | <u>0.53</u> | <u>0.07</u> | <u>2.3</u> | <u>0.35</u> |

7.2 Constrained Peak Load HLI Analysis by International Participants

The NB Power system conditions used are the same as those for the State Enumeration methodology as described in Section 6.2. The results of the constrained peak load evaluation are shown in Table 7.2.

**Table 7.2
Monte Carlo Results by Participants**

| Participant | Program | Reliability Index | |
|----------------------|----------|-------------------|---------------|
| | | LOLE (Hours) | EENS (GWh) |
| ENEL (Italy) | SICRET | 92 | 15.5 |
| EDP (Portugal) | ZANZIBAR | -- | 15.5 |
| UMIST (UK) | COMPASS | 93 | 15.7 |
| NGC (UK) | ESCORT | -- | 13.1 |
| EDF (France) | MEXICO | 95 | 15.2 |
| USsask (Canada) | MECORE | 85 | 14.7 |
| NB Power (Canada) | NB HLI-M | 86 | 14.5 |

7.3 Simulation Parameters

In conducting a Monte Carlo evaluation, there are two parameters which can influence the results of the calculation:

- (a) Random number generator seed value
- (b) Number of simulations conducted

To illustrate this variation, the constrained peak load HLI evaluation was carried out using the three different seed values of 1, 5 and 21 applied for 1000, 3000 and 10,000 simulations. The results are shown in Table 7.3.

**Table 7.3
Results for Different Simulation Parameters**

| Number of Simulations | Seed Value | | | Average |
|-----------------------|------------|----|----|---------|
| | 1 | 5 | 21 | |
| 1000 | 35 | 79 | 79 | 64 |
| 3000 | 61 | 94 | 90 | 81 |
| 10000 | 78 | 96 | 83 | 86 |

| Number of Simulations | Seed Value | | | Average |
|-----------------------|------------|------|------|---------|
| | 1 | 5 | 21 | |
| 1000 | 8.8 | 14.7 | 17.5 | 13.0 |
| 3000 | 9.6 | 17.8 | 18.7 | 15.4 |
| 10000 | 12.6 | 16.9 | 14.1 | 14.5 |

The results are in agreement with the classical theory for random variable simulations upon which the Monte Carlo approach is based. Results vary for different seed values and the amount of variance decreases as the number of simulations increases.

8.0 DISCUSSION AND COMPARISON OF PROBABILISTIC GENERATION RESULTS

Similar indices are available from both the state enumeration and Monte Carlo methods. The indices chosen for this general comparison of analyses are LOLE in hours and EENS in GWh.

Probabilistic evaluation of generation only or HLI reliability was conducted from two approaches. NB Power did detailed complete year reliability evaluations for four different considerations of interconnection support and contract obligations. This was followed by a constrained peak load HLI evaluation case carried out by all participating parties for only the Case 4 interconnection model.

8.1 Comparison of Probabilistic Generation Results

Summary results of the NB Power detailed evaluation are given in Table 8.1 for both Monte Carlo and State Enumeration methodologies.

Table 8.1
Summary of NB Power Complete Year HLI Results

| Method: Reliability Index | With | | | |
|---------------------------------|-----------------------------|--------|--------|--------|
| | NB Power Isolated Case 1 | Case 2 | Case 3 | Case 4 |
| State Enumeration: | | | | |
| LOLE (Hours) | 271.2 | 27.4 | 0.44 | 2.23 |
| EENS (GWh) | 51.9 | 4.4 | 0.05 | 0.31 |
| Monte Carlo: | | | | |
| LOLE (Hours) | 273.2 | 28.5 | 0.53 | 2.30 |
| EENS (GWh) | 53.5 | 4.5 | 0.07 | 0.35 |

The results from each of the two methods compare extremely well. This suggests that the final reliability result is not influenced by the probabilistic calculation method. However, the widely varying results that occur by changing the interconnection modelling indicates that this is not true for different modelling approaches.

This raises concern for the composite system reliability evaluation because many different modelling approaches exist in the

various international software packages. To assist in isolating potential differences a peak load HLI evaluation with data constraints was conducted. Results given in Table 8.2 show excellent agreement by all participants at this level of evaluation.

8.2 Discussion of Results by Methodology

These results for the generation only case have been obtained by running the NB Power data on the full software packages of the participants which employ either State Enumeration or Monte Carlo methods.

Table 8.2
Peak Load HLI Evaluation (Case 4)

| Participant | Program | Reliability Index | |
|---------------------------|--------------|-------------------|---------------|
| | | LOLE (Hours) | EENS (GWh) |
| State Enumeration: | | | |
| USask (Canada) | F & D | -- | 14.7 |
| | SEGMENTATION | -- | 16.2 |
| UMIST (UK) | RELACS #1 | 73 | 11.0* |
| | RELACS #2 | 88 | 15.2** |
| | HLI | 86 | 16.2 |
| PTI (USA) | MAREL | 81 | 13.6 |
| NB Power (Canada) | NB HLI-S | 82 | 14.5 |
| Monte Carlo: | | | |
| ENEL (Italy) | SICRET | 92 | 15.5 |
| EDP (Portugal) | ZANZIBAR | -- | 15.5 |
| UMIST (UK) | COMPASS | 93 | 15.7 |
| NGC (UK) | ESCORT | -- | 13.1 |
| EDF (France) | MEXICO | 95 | 15.2 |
| USask (Canada) | MECORE | 85 | 14.7 |
| NB Power (Canada) | NB HLI-M | 86 | 14.5 |

* Going 7 states down in contingency selection

** Going 11 states down in contingency selection

The State Enumeration method exhaustively lists each possible state of available generators and available transmission lines, and calculates the probability of having each state. The Monte Carlo method lists the states of the power system based on a process which is weighted or controlled by the availability statistics of the generators and transmission lines. Consequently in theory both methodologies should give the same reliability results.

The results of Table 8.2 conclusively prove this theoretical expectation. The results are independent of methodology. Aside from modelling differences, there are only two factors which can make the results of the State Enumeration method and the Monte Carlo method differ. These are:

(a) A failure to go far enough down in selecting possible outage states in the

State Enumeration method. This means that some states, which can significantly affect the reliability indices, may get left out.

(b) A failure to use a large enough sample size in the Monte Carlo method. This can result in a standard deviation in the reliability indices which is too large.

SECTION D - PROBABILISTIC METHODS FOR COMPOSITE SYSTEM RELIABILITY

The addition of the transmission system to the generation system is of much significance. A number of international software packages have been made available for composite system reliability evaluation.

9.0 INPUT DATA AND MODELLING ISSUES FOR COMPOSITE RELIABILITY STUDIES

We are going to discuss composite input data and modelling issues from three points of view:

- (i) Detailed Complete Year specifics of the NB Power system
- (ii) Simplifications for the constrained Peak Load evaluation
- (iii) Data Preparation for the various software packages

9.1 Complete Year HL2 Modelling Details

Great effort has been expended so that NB Power system map, the peak load flow analysis and the composite system data set are consistent. But because of the nature of the composite problem, more detailed explanation of modelling issues behind the data is required and is addressed in this section. In following this discussion, reference on the part of the reader is necessary to the system one line diagram in Figure 2.4, the load flow in Appendix III and the Generic System Data set in Appendix I.

9.1.1 Network Configuration

1. Load flow inconsistencies:

In the load flow, all generators are connected to a unit node and then through the unit transformer to the high voltage terminal. In the system data set, the generators are connected directly to the terminal and the unit transformer is not included.

2. Caraquet-Tracadie area and 69 kV system:

System Operations procedures allow for immediate start up and dispatch of the Tracadie (St. Rose) gas turbine which can supply the area load. Taking this

into account, the most appropriate 138 kV equivalent for the area is to join the Caraquet (1677) and Tracadie (1963) nodes together at Caraquet and ignore the 69 kV system. All load in the area and the Tracadie (St. Rose) generator is placed at node 1677 and node 1963 disappears.

3. Iroquois Terminal and 69 kV System:

All load and losses in the northwest 69 kV system are brought back to the two Iroquois 138 kV nodes (1910) and (1909). This includes the load netted out by generation from Grand Falls (69 kV Station) and Tobique. To correct this, an equivalent generator for Grand Falls and Tobique (GF.TOB.6) is placed at node 1910.

4. Lancaster - Courtenay Bay 69 kV:

The 69 kV has been deleted with all loads and generation moved to 138 kV nodes at Lancaster (1679) and Courtenay Bay (1813).

5. Marysville - Grand Lake 69 kV:

The 69 kV has been deleted with all flows to 69 kV considered as loads.

9.1.2 Interconnection Equivalents:

6. External Sales:

The 230 MW Point Lepreau participation sale to New England and the 60 MW of sales to Prince Edward Island are modelled as base loads at node numbers 700 and 1844. This approach is consistent with the Case 4 sales models described in detail in section 6.1.4 which were employed for both the General and Constrained HLI evaluations.

The 400 MW peaking sale to Hydro Quebec is modelled as a shaped load (type 4) split between the two Hydro Quebec interconnection points at node numbers 1869 and 9996. The HVDC stations are ignored.

Transmission lines linking these loads to the NB Power main system are assumed available at 100%, so that unserved energy associated with interconnection outages are not included with NB Power EENS.

7. External Generation Support:

The ability of external systems to provide emergency support to NB Power is modelled by means of equivalent generators at the interconnection. The availabilities of these generators have been selected to approximate a multi-state capacity availability table determined by either detailed analysis or approximation of the total system behind the interconnection. The models employed are consistent with those used for HLI evaluations presented earlier in section 5.3.5.

8. Nova Scotia Transmission System:

The Nova Scotia Transmission system is modelled in detail back to the ONSLOW 345 kV bus (168). Fixed loads are placed on nodes 157, 158, 167, and 183 which are offset by a 100% available generator at 168. These loads maintain flows on the Nova Scotia lines which are assumed available at 100%. This will limit the support available over the 138 kV circuits to their transmission limits.

9. US Equivalent at Tinker:

Line 1126 (14 km) shown on the system diagram connects to Tinker (1986) through the Maine Public Service system. For the reliability equivalent its effective length has been lengthened to 44 km.

9.1.3 Load Modelling Issues


10. Space/time Load Allocations:

A major problem with composite modelling is the allocation of load throughout the network to the proper node where it is located and still account for the time distribution of each load throughout the year. To this end three models were developed to provide some flexibility to TF 38.03.10 participants for the inputting of load data to their computer models.

Load Model I is a detailed model based on weekly load duration curves, allowing one of four possible different load types to be used at any node. Each of the four load types is defined by twelve separate weekly distributions. The general weekly load duration shape used to develop each distribution is shown in Figure 9.1. While all weekly distributions employ this same generic shape, unique load models were generated by changing the value of load levels for each week for each load type. As well a month is assumed to consist of an integer number of weeks, essentially making the twelve weekly load duration curves become monthly load duration curves.

Load Model II is a simplified seasonal load model set to only five different variable load levels for the entire year.

LOAD DURATION MODEL



CHRONOLOGICAL LOAD MODEL




Figure 9.1
Load Duration and Chronological Load Models

In this model, only base load (100% Load factor) and peak load at each node are defined. The difference between these values is the variable portion of the load which follows the five level load distribution.

| <u>Bus</u> | <u>Name</u> | <u>MW</u> |
|------------|-------------|-----------|
| 1813 | INITLOAD1 | 10 |
| 1847 | INITLOAD2 | 12 |
| 1910 | INITLOAD3 | 15 |
| 1948 | INITLOAD4 | 15 |

Load Model III is an extension of Load Model I. It provides a general weekly sequential load shape which is consistent with the general load duration shape of Load Model I. The sequential shape is given in Figure 9.1. Application of this general shape to the six load levels for each month of each load type will translate each load duration distribution to a sequential distribution. This actual translation was left to individual participants to perform.

If none of these load models fit a particular composite computer package it was necessary that the participant adjust a model as required. Generally most participants used Load Model I or II but model III was available for sequential analysis if desired.

11. Lepreau Station Service:

The Point Lepreau nuclear station is rated at 635 MW net, but has a station service load of 22 MW when shutdown. To model this the unit MW rating is set at 657 MW with a fixed 100% available load of 22 MW at the Lepreau (1843) node.

12. Interruptible Loads:

NB Power has 52 MW of load that is interruptible. Most of this is to large industrial customers and is constant all year.

To model this situation, the interruptible load has been included as firm load which will be netted out by an equivalent 100% available generator to simulate the interruption. The interruptible generators are assigned costs so they will be dispatched after all regular NB Power generation but before interconnection generators.

These interruptible load generators are specified at the following nodes:

13. Transmission Losses:

Generation only (HLI) reliability evaluation is done with the losses included in the loads which is forecast for the test system to be 3156 MW. Composite modelling requires that the losses be calculated from the load flow associated with a particular evaluation state. For composite models which do not calculate losses, they must be included in some equivalent manner so that results will be on a comparable basis. This problem was left for individual participants to solve as they best know their own software package.

9.1.4 Common Mode, Hydro and Weather Models

14. Common Mode Failures (Tapped Loads):

NB Power has many 138 kV lines which are tapped to 69 kV radial supplies but without breakers and primary protection on each side of the tap. When any portion of the line is faulted the entire line is cleared and the radial 69 kV load from the tap is interrupted.

In the load flow these tap points are considered as a node with a load. For reliability it is necessary that unavailability of one portion of the line to the tap also result in unavailability of the other portion of the line as well. That is, the conditional probability of a common mode fault is 100% given that any fault occurs.

A list of the common mode pairs of lines is given in the data set along with the probability of the common outage.

15. Hydro Generating Plant Models:

The hydro generators on the NB Power system all have some, but limited, storage. This fact is expressed in two ways.

- (i) Each plant has a capacity factor less than one (usually significantly less than one).
- (ii) We say that the plant and generators are energy limited.

Hydro generators therefore become a special problem in composite system reliability evaluation. The usual way in which they have been handled is as follows:

- (i) The total system load has been established.
- (ii) The hydro generators have been assumed to have a zero forced outage rate.
- (iii) The hydro capacity has been dispatched to utilize the limited hydro energies to shave off the peak part of the system load.

Two hydro models are supplied and participants may be able to utilize either directly or make adjustments as appropriate.

Model I, which is consistent with Load Model I, is a detailed schedule for each month which simulates peak shaving of the total system load by the hydro plants. The area under each plant schedule is equal to the monthly average hydro energy available.

Model II does not attempt to preschedule the hydro. It simply provides the total energy available for each plant and the percentage allocation of this total to each season. This data can be used to model the hydro plants as energy limited thermal units. If a participant's composite computer model does not have this energy limited capability it may be necessary to determine by trial and error a thermal equivalent cost which will dispatch the hydro correctly. To assist in this matter seasonal dispatch

costs were provided for a reasonable hydro dispatch.

16. Adverse/Normal Weather Affects:

The FOR data supplied for each transmission line is the annual average forced outage rate. As such, it does not include the concentration of outages in the relatively short duration of adverse weather in which most transmission outages occur. Additional data is supplied which can be used to model this effect. It was hoped that participants would do calculations with and without weather modelling to try to quantify its impact.

9.1.5 Modelling Summary

As a result of the above modelling decisions, the final system to be evaluated is summarized under peak load conditions as follows. All values are MW.

System Loads:

| | |
|---------------------------------------|------------|
| NB Power forecast load (Table 2.1) | 3156 |
| Less system transmission losses | (82) |
| Plus Lepreau station service load | <u>22</u> |
| NB Power total connected load | 3096 |
| NS load to model transmission limits | 119 |
| Interconnection contract loads | <u>690</u> |
| Total connected load | 3905 |
| Transmission losses | <u>82</u> |
| Total load seen by generation | 3987 MW |

Generation Resources:

| | |
|--|-------------|
| NB Power thermal generation (Table 2.4) | 3450 MW |
| Lepreau station service adjustment | <u>22</u> |
| Thermal generation subtotal | 3472 |
| NB Power hydro generation (Table 2.2) | 870 |
| Less energy limited deration on peak | <u>220</u> |
| Scheduled hydro generation | 650 |
| Interruptible load generators | 52 |
| NS generation for transmission limit | 119 |
| Interconnection support generators | <u>1220</u> |
| Total generation resources | 5513 MW |

9.2 Constrained Peak Load Modelling Details for HL2

As with the HL1 evaluations, a peak load analysis for composite system reliability (HL2) was also conducted. Data constraints were applied to simplify the general case HL2 data described in detail in section 9.1.

The data constraints employed were identical to those used for the peak load HL1 analysis plus some additional ones concerning the transmission system. For completeness all of these constraints are reported below:

- (a) The load at each bus was assumed to exist at the peak level for each of the 8760 hours of the year.
- (b) The hydro was prescheduled at a power value corresponding to the available hydro energy for the year. In essence, the hydro units were treated as 100% available thermal units at a capacity of 650 MW. Individual capacities are Mactaquac 500 MW, Beechwood 80 MW, Grand Falls #1 30 MW and the combined Grand Falls/Tobique at 40 MW.
- (c) Maintenance was not considered.
- (d) Common mode modelling of transmission outages was not considered.
- (e) Weather related transmission outage modelling was not considered.

9.3 Data Preparation

In the initial stages of this project, data was prepared according to specific formats for four programs - the SICRET program of ENEL (Italy), the ZANZIBAR program of EDP (Portugal), the ESCORT program of NGC (United Kingdom) and the COMREL program of the University of Saskatchewan (Canada). Subsequent to this the number of participants grew and a set of Generic Data was provided, which in overall structure quite closely resembled the SICRET form. Some data changes were required in November 1990, and these data changes were made to the Generic Data set only. In this way, the Generic Data set came to be used by all participants.

Clearly to satisfy the data input requirements for the software packages of all

participants, the Generic Data set had to include equivalent data in different forms. It is useful to look at two of these circumstances.

- (a) Concerning line availabilities, one program requires line unavailability per 100 kilometers, another asks for the unavailability rate, while another asks for the failure rate of the line in failures/year together with the repair duration of the line in years/repair.
- (b) Concerning line electrical modelling, one program requires the series impedance in ohms per kilometer together with the line length in kilometers, while other programs ask for the series impedance in per unit on the chosen system MVA base. Relative to this data item, it should be noted that the Generic Data set provided may have introduced some minor discrepancies. The fundamental data set which NB Power has in its data base is series resistance and reactance in per unit, as required for load flow and stability studies. An exact conversion of this data to series impedance in ohms per kilometer was not done for all lines, but rather typical impedance values in ohms per kilometer were provided for each of the lines according to the three voltage levels. This should not have introduced any appreciable error.

9.4 Generation Dispatch and Load Curtailment Philosophy

As part of the system data, NB Power provided the fuel cost functions for each of the thermal generators. Available generation is generally dispatched on a cost basis, although it is possible to dispatch the generation on a cost and reliability basis. In addition, there are a variety of load curtailment philosophies including curtailment at a major bus, curtailment in the area of overloaded transmission lines, and curtailment by an equal percentage at every bus of the system. For details of the generation dispatch approach and of the load curtailment philosophy for each of the international participants, reference should be made to Appendices IV-X where the international participants have outlined their software packages.

10.0 COMPOSITE SYSTEM RELIABILITY RESULTS

There is a wealth of information available from the composite system reliability results.

The first set of indices might be called System Indices. One example is the very familiar Expected Energy Not Served (EENS in GWh). Now however, the EENS can be assigned partly to generation and partly to transmission. Further the transmission component can be broken up into reasons such as line capability exceeded, partial system separation, and node isolation. Another example is the specification of the most frequently overloaded transmission lines, thus indicating potential weaknesses in the transmission system.

The second set of indices might be called Load Point Indices. One example is the frequency of load interruptions at one or more buses. Another example is the frequency of occurrence of low voltages at selected buses.

Finally it should be kept in mind that, since each of the international software packages were written for specific system planning purposes, the results which are output may not be in exactly, or even nearly, comparable form.

10.1 Brief Summary of HL2 Cases

The composite system reliability evaluation packages were run for four different sets of NB Power system data.

1. Base System Peak Load HL2 Case

The Base System peak load HL2 case represents the operating NB Power system as explained in detail in Section 9.1, but with the modelling constraints as described in Section 9.2 and summarized in Table 10.1.

It should be remembered that the constraints are present, not because they are necessary for system operation but, because they allow comparisons of results by different methodologies unencumbered by software differences.

2. Improved System Peak Load HL2 Case

As stated in Section 2.7 the NB Power system includes a phase shifting transformer in the south central part of the province to control active power flow in the Coleson Cove - Courtenay Bay - Norton area. This transformer was removed from the Base System to provide a transmission weakness that could be detected by the reliability analysis. It was originally intended that it be returned to the system for this improved case.

In the early stages of the work it became clear that few of the reliability software packages had the capability to model phase shifting transformers as such. Despite the best efforts of the Task Force, it was not possible to come up with an equivalent generator - load representation. Consequently an attempt was made to duplicate most of the effects of the phase shifting transformer by the addition of two transmission lines to the system and the upgrading of a transformer and a short transmission line. This improved transmission system is illustrated in detail in Figure 10.1.




Figure 10.1
Transmission Improvements in the Coleson Cove - Courtenay Bay - Norton Area

As before the constraints on the data are those given in Section 9.2, and summarized in Table 10.1.

3. Base System Complete Year HL2 Case

This is the Base System in the normal operating mode, but without the constraints of Section 9.2. It includes all of the general

modelling details of Section 9.1 to provide the most reasonable representation of the base NB Power study system possible over the complete year. Also each international software package is free to employ its full modelling capability to best analyze this case. The conditions for this case are summarized in Table 10.1.

Table 10.1

Summary of Composite System HL2 Case Studies

| System Condition or Variable | Base Peak Load Analysis | Base Complete Year Analysis | Improved Peak Load Analysis | Improved Complete Year Analysis |
|-------------------------------|--------------------------|--------------------------------|-----------------------------|--------------------------------------|
| Transmission State | Base | Base | Improved | Improved |
| Transmission line maintenance | None | None | None | None |
| Load conditions | Peak load for 8760 hours | Annual load variation | Peak Load for 8760 hours | Actual weekly load diagrams diagrams |
| Common mode failure | No | Yes | No | Yes |
| Generating unit maintenance | No | Yes | No | Yes |
| Weather Conditions | Same all year | Vary | Same all year | Vary |
| Hydro production variation | Prespecified at 650 MW | Average Gwh monthly peak-shave | Prespecified at 650 MW | Average load |
| Interruptible load | Yes | Yes | Yes | Yes |
| Contract transfers | Firm load | Firm load | Firm load | Firm load |
| Interconnection support | Yes | Yes | Yes | Yes |

4. Improved System Complete Year HL2 Case

With the two line transmission improvement in place of the existing phase shifting transformer, and without the data constraints, this case is very close to the actual operating condition of the NB Power System. It utilizes all of the data supplied in Appendix I (including transmission upgrade) and employs the full modelling capability of each international software package. The conditions for this case are summarized in Table 10.1.

10.2 Composite System Reliability Indices

The state of a power system is one combination of loads, available generators, and available transmission lines. If the loads are assumed known at deterministic values for any time frame, then the state of the power system is any one combination of available generators and available transmission lines.

The State Enumeration method simply exhaustively lists, or enumerates, each possible combination or state of available generators and available transmission lines, and calculates the probability of having each combination. On the other hand, the Monte Carlo method comes up with the combinations or states of available generators and available transmission lines by a process which is weighted or controlled by the statistics of their availability.

Which ever method is used, the states of a power system are produced one at a time. For any state of a power system, there are three major studies which can be carried out on it. These are the load flow, transient stability runs and mode analysis studies.

Simply put, and it can be simply put, reliability indices are any information open to the imagination perceived as being available from load flow, stability and mode analysis studies.

10.2.1 Overview of Indices

With reference to Section 1.3 on reliability concepts, it is possible to structure indices according to three groups.

(a) Adequacy Indices

Indices available from load flow studies done on each of the states of the power system. At this point in time, these

are the only indices which are regularly computed.

(b) Security Constrained Adequacy Indices

Indices available from load flow studies done when any component may be lost from an adequacy evaluated state.

(c) Security Indices

Indices available from transient stability studies during the loss of a component when in an adequacy evaluated state. While not yet available, these are best obtained from direct stability analysis methods based on energy functions.

10.2.2 Adequacy Indices Based on the Load Flow

Before proceeding to summarize these indices it is useful to point out that the formulation of indices is still in a continual state of development and it is useful to give a contemporary example of this fact. Chapter 2 of the Application Guide is on the subject of Reliability Indices and it gives a comprehensive overview, along with detailed definitions, of a large number of indices. However four of the international participants of the Task Force provided an index which was not in the Application Guide. This is the Marginal EENS Gain for Overloaded Lines in MWh per MW.

The following two indices may be considered as fundamental ones.

1. Loss of Load Expectation (LOLE), which is most easily illustrated in the Monte Carlo method, is simply the number of hours in which the load is not able to be served during a month or during a year.
2. Expected Energy Not Served (EENS), again most easily illustrated in the Monte Carlo method, is the summation over all the instances in which it happens of unserved load multiplied by the length of time that it is unserved.

The next two indices can be derived from the two above.

3. Average Megawatts of Dependence (AMD) is the Expected Energy Not Served in MWh

divided by the LOLE in hours.

4. System Minutes (SM) is the Expected Energy Not Served in MWh divided by the Peak Load for the year, with the resultant hour value converted to minutes.

Many additional indices have been defined, most of which are set out in Reliability Evaluation of Power Systems by Billinton and Allan. These can best be described when classified into groups.

A paper also being presented at the CIGRE Montreal Symposium, entitled "Composite Reliability Assessment Studies in the Greek Interconnected Power System" and written by authors at the National Technical University at Athens, classifies indices into two sets, with each set then subdivided into three types.

(A) Load Point Indices

(a) Basic Indices.

5. Probability of failure
6. Expected frequency of failure in occurrences per year.
7. Expected frequency of voltage violations in occurrences per year.
8. Expected frequency of load curtailments in occurrences per year.
9. Expected load curtailed in MW.
10. Expected duration of load curtailment in hours.
11. Expected energy not supplied in MWh.

(b) Maximum Indices

12. Maximum load curtailed in MW per curtailment.
13. Maximum energy not supplied in MWh.
14. Maximum duration of load curtailment in hours.

(c) Average Indices

15. Average load curtailed in MW per curtailment.
16. Average energy not supplied in MWh.
17. Average duration of load curtailment in hours.

(B) System Indices

(a) Basic Indices

18. Bulk power interruption index in MW per MW-year.
19. Bulk power supply average curtailment in MW per disturbances.
20. Bulk power energy curtailment index in MW-minutes per MW-year.
21. Modified bulk power curtailment index.
22. System minutes in MWh per MW-yr converted to minutes.

(b) Maximum indices

23. Maximum system load curtailed in MW.
24. Maximum system energy not supplied in MWh.

(c) Average indices

25. Average number of curtailments per load point.
26. Average load curtailed per load point in MW.
27. Average energy curtailed per load point in MWh.
28. Average duration of load curtailed per load point in hours.
29. Average number of voltage violations per load point.

In the preparation of results for this Task Force, Billinton prepared a list of indices some of which are included above. Those not included are:

(B) System Indices

30. Expected number of load curtailments in events per year.
31. Expected duration of load curtailments in hours per year.

Finally as already indicated, four of the international participants of the Task Force calculated an additional index.

32. Marginal EENS gain for overloaded lines in MWh per MW.

10.3 System Wide Reliability Measures

Indices used to indicate the reliability of the system as a whole are EENS and LOLE. The contributions from the generation and the network are provided as well as the system total in Table 10.2 for EENS, and in Table 10.3 for LOLE. Results for all HL2 study cases are given.

For the peak load analysis the generation components of outage are nearly identical. This is consistent with the HL1 results discussed in Section 8. There is greater variation in the network component of outage but the results clearly show the

reliability improvement gained through the transmission reinforcement.

As expected there is greater variation in the results of the complete year analysis because of the varied modelling approaches taken. For example the network component for MEXICO is higher than others most likely because it utilizes a security constrained dispatch algorithm, while the COMPASS results are lower most likely because of its sequential load model. TPLAN network results are given in the PTI report but are not shown here because they are not available on a comparable basis to the other models. Regardless of these types of variations, all the models show the relative impact of the transmission reinforcement.

Table 10.2
HL2 Analysis EENS Results
(GWh)

Peak Load Analysis

| Participant | Program | Base System | | | Improved System | | |
|-------------------|-------------|-------------|---------|-------|-----------------|---------|-------|
| | | Generation | Network | HL2 | Generation | Network | HL2 |
| ENEL (Italy) | SICRET #1 | 20.9 | 73.0 | 93.9* | 20.9 | 2.7 | 23.6* |
| | SICRET #2 | 15.5 | 56.9 | 72.4 | 15.5 | 2.2 | 17.7 |
| EDP (Portugal) | ZANZIBAR | 15.1 | 35.7 | 50.8 | 14.6 | 2.8 | 17.4 |
| EDF (France) | MEXICO | 15.2 | 53.9 | 69.1 | 15.2 | 1.3 | 16.6 |
| UMIST (UK) | COMPASS | 15.7 | 59.6 | 75.3 | 15.7 | 1.1 | 16.8 |
| | RELACS | -- | -- | 38.1 | -- | -- | -- |
| NGC (UK) | ESCORT | 13.1 | 80.3 | 93.4 | 13.0 | 2.4 | 15.4 |
| PTI (USA) | MAREL/TPLAN | 13.6 | -- | -- | 13.6 | -- | -- |
| USask (Canada) | MECORE | 14.7 | 38.3 | 52.9 | 14.7 | 1.7 | 16.4 |
| | COMREL | -- | -- | 46.7 | -- | -- | 20.6 |
| NB Power (Canada) | NB HL1 | 14.5 | -- | -- | 14.5 | -- | -- |

Complete Year Analysis

| Participant | Program | Base System | | | Improved System | | |
|-------------------|-------------|-------------|---------|-------|-----------------|---------|-------|
| | | Generation | Network | HL2 | Generation | Network | HL2 |
| ENEL (Italy) | SICRET #1 | 0.41 | 4.1 | 4.5* | 0.41 | 1.6 | 2.0* |
| | SICRET #2 | 0.28 | 3.2 | 3.5 | 0.28 | 1.6 | 1.9 |
| EDP (Portugal) | ZANZIBAR | 1.50 | 3.9 | 5.4 | 1.50 | 0.6 | 2.1 |
| EDF (France) | MEXICO | 0.80 | 5.3 | 6.1 | 0.80 | 2.3 | 3.1 |
| UMIST (UK) | COMPASS | 0.12 | 0.7 | 0.8 | 0.12 | 0.05 | 0.17 |
| NGC (UK) | ESCORT | 0.11 | 0.2 | 0.3** | 0.11 | 0.2 | 0.3** |
| PTI (USA) | MAREL/TPLAN | | | | | | |
| USask (Canada) | MECORE | 0.20 | 0.9 | 1.1 | 0.20 | 0.3 | 0.5 |
| NB Power (Canada) | NB HL1 | 0.31 | -- | -- | 0.31 | -- | -- |

* SICRET #1 includes 52 MW Interruptible Load as firm load

** Based on insufficient simulations for convergence

Table 10.3
HL2 Analysis LOLE Results
(hours/year)

Peak Load Analysis

| <u>Participant</u> | <u>Program</u> | <u>Base System</u> | | | <u>Improved System</u> | | |
|--------------------|----------------|--------------------|----------------|------------|------------------------|----------------|------------|
| | | <u>Generation</u> | <u>Network</u> | <u>HL2</u> | <u>Generation</u> | <u>Network</u> | <u>HL2</u> |
| ENEL (Italy) | SICRET #1 | 114 | 1790 | -- | 114 | 96 | -- |
| | SICRET #2 | 92 | 1750 | -- | 92 | 79 | -- |
| EDP (Portugal) | ZANZIBAR | | | | | | |
| EDF (France) | MEXICO | 95 | 1762 | 1842 | 95 | 43 | 128 |
| UMIST (UK) | COMPASS | 93 | 2000 | 2048 | 93 | 193 | 253 |
| NGC (UK) | ESCORT | | | | | | |
| PTI (USA) | TPLAN | | | | | | |
| USask (Canada) | MECORE | 85 | -- | 1565 | 85 | -- | 110 |
| NB Power (Canada) | NB HL1 | 82 | -- | -- | 82 | -- | -- |

Complete Year Analysis

| <u>Participant</u> | <u>Program</u> | <u>Base System</u> | | | <u>Improved System</u> | | |
|--------------------|----------------|--------------------|----------------|------------|------------------------|----------------|------------|
| | | <u>Generation</u> | <u>Network</u> | <u>HL2</u> | <u>Generation</u> | <u>Network</u> | <u>HL2</u> |
| ENEL (Italy) | SICRET #1 | 2.8 | 135 | | 2.8 | 41 | |
| | SICRET #2 | 2.1 | 105 | | 2.8 | 41 | |
| EDP (Portugal) | ZANZIBAR | | | | | | |
| EDF (France) | MEXICO | -- | 1.6 | -- | -- | 0.6 | -- |
| UMIST (UK) | COMPASS | 0.8 | 56 | 57 | 0.8 | 5.8 | 6.5 |
| NGC (UK) | ESCORT | | | | | | |
| PTI (USA) | TPLAN | | | | | | |
| USask (Canada) | MECORE | 1.3 | -- | 35 | 1.3 | -- | 11.0 |
| NB Power (Canada) | NB HL1 | 2.2 | -- | -- | 2.2 | -- | -- |

10.4 Overloaded Transmission Lines

Many of the composite software packages identify the most severely overloaded transmission lines or transformers by various measures. Some determine the frequency of overloads and/or the average amount of overload. Others use this data to determine the reduction in overload that could be gained by a 1 MW increase in the capability of the transmission line. While this is often expressed in different forms in different programs, a common index is delta EENS reduction per delta MW capacity. Where possible the results of all

programs have been translated to this index for comparison purposes as given in Table 10.4 for the two most commonly overloaded lines. In addition this index or an alternate is used to rank the transmission lines in decreasing order of overload.

Results show that all models identify the transmission line from C.COVE-1837 to MILD47-1860 as being the most critically overloaded before the transmission reinforcement. All models also show a significant improvement in this line loading after the transmission reinforcement.

Table 10.4
Marginal EENS Gain and Ranking For Overloaded Lines
MWh / MW (Rank)

From: C.Cove-1837 NEWCA1-18007
 To: MILD47-1860 MILEK1-1969

Peak Load Analysis

| <u>Participant</u> | <u>Program</u> | <u>Base System</u> | <u>Improved System</u> | <u>Base System</u> | <u>Improved System</u> |
|--------------------|----------------|--------------------|------------------------|--------------------|------------------------|
| ENEL (Italy) | SICRET #1 | 2919 () | 78 () | 760 () | 179 () |
| | SICRET #2 | 2850 () | 55 () | 419 () | 28 () |
| EDP (Portugal) | ZANZIBAR | 8760 (1) | 109 (2) | 190 (3) | 27 (5) |
| EDF (France) | MEXICO | 3234 (1) | 30 (1) | 60 (2) | 13(2) |
| UMIST (UK) | COMPASS | -- | -- | -- | -- |
| NGC (UK) | ESCORT | 3483 (1) | 144 (2) | 159 (2) | 159 (1) |
| PTI (USA) | TPLAN | (1) | (2) | | |
| USASK (Canada) | MECORE | -- | -- | -- | -- |
| | COMREL | -- | -- | -- | -- |

Complete Year Analysis

| <u>Participant</u> | <u>Program</u> | <u>Base System</u> | <u>Improved System</u> | <u>Base System</u> | <u>Improved System</u> |
|--------------------|----------------|--------------------|------------------------|--------------------|------------------------|
| ENEL (Italy) | SICRET #1 | 155 () | 0.4 (2) | 15 (3) | 0.4 (1) |
| | SICRET #2 | 106 () | 0.3 () | 11 () | 0.7 () |
| EDP (Portugal) | ZANZIBAR | 2059 (1) | 0.0 (5) | 17 (3) | 1.0 (4) |
| EDF (France) | MEXICO | 184 (1) | 3.7 (2) | 2.6 (5) | 0.6 (3) |
| UMIST (UK) | COMPASS | -- | -- | -- | -- |
| NGC (UK) | ESCORT | | | | |
| PTI (USA) | TPLAN | | | | |
| USASK (Canada) | MECORE | -- | -- | -- | -- |
| | COMREL | -- | -- | -- | -- |

10.5 Load Point Indices

There are different indices that measure the reliability of a specific load point including frequency of curtailment, MWh of curtailment and frequency of low voltage. It is impossible to report all results in all indices.

The capability of the composite software packages to identify the weak delivery points in the network is illustrated using only one index in Table 10.5. The MWh of curtailment is given for MILD47-1860 and C.BAY1-1813 which are the load points that are most improved by the additional transmission. This illustrates

the general ability of the software packages to quantify specific load point improvements.

It must be noted that load point curtailment is an area that is greatly influenced by the load curtailment philosophy built into the model. In all systems, this is dependent on operator interaction and so becomes very difficult to model in a generic sense. Results show reasonable agreement between the models for the base system which has a clear transmission deficiency, but after transmission reinforcement where there is no clear weakness the results are much more varied.

Table 10.5
Load Point Energy of Curtailment and Ranking
GWh (Rank)

Peak Load Analysis

| <u>Participant</u> | <u>Program</u> | <u>MILD47-1860</u> | | <u>C.BAY1-1813</u> | |
|--------------------|----------------|--------------------|------------------------|--------------------|------------------------|
| | | <u>Base System</u> | <u>Improved System</u> | <u>Base System</u> | <u>Improved System</u> |
| ENEL (Italy) | SICRET #1 | 41.3 (1) | .6 (14) | 11.6 (3) | 1.5 (5) |
| | SICRET #2 | -- | -- | -- | -- |
| EDP (Portugal) | ZANZIBAR | 23 (1) | .1 (17) | 9.5 (2) | 1.3 (3) |
| EDF (France) | MEXICO | 40 (1) | 1.4 (1) | 16.6 (2) | 0.0 (-) |
| UMIST (UK) | COMPASS | 30.7 (1) | .16(32) | 27.2 (2) | 1.0 (3) |
| NGC (UK) | ESCORT | -- | -- | -- | -- |
| PTI (USA) | TPLAN | -- | -- | -- | -- |
| USask (Canada) | MECORE | 7.3 (3) | .22(21) | 16.2 (1) | .40(20) |
| | COMREL | 25.4 (1) | .03(15) | 19.7 (2) | .10(7) |

Complete Year Analysis

| <u>Participant</u> | <u>Program</u> | <u>MILD47-1860</u> | | <u>C.BAY1-1813</u> | |
|--------------------|----------------|--------------------|------------------------|--------------------|------------------------|
| | | <u>Base System</u> | <u>Improved System</u> | <u>Base System</u> | <u>Improved System</u> |
| ENEL (Italy) | SICRET #1 | 1.4 (1) | .002 (42) | 0.5 (2) | .04 (13) |
| | SICRET #2 | -- | -- | -- | -- |
| EDP (Portugal) | ZANZIBAR | 1.6 (1) | .0 (27) | 1.5 (2) | .18 (3) |
| EDF (France) | MEXICO | -- | -- | -- | -- |
| UMIST (UK) | COMPASS | .32 (1) | .001 (30) | .29 (2) | .009 (2) |
| NGC (UK) | ESCORT | -- | -- | -- | -- |
| PTI (USA) | TPLAN | -- | -- | -- | -- |
| USask (Canada) | MECORE | .11 (4) | .002 (21) | .29 (1) | .003 (20) |

10.6 Additional Results

Most of the models are capable of providing additional information which is valid to the power system planning process. Some participants utilized these capabilities for this project and have documented their results in individual reports included in the Appendices. Some of the additional results and capabilities are:

- (a) MEXICO and ESCORT have evaluated the impact of properly tying the availability of contracted participation sales to the availability of the generating units from which the sales are made.
- (b) The reliability benefits of the 52 MW of interruptible load are considered by ENEL using SICRET.
- (c) A cost-benefit analysis of the transmission reinforcement considering the benefits of reduced customer outage costs and reduced system fuel costs is proposed in the ENEL and National Grid reports.
- (d) UMIST has reported statistical parameters such as standard deviation and confidence limits for the main system reliability indices.
- (e) Histograms of transmission line flows are available from many of the models. Actual reported examples are included for TPLAN and ESCORT.
- (f) While the focus of this work has centered on HL2 adequacy, the MEXICO and ESCORT models include some security considerations through the use of a security constrained dispatch algorithm.

- (g) Hydro generation is an integral part of the NB Power system that must be integrated properly with the thermal generation. ZANZIBAR includes a probabilistic model to account for varying river flows and resulting hydro generation.
- (h) TPLAN and COMREL both include full AC load flow capability which provides for an analysis of voltage problems as presented in the Power Technologies Inc. report.
- (i) USask results report the complete set of output reliability indices.

10.7 Future Considerations

Composite generation and transmission reliability evaluation models are not yet in wide use in the utility industry. They are continually evolving such that the various reliability models have certain relative features and strengths compared to each other. From the evaluations done in this project, the following features are recommended for future incorporation into all models:

- (a) capability to handle phase shifting transformers
- (b) capability to handle contract sales of various types especially those tied to the availability of specific generating units.
- (c) consistent approaches to load curtailment which provide some flexibility to incorporate system operating procedures.
- (d) voltage considerations
- (e) security constraints and their impact on generation dispatch
- (f) capability to model the varying availabilities of system components because of adverse weather conditions
- (g) standard output indices
- (h) common mode failures
- (i) limited energy unit capabilities
- (j) flexible hydro plant modelling
- (k) consideration of system losses

While none of the models include all of the above features, each model has shown that it can make a significant contribution to the system planning process.

APPENDIX I
GENERIC SYSTEM DATA

C NB POWER COMPOSITE SYSTEM DATA FOR RELIABILITY EVALUATION

C -----
 C Prepared by
 C CIGRE Task Force 38.03.10 at NB Power
 C November 1990
 C (Updated August 1991)
 C

C*** General Information ***

C-----
 C Col. 4- 5 : number of nodes
 C Col. 9-10 : number of transmission lines
 C Col. 14-15 : number of transformers
 C Col. 19-20 : number of generators
 C Col. 24-25 : number of nodes with load
 C Col. 30 : number of voltage levels
 C Col. 35 : number of meteorological zones
 C Col. 40 : number of weekly cumulative distributions for
 C each type of load
 C Col. 45 : number of load diagram configurations
 C Col. 49-50 : number of nodes with generating units
 C Col. 54 : number of simulated generating stations from
 C interchange areas
 C-----

C 85 98 24 39 49 3 1 4 6 21 6
 C
 C
 C

C*** Node information ***

C-----
 C col. 3- 6 : node identification number
 C " 11 : number of lines connected to node
 C " 16 : number of transformers connected to node
 C " 21-23 : voltage level at node
 C " 28-33 : generating power in MW for peak load
 C " 38-42 : peak active load in MW at this node
 C " 44-49 : peak reactive load in MVAR at this node
 C " 52 : type of cumulative distribution of the load (see monthly
 C load model I)
 C " 55-60 : name of node
 C " 65-69 : base (100% Load Factor) load in MW (see seasonal
 C load model II)
 C " 74-77 : static shunt capacitors in MVAR at rated voltage at this node
 C-----

C 1. Inter-change Generating Nodes

| | | | | | | | | | |
|------|---|---|-----|--------|-------|-------|---|--------|-------|
| 168 | 1 | 2 | 345 | 119.10 | 0.0 | 0.0 | 1 | ONSLO3 | |
| 700 | 2 | 0 | 345 | 0.00 | 230.0 | 54.0 | 3 | ORRING | 230.0 |
| 1844 | 2 | 0 | 138 | 0.00 | 60.0 | -20.0 | 3 | MURRCR | 60.0 |
| 1869 | 1 | 0 | 345 | 0.00 | 200.0 | 40.0 | 4 | MADHYQ | |
| 1896 | 2 | 0 | 138 | 0.00 | 0.0 | 0.0 | 1 | TINKER | |
| 9996 | 2 | 0 | 230 | 0.00 | 200.0 | 40.0 | 4 | EELHYQ | |
| 9997 | 2 | 0 | 345 | 0.00 | 0.0 | 0.0 | 1 | CHESTR | |

SYSTEM DATA - 2

C 2. NB Power Hydro Generating Nodes

| C | | | | | | | | | | |
|------|---|---|-----|--------|------|------|---|--------|------|--|
| 1800 | 4 | 0 | 138 | 80.00 | 39.1 | 20.0 | 2 | BEECHW | 15.0 | |
| 1802 | 2 | 0 | 138 | 30.00 | 0.0 | 0.0 | 1 | GRFALL | | |
| 1809 | 3 | 0 | 138 | 500.00 | 20.7 | 5.0 | 1 | MACTQC | | |

C 3. NB Power Thermal Generating Nodes

| C | | | | | | | | | | |
|------|---|---|-----|---------|-------|------|---|--------|------|------|
| 1677 | 2 | 0 | 138 | 100.00 | 135.7 | 24.0 | 1 | CARAQT | | |
| 1807 | 3 | 2 | 138 | 20.00 | 191.0 | 74.0 | 2 | NEWCA1 | 30.0 | 70.0 |
| 1811 | 3 | 0 | 138 | 230.00 | 46.2 | 30.0 | 1 | GRLAKE | | |
| 1812 | 6 | 0 | 138 | 0.00 | 350.6 | 87.5 | 1 | MONCTN | 17.0 | 55.0 |
| 1813 | 4 | 0 | 138 | 253.80 | 245.6 | 50.4 | 2 | C.BAY1 | 40.0 | 20.0 |
| 1826 | 1 | 0 | 138 | 306.00 | 0.0 | 0.0 | 1 | DALHOU | | |
| 1836 | 3 | 2 | 345 | 1005.00 | 0.0 | 0.0 | 1 | C.COV3 | | |
| 1843 | 3 | 0 | 345 | 657.00 | 22.0 | 10.0 | 3 | LEPRAU | 22.0 | |
| 1847 | 2 | 0 | 138 | 0.00 | 55.0 | 14.8 | 2 | 112572 | 20.0 | |
| 1910 | 1 | 0 | 138 | 40.00 | 153.9 | 33.6 | 2 | IROQUB | 60.0 | |
| 1913 | 2 | 0 | 345 | 450.00 | 0.0 | 0.0 | 1 | BELDUN | | |
| 1948 | 2 | 1 | 138 | 0.00 | 108.8 | 43.4 | 1 | EELRA1 | | 20.0 |
| 1965 | 1 | 0 | 230 | 100.00 | 0.0 | 0.0 | 1 | MILBK2 | | |
| 1969 | 2 | 0 | 138 | 90.00 | 0.0 | 0.0 | 1 | MILBK1 | | |
| 1971 | 1 | 0 | 138 | 0.00 | 58.7 | 18.6 | 1 | PENFLD | | 10.0 |

C 4. Non-Generating Nodes

| C | | | | | | | | | | |
|------|---|---|-----|------|-------|-------|---|--------|------|------|
| 157 | 2 | 0 | 138 | 0.00 | 12.6 | 5.1 | 3 | MACCAN | 12.6 | |
| 158 | 1 | 1 | 138 | 0.00 | 50.1 | 90.5 | 3 | ONSL01 | 50.1 | 50.0 |
| 167 | 0 | 3 | 230 | 0.00 | 31.4 | 112.7 | 3 | ONSL02 | 31.4 | |
| 183 | 3 | 0 | 138 | 0.00 | 23.6 | 7.1 | 3 | SPRNGH | 23.6 | |
| 1679 | 1 | 0 | 138 | 0.00 | 101.5 | 42.0 | 1 | LANCST | | |
| 1681 | 2 | 0 | 138 | 0.00 | 32.9 | 8.3 | 3 | IRVREF | 32.9 | |
| 1712 | 2 | 0 | 138 | 0.00 | 149.2 | 31.0 | 2 | RICHBT | 40.0 | |
| 1717 | 2 | 0 | 138 | 0.00 | 129.2 | 31.4 | 2 | 114963 | 23.4 | |
| 1747 | 2 | 0 | 138 | 0.00 | 0.0 | 0.0 | 1 | NORPSR | | |
| 1776 | 2 | 0 | 138 | 0.00 | 46.2 | 13.5 | 2 | 114981 | 19.1 | |
| 1803 | 4 | 3 | 345 | 0.00 | 0.0 | 0.0 | 1 | KESWK3 | | |
| 1804 | 2 | 0 | 138 | 0.00 | 14.9 | 3.7 | 1 | 117562 | | |
| 1805 | 4 | 1 | 138 | 0.00 | 15.9 | 2.0 | 3 | EELRV1 | 15.9 | |
| 1806 | 4 | 3 | 138 | 0.00 | 130.5 | 53.0 | 1 | BATHS1 | | 40.0 |
| 1810 | 4 | 0 | 138 | 0.00 | 159.6 | 41.0 | 1 | MARYSV | | |
| 1817 | 3 | 0 | 138 | 0.00 | 0.0 | 0.0 | 1 | 111144 | | |
| 1824 | 2 | 0 | 138 | 0.00 | 46.6 | 14.5 | 2 | 111528 | 27.0 | |
| 1825 | 3 | 0 | 138 | 0.00 | 0.0 | 0.0 | 1 | MEMCOK | | |
| 1827 | 6 | 2 | 138 | 0.00 | 0.0 | 0.0 | 1 | KESWK1 | | |
| 1828 | 2 | 1 | 230 | 0.00 | 0.0 | 0.0 | 1 | KESWK2 | | |
| 1829 | 3 | 2 | 230 | 0.00 | 0.0 | 0.0 | 1 | BATHS2 | | |
| 1830 | 4 | 3 | 230 | 0.00 | 0.0 | 0.0 | 1 | EELRV2 | | |
| 1832 | 2 | 0 | 138 | 0.00 | 15.5 | 8.0 | 2 | 110553 | 5.5 | |
| 1834 | 1 | 0 | 138 | 0.00 | 60.2 | 24.8 | 1 | OAKBAY | | 30.0 |
| 1835 | 2 | 0 | 138 | 0.00 | 0.0 | 0.0 | 1 | 110421 | | |
| 1837 | 5 | 2 | 138 | 0.00 | 0.0 | 0.0 | 1 | C.COV1 | | |
| 1838 | 1 | 1 | 230 | 0.00 | 0.0 | 0.0 | 1 | SALBR2 | | |
| 1839 | 5 | 3 | 138 | 0.00 | 0.0 | 0.0 | 1 | SALBR1 | | |
| 1845 | 2 | 0 | 138 | 0.00 | 20.9 | 5.3 | 1 | NASH03 | | |
| 1846 | 2 | 0 | 138 | 0.00 | 20.9 | 5.3 | 1 | NASH12 | | |
| 1849 | 2 | 1 | 138 | 0.00 | 0.0 | 0.0 | 1 | STAND1 | | |
| 1850 | 3 | 2 | 345 | 0.00 | 0.0 | 0.0 | 1 | SALBR3 | | 16.0 |
| 1851 | 2 | 3 | 230 | 0.00 | 0.0 | 0.0 | 1 | NEWCA2 | | |
| 1852 | 2 | 0 | 138 | 0.00 | 21.9 | 5.5 | 1 | 110871 | | |
| 1854 | 2 | 0 | 138 | 0.00 | 4.8 | 1.2 | 1 | HARDRD | | |

SYSTEM DATA - 3

| | | | | | | | | | |
|------|---|---|-----|------|-------|------|---|--------|------|
| 1860 | 2 | 0 | 138 | 0.00 | 26.0 | 6.6 | 1 | MILD47 | |
| 1861 | 2 | 0 | 138 | 0.00 | 119.2 | 30.0 | 1 | DOAKST | |
| 1862 | 2 | 0 | 138 | 0.00 | 0.0 | 0.0 | 1 | MILD65 | |
| 1863 | 3 | 0 | 138 | 0.00 | 65.8 | 34.1 | 1 | 119042 | |
| 1865 | 2 | 0 | 138 | 0.00 | 2.1 | 0.5 | 3 | 111036 | 2.1 |
| 1866 | 2 | 1 | 345 | 0.00 | 0.0 | 0.0 | 1 | EELRV3 | |
| 1867 | 2 | 2 | 345 | 0.00 | 0.0 | 0.0 | 1 | EDMST3 | |
| 1868 | 3 | 1 | 345 | 0.00 | 0.0 | 0.0 | 1 | STAND3 | |
| 1900 | 2 | 1 | 345 | 0.00 | 0.0 | 0.0 | 1 | NORTN3 | |
| 1901 | 2 | 1 | 138 | 0.00 | 0.0 | 0.0 | 1 | NORTN1 | |
| 1907 | 2 | 2 | 138 | 0.00 | 0.0 | 0.0 | 1 | EDMST1 | |
| 1908 | 2 | 0 | 138 | 0.00 | 0.0 | 0.0 | 1 | 114084 | |
| 1909 | 1 | 0 | 138 | 0.00 | 122.7 | 37.0 | 1 | IROQUA | 30.0 |
| 1915 | 2 | 1 | 345 | 0.00 | 0.0 | 0.0 | 1 | BATHS3 | |
| 1916 | 2 | 1 | 345 | 0.00 | 0.0 | 0.0 | 1 | NEWCA3 | |
| 1928 | 3 | 0 | 138 | 0.00 | 0.0 | 0.0 | 1 | 110684 | |
| 1930 | 2 | 0 | 138 | 0.00 | 50.3 | 20.8 | 1 | 1126MP | |
| 1945 | 3 | 0 | 138 | 0.00 | 6.6 | 1.5 | 1 | 119024 | |
| 1946 | 3 | 0 | 138 | 0.00 | 6.6 | 1.5 | 1 | 112408 | |
| 1964 | 3 | 0 | 230 | 0.00 | 0.0 | 0.0 | 1 | MBNKTP | |
| 2495 | 1 | 0 | 138 | 0.00 | 29.7 | 7.5 | 3 | NBIPC1 | 29.7 |
| 2496 | 1 | 0 | 138 | 0.00 | 89.1 | 22.3 | 3 | ROTHPR | 89.1 |
| 2497 | 1 | 0 | 138 | 0.00 | 52.0 | 13.1 | 3 | BRMINE | 52.0 |
| 2498 | 1 | 0 | 230 | 0.00 | 68.9 | 17.3 | 3 | NBIPC2 | 68.9 |
| 2499 | 1 | 0 | 230 | 0.00 | 60.0 | 16.4 | 3 | CONSBH | 60.0 |

C

C

C

C *** Transmission Line Information ***

C

C -----

C There are two data lines for each transmission line.

C Data Line 1:

C Col. 2- 3 : progressive number of line

C Col. 5- 8 : identification number of node at 1st extreme end of line

C Col. 10-13 : identification number of node at 2nd extreme end of line

C Col. 15 : indication of weather zone to which line belongs

C Col. 17-18 : week line maintenance begins

C Col. 20-21 : week line maintenance ends

C Col. 23-28 : length of line in km

C Col. 32-39 : probable unavailability for 100 km of line

C (including terminal related forced outages)

C Col. 44-50 : failure rate in failures per year

C Col. 54-60 : repair duration in hours per repair

C Data Line 2:

C Col. 13-18 : resistance in ohms/ km of line

C Col. 20-25 : reactance in ohms/ km of line

C Col. 27-29 : voltage level in line (kV)

C Col. 32-36 : emergency transmission capability of line in MW

C Col. 39-43 : normal transmission capability of line in MW

C Col. 46-52 : resistance of line in pu

C Col. 54-60 : reactance of line in pu

C Col. 63-69 : total line charging capacitive

susceptance/admittance in pu

C -----

C

| | | | | | | | | | | | | | |
|---|-----|------|---|---|---|--------|----------|---------|-------|-------|---------|---------|---------|
| 1 | 157 | 183 | 1 | 0 | 0 | 15.00 | 0.000000 | 0.00000 | 0.00 | | | | |
| | | | | | | 0.1200 | 0.4963 | 138 | 220.0 | 140.0 | 0.00880 | 0.03940 | 0.00000 |
| 2 | 157 | 1825 | 1 | 0 | 0 | 43.20 | 0.000477 | 0.37412 | 4.83 | | | | |
| | | | | | | 0.1200 | 0.4963 | 138 | 220.0 | 140.0 | 0.02518 | 0.11266 | 0.00000 |

SYSTEM DATA - 4

| | | | | | | | | | | | |
|----|------|------|---|---|---|--------|----------|---------|-------|-------|-------------------------|
| 3 | 158 | 183 | 1 | 0 | 0 | 68.00 | 0.000000 | 0.00000 | 0.00 | | |
| | | | | | | 0.1200 | 0.4963 | 138 | 220.0 | 140.0 | 0.03710 0.17170 0.04360 |
| 4 | 168 | 1850 | 1 | 0 | 0 | 159.74 | 0.000957 | 0.49888 | 26.88 | | |
| | | | | | | 0.0390 | 0.4270 | 345 | 400.0 | 400.0 | 0.00504 0.05727 0.00000 |
| 5 | 183 | 1863 | 1 | 0 | 0 | 51.30 | 0.000477 | 0.44421 | 4.83 | | |
| | | | | | | 0.1200 | 0.4800 | 138 | 220.0 | 140.0 | 0.03052 0.12998 0.00000 |
| 6 | 700 | 1843 | 1 | 0 | 0 | 210.00 | 0.000000 | 0.00000 | 0.00 | | |
| | | | | | | 0.0390 | 0.3723 | 345 | 900.0 | 700.0 | 0.00670 0.07020 1.19620 |
| 7 | 700 | 9997 | 1 | 0 | 0 | 76.04 | 0.000000 | 0.00000 | 0.00 | | |
| | | | | | | 0.0468 | 0.3710 | 345 | 900.0 | 700.0 | 0.00299 0.02370 0.00000 |
| 8 | 1677 | 1806 | 1 | 0 | 0 | 56.00 | 0.000477 | 0.48492 | 4.83 | | |
| | | | | | | 0.1200 | 0.4520 | 138 | 220.0 | 140.0 | 0.03400 0.13290 0.03920 |
| 9 | 1677 | 1928 | 1 | 0 | 0 | 45.00 | 0.000477 | 0.38965 | 4.83 | | |
| | | | | | | 0.1200 | 0.4520 | 138 | 220.0 | 140.0 | 0.04778 0.18992 0.00000 |
| 10 | 1679 | 1837 | 1 | 0 | 0 | 12.97 | 0.000477 | 0.11229 | 4.83 | | |
| | | | | | | 0.1200 | 0.4669 | 138 | 220.0 | 190.0 | 0.00550 0.03180 0.00870 |
| 11 | 1681 | 1717 | 1 | 0 | 0 | 19.41 | 0.000477 | 0.16805 | 4.83 | | |
| | | | | | | 0.1295 | 0.5897 | 138 | 220.0 | 190.0 | 0.01320 0.06010 0.00000 |
| 12 | 1681 | 1813 | 1 | 0 | 0 | 1.84 | 0.000477 | 0.01593 | 4.83 | | |
| | | | | | | 0.1200 | 0.4852 | 138 | 220.0 | 140.0 | 0.00110 0.00470 0.00120 |
| 13 | 1712 | 1807 | 1 | 0 | 0 | 89.99 | 0.000477 | 0.77938 | 4.83 | | |
| | | | | | | 0.1071 | 0.4954 | 138 | 220.0 | 140.0 | 0.05059 0.23408 0.00000 |
| 14 | 1712 | 1812 | 1 | 0 | 0 | 77.01 | 0.000477 | 0.66692 | 4.83 | | |
| | | | | | | 0.1118 | 0.4953 | 138 | 220.0 | 140.0 | 0.04520 0.20030 0.00000 |
| 15 | 1717 | 1747 | 1 | 0 | 0 | 31.59 | 0.000477 | 0.27352 | 4.83 | | |
| | | | | | | 0.1302 | 0.5895 | 138 | 220.0 | 190.0 | 0.02160 0.09779 0.00000 |
| 16 | 1747 | 1901 | 1 | 0 | 0 | 16.75 | 0.000000 | 0.00000 | 0.00 | | |
| | | | | | | 0.0171 | 0.5895 | 138 | 220.0 | 190.0 | 0.00150 0.05185 0.00000 |
| 17 | 1776 | 1839 | 1 | 0 | 0 | 51.26 | 0.000477 | 0.44387 | 4.83 | | |
| | | | | | | 0.1048 | 0.4480 | 138 | 220.0 | 140.0 | 0.02820 0.12059 0.00000 |
| 18 | 1776 | 1901 | 1 | 0 | 0 | 15.47 | 0.000477 | 0.13393 | 4.83 | | |
| | | | | | | 0.1059 | 0.4481 | 138 | 220.0 | 140.0 | 0.00860 0.03640 0.00000 |
| 19 | 1800 | 1817 | 1 | 0 | 0 | 34.76 | 0.000477 | 0.30097 | 4.83 | | |
| | | | | | | 0.1200 | 0.4640 | 138 | 220.0 | 140.0 | 0.02120 0.08470 0.02360 |
| 20 | 1800 | 1847 | 1 | 0 | 0 | 65.21 | 0.000477 | 0.56470 | 4.83 | | |
| | | | | | | 0.1200 | 0.4667 | 138 | 220.0 | 140.0 | 0.03970 0.15890 0.04430 |
| 21 | 1800 | 1896 | 1 | 0 | 0 | 44.00 | 0.000477 | 0.38099 | 4.83 | | |
| | | | | | | 0.1200 | 0.4667 | 138 | 220.0 | 140.0 | 0.12681 0.47602 0.00000 |
| 22 | 1800 | 1930 | 1 | 0 | 0 | 32.18 | 0.000477 | 0.27862 | 4.83 | | |
| | | | | | | 0.1200 | 0.4801 | 138 | 220.0 | 140.0 | 0.01962 0.08113 0.02122 |
| 23 | 1802 | 1804 | 1 | 0 | 0 | 0.62 | 0.000477 | 0.00538 | 4.83 | | |
| | | | | | | 0.1200 | 0.5221 | 138 | 220.0 | 190.0 | 0.00050 0.00170 0.00040 |
| 24 | 1802 | 1817 | 1 | 0 | 0 | 23.49 | 0.000477 | 0.20338 | 4.83 | | |
| | | | | | | 0.1200 | 0.4645 | 138 | 220.0 | 140.0 | 0.01430 0.05730 0.01600 |
| 25 | 1803 | 1836 | 1 | 0 | 0 | 116.83 | 0.000957 | 0.36472 | 26.88 | | |
| | | | | | | 0.0390 | 0.3943 | 345 | 900.0 | 700.0 | 0.00410 0.03870 0.58410 |
| 26 | 1803 | 1843 | 1 | 0 | 0 | 135.01 | 0.000957 | 0.42154 | 26.88 | | |
| | | | | | | 0.0390 | 0.3941 | 345 | 900.0 | 700.0 | 0.00470 0.04470 0.67500 |
| 27 | 1803 | 1868 | 1 | 0 | 0 | 146.12 | 0.000957 | 0.45628 | 26.88 | | |
| | | | | | | 0.0390 | 0.3943 | 345 | 900.0 | 700.0 | 0.00510 0.04840 0.73040 |
| 28 | 1803 | 9997 | 1 | 0 | 0 | 164.70 | 0.000000 | 0.00000 | 0.00 | | |
| | | | | | | 0.0358 | 0.3710 | 345 | 900.0 | 700.0 | 0.00496 0.05133 0.00000 |
| 29 | 1804 | 1849 | 1 | 0 | 0 | 13.30 | 0.000477 | 0.11515 | 4.83 | | |
| | | | | | | 0.1200 | 0.4940 | 138 | 220.0 | 190.0 | 0.00940 0.03450 0.00850 |
| 30 | 1805 | 1824 | 1 | 0 | 0 | 58.75 | 0.000477 | 0.50874 | 4.83 | | |
| | | | | | | 0.0536 | 0.4779 | 138 | 220.0 | 140.0 | 0.03577 0.14744 0.00000 |
| 31 | 1805 | 1826 | 1 | 0 | 0 | 7.50 | 0.000477 | 0.06493 | 4.83 | | |
| | | | | | | 0.1200 | 0.4698 | 138 | 400.0 | 310.0 | 0.00210 0.01860 0.00510 |
| 32 | 1805 | 1865 | 1 | 0 | 0 | 23.77 | 0.000477 | 0.20580 | 4.83 | | |
| | | | | | | 0.1200 | 0.4935 | 138 | 220.0 | 140.0 | 0.01650 0.06160 0.01520 |

SYSTEM DATA - 5

| | | | | | | | | | | | | | | |
|----|------|------|---|---|---|--------|----------|----------|------|-------|-------|----------|---------|---------|
| 33 | 1805 | 1948 | 1 | 0 | 0 | 0.01 | 0.000000 | 0.000000 | 0.00 | | | | | |
| | | | | | | | 0.1200 | 0.4935 | 138 | 900.0 | 700.0 | 0.000000 | 0.00010 | 0.00000 |
| 34 | 1806 | 1824 | 1 | 0 | 0 | 27.53 | 0.000477 | 0.23836 | 4.83 | | | | | |
| | | | | | | | 0.1148 | 0.4779 | 138 | 220.0 | 140.0 | 0.01659 | 0.06909 | 0.00000 |
| 35 | 1806 | 1928 | 1 | 0 | 0 | 22.53 | 0.000477 | 0.19506 | 4.83 | | | | | |
| | | | | | | | 0.1200 | 0.4820 | 138 | 220.0 | 140.0 | 0.01378 | 0.05702 | 0.01490 |
| 36 | 1806 | 2497 | 1 | 0 | 0 | 27.00 | 0.000000 | 0.000000 | 0.00 | | | | | |
| | | | | | | | 0.1200 | 0.4820 | 138 | 220.0 | 140.0 | 0.01620 | 0.06540 | 0.01800 |
| 37 | 1807 | 1832 | 1 | 0 | 0 | 64.31 | 0.000477 | 0.55690 | 4.83 | | | | | |
| | | | | | | | 0.1153 | 0.4959 | 138 | 220.0 | 140.0 | 0.03894 | 0.16747 | 0.00000 |
| 38 | 1807 | 1969 | 1 | 0 | 0 | 18.37 | 0.000477 | 0.15904 | 4.83 | | | | | |
| | | | | | | | 0.1200 | 0.4969 | 138 | 220.0 | 140.0 | 0.00870 | 0.03610 | 0.00000 |
| 39 | 1809 | 1827 | 1 | 0 | 0 | 11.60 | 0.000477 | 0.10043 | 4.83 | | | | | |
| | | | | | | | 0.1200 | 0.4695 | 138 | 320.0 | 280.0 | 0.00330 | 0.02860 | 0.00780 |
| 40 | 1809 | 1827 | 1 | 0 | 0 | 11.60 | 0.000477 | 0.10043 | 4.83 | | | | | |
| | | | | | | | 0.1200 | 0.4695 | 138 | 320.0 | 280.0 | 0.00330 | 0.02880 | 0.00790 |
| 41 | 1809 | 1861 | 1 | 0 | 0 | 15.71 | 0.000477 | 0.13601 | 4.83 | | | | | |
| | | | | | | | 0.0897 | 0.4606 | 138 | 240.0 | 190.0 | 0.00740 | 0.03800 | 0.00000 |
| 42 | 1810 | 1811 | 1 | 0 | 0 | 49.08 | 0.000477 | 0.42498 | 4.83 | | | | | |
| | | | | | | | 0.1200 | 0.4800 | 138 | 230.0 | 140.0 | 0.02990 | 0.12370 | 0.03230 |
| 43 | 1810 | 1845 | 1 | 0 | 0 | 5.31 | 0.000477 | 0.04597 | 4.83 | | | | | |
| | | | | | | | 0.1200 | 0.4806 | 138 | 220.0 | 140.0 | 0.00320 | 0.01340 | 0.00350 |
| 44 | 1810 | 1846 | 1 | 0 | 0 | 5.23 | 0.000477 | 0.04528 | 4.83 | | | | | |
| | | | | | | | 0.1200 | 0.4624 | 138 | 220.0 | 140.0 | 0.00320 | 0.01270 | 0.00360 |
| 45 | 1810 | 1861 | 1 | 0 | 0 | 13.68 | 0.000477 | 0.11844 | 4.83 | | | | | |
| | | | | | | | 0.1239 | 0.4608 | 138 | 220.0 | 140.0 | 0.00890 | 0.03310 | 0.00000 |
| 46 | 1811 | 1812 | 1 | 0 | 0 | 95.25 | 0.000477 | 0.82495 | 4.83 | | | | | |
| | | | | | | | 0.1200 | 0.4826 | 138 | 220.0 | 140.0 | 0.05780 | 0.24140 | 0.06200 |
| 47 | 1811 | 1832 | 1 | 0 | 0 | 52.19 | 0.000477 | 0.45192 | 4.83 | | | | | |
| | | | | | | | 0.1170 | 0.4960 | 138 | 220.0 | 140.0 | 0.03206 | 0.13592 | 0.00000 |
| 48 | 1812 | 1839 | 1 | 0 | 0 | 14.91 | 0.000477 | 0.12908 | 4.83 | | | | | |
| | | | | | | | 0.1200 | 0.4803 | 138 | 240.0 | 190.0 | 0.00910 | 0.03760 | 0.00980 |
| 49 | 1812 | 1839 | 1 | 0 | 0 | 14.91 | 0.000477 | 0.12908 | 4.83 | | | | | |
| | | | | | | | 0.1200 | 0.4803 | 138 | 240.0 | 190.0 | 0.00910 | 0.03760 | 0.00980 |
| 50 | 1812 | 1945 | 1 | 0 | 0 | 6.00 | 0.000477 | 0.05194 | 4.83 | | | | | |
| | | | | | | | 0.1200 | 0.4803 | 138 | 220.0 | 140.0 | 0.00529 | 0.02001 | 0.00000 |
| 51 | 1812 | 1946 | 1 | 0 | 0 | 6.00 | 0.000477 | 0.05194 | 4.83 | | | | | |
| | | | | | | | 0.1200 | 0.4803 | 138 | 220.0 | 140.0 | 0.00529 | 0.02001 | 0.00000 |
| 52 | 1813 | 1860 | 1 | 0 | 0 | 9.43 | 0.000477 | 0.08164 | 4.83 | | | | | |
| | | | | | | | 0.1200 | 0.4827 | 138 | 220.0 | 140.0 | 0.00580 | 0.02390 | 0.00610 |
| 53 | 1813 | 1862 | 1 | 0 | 0 | 9.43 | 0.000477 | 0.08164 | 4.83 | | | | | |
| | | | | | | | 0.1200 | 0.4827 | 138 | 220.0 | 140.0 | 0.00580 | 0.02390 | 0.00610 |
| 54 | 1813 | 2496 | 1 | 0 | 0 | 0.60 | 0.000000 | 0.000000 | 0.00 | | | | | |
| | | | | | | | 0.1200 | 0.4827 | 138 | 220.0 | 140.0 | 0.00040 | 0.00170 | 0.00040 |
| 55 | 1817 | 1896 | 1 | 0 | 0 | 7.02 | 0.000477 | 0.06077 | 4.83 | | | | | |
| | | | | | | | 0.1200 | 0.4801 | 138 | 220.0 | 140.0 | 0.00430 | 0.01780 | 0.00470 |
| 56 | 1825 | 1844 | 1 | 0 | 0 | 50.21 | 0.000000 | 0.000000 | 0.00 | | | | | |
| | | | | | | | 0.1200 | 0.4798 | 138 | 220.0 | 140.0 | 0.03060 | 0.12650 | 0.03110 |
| 57 | 1825 | 1852 | 1 | 0 | 0 | 22.42 | 0.000477 | 0.19411 | 4.83 | | | | | |
| | | | | | | | 0.1200 | 0.4986 | 138 | 220.0 | 140.0 | 0.01460 | 0.05870 | 0.01420 |
| 58 | 1827 | 1845 | 1 | 0 | 0 | 17.20 | 0.000477 | 0.14891 | 4.83 | | | | | |
| | | | | | | | 0.1200 | 0.4805 | 138 | 220.0 | 140.0 | 0.01050 | 0.04340 | 0.01130 |
| 59 | 1827 | 1846 | 1 | 0 | 0 | 17.20 | 0.000477 | 0.14891 | 4.83 | | | | | |
| | | | | | | | 0.1200 | 0.4805 | 138 | 220.0 | 140.0 | 0.01050 | 0.04200 | 0.01170 |
| 60 | 1827 | 1847 | 1 | 0 | 0 | 23.29 | 0.000477 | 0.20164 | 4.83 | | | | | |
| | | | | | | | 0.1200 | 0.4644 | 138 | 220.0 | 140.0 | 0.01420 | 0.05680 | 0.01580 |
| 61 | 1827 | 1930 | 1 | 0 | 0 | 56.40 | 0.000477 | 0.48839 | 4.83 | | | | | |
| | | | | | | | 0.1200 | 0.4801 | 138 | 220.0 | 140.0 | 0.03438 | 0.14217 | 0.03718 |
| 62 | 1828 | 1838 | 1 | 0 | 0 | 146.89 | 0.000780 | 1.50532 | 6.68 | | | | | |
| | | | | | | | 0.0780 | 0.4837 | 230 | 480.0 | 350.0 | 0.02280 | 0.13430 | 0.26720 |

SYSTEM DATA - 6

| | | | | | | | | | | |
|----|------|------|---|---|---|-------------------|----------|---------|---------|-----------------|
| 63 | 1828 | 1851 | 1 | 0 | 0 | 145.46 | 0.000780 | 1.49065 | 6.68 | |
| | | | | | | 0.0780 0.4670 230 | 480.0 | 350.0 | 0.02240 | 0.12840 0.43560 |
| 64 | 1829 | 1830 | 1 | 0 | 0 | 88.34 | 0.000780 | 0.90489 | 6.68 | |
| | | | | | | 0.0780 0.4838 230 | 480.0 | 350.0 | 0.00690 | 0.06590 0.19660 |
| 65 | 1829 | 1964 | 1 | 0 | 0 | 49.19 | 0.000780 | 0.50371 | 6.68 | |
| | | | | | | 0.0780 0.4673 230 | 480.0 | 350.0 | 0.00820 | 0.04680 0.09980 |
| 66 | 1829 | 2499 | 1 | 0 | 0 | 4.00 | 0.000000 | 0.00000 | 0.00 | |
| | | | | | | 0.0780 0.4673 230 | 480.0 | 350.0 | 0.00060 | 0.00330 0.00740 |
| 67 | 1830 | 2498 | 1 | 0 | 0 | 9.00 | 0.000000 | 0.00000 | 0.00 | |
| | | | | | | 0.0780 0.4673 230 | 480.0 | 350.0 | 0.00140 | 0.00850 0.01710 |
| 68 | 1830 | 9996 | 1 | 0 | 0 | 34.00 | 0.000000 | 0.00000 | 0.00 | |
| | | | | | | 0.0780 0.4673 230 | 480.0 | 350.0 | 0.00170 | 0.00990 0.00000 |
| 69 | 1830 | 9996 | 1 | 0 | 0 | 34.00 | 0.000000 | 0.00000 | 0.00 | |
| | | | | | | 0.0780 0.4673 230 | 480.0 | 350.0 | 0.00170 | 0.00990 0.00000 |
| 70 | 1834 | 1835 | 1 | 0 | 0 | 65.56 | 0.000477 | 0.56773 | 4.83 | |
| | | | | | | 0.1200 0.4802 138 | 220.0 | 140.0 | 0.03989 | 0.16517 0.00000 |
| 71 | 1835 | 1837 | 1 | 0 | 0 | 71.91 | 0.000477 | 0.62274 | 4.83 | |
| | | | | | | 0.1200 0.4907 138 | 220.0 | 140.0 | 0.04090 | 0.18530 0.04640 |
| 72 | 1836 | 1843 | 1 | 0 | 0 | 28.80 | 0.000957 | 0.08983 | 26.88 | |
| | | | | | | 0.0390 0.3968 345 | 900.0 | 900.0 | 0.00100 | 0.00960 0.14400 |
| 73 | 1836 | 1900 | 1 | 0 | 0 | 87.00 | 0.000957 | 0.27152 | 26.88 | |
| | | | | | | 0.0390 0.3937 345 | 900.0 | 700.0 | 0.00340 | 0.03270 0.49310 |
| 74 | 1837 | 1860 | 1 | 0 | 0 | 22.48 | 0.000477 | 0.19463 | 4.83 | |
| | | | | | | 0.1200 0.4736 138 | 220.0 | 140.0 | 0.01120 | 0.05590 0.01510 |
| 75 | 1837 | 1862 | 1 | 0 | 0 | 23.43 | 0.000477 | 0.20286 | 4.83 | |
| | | | | | | 0.1200 0.4698 138 | 220.0 | 140.0 | 0.01240 | 0.05780 0.01580 |
| 76 | 1837 | 1971 | 1 | 0 | 0 | 50.70 | 0.000477 | 0.43902 | 4.83 | |
| | | | | | | 0.1200 0.4527 138 | 220.0 | 140.0 | 0.02931 | 0.11457 0.01809 |
| 77 | 1839 | 1945 | 1 | 0 | 0 | 24.00 | 0.000477 | 0.20779 | 4.83 | |
| | | | | | | 0.1200 0.4748 138 | 220.0 | 140.0 | 0.01000 | 0.04010 0.01130 |
| 78 | 1839 | 1946 | 1 | 0 | 0 | 24.00 | 0.000477 | 0.20779 | 4.83 | |
| | | | | | | 0.1200 0.4748 138 | 220.0 | 140.0 | 0.01000 | 0.04010 0.01130 |
| 79 | 1844 | 1854 | 1 | 0 | 0 | 11.47 | 0.000000 | 0.00000 | 0.00 | |
| | | | | | | 0.1200 0.4798 138 | 220.0 | 140.0 | 0.00700 | 0.02890 0.00760 |
| 80 | 1849 | 1865 | 1 | 0 | 0 | 124.62 | 0.000477 | 1.07948 | 4.83 | |
| | | | | | | 0.1200 0.4938 138 | 220.0 | 140.0 | 0.08830 | 0.32310 0.07950 |
| 81 | 1850 | 1900 | 1 | 0 | 0 | 69.82 | 0.000957 | 0.21786 | 26.88 | |
| | | | | | | 0.0390 0.3938 345 | 900.0 | 700.0 | 0.00230 | 0.02210 0.33390 |
| 82 | 1850 | 1916 | 1 | 0 | 0 | 119.09 | 0.000957 | 0.37178 | 26.88 | |
| | | | | | | 0.0390 0.3938 345 | 900.0 | 700.0 | 0.00410 | 0.03940 0.59530 |
| 83 | 1851 | 1964 | 1 | 0 | 0 | 15.00 | 0.000780 | 0.15356 | 6.68 | |
| | | | | | | 0.0780 0.4673 230 | 480.0 | 350.0 | 0.00170 | 0.00990 0.02130 |
| 84 | 1852 | 1946 | 1 | 0 | 0 | 0.80 | 0.000477 | 0.00693 | 4.83 | |
| | | | | | | 0.1200 0.4690 138 | 220.0 | 140.0 | 0.00040 | 0.00200 0.00040 |
| 85 | 1854 | 1863 | 1 | 0 | 0 | 38.73 | 0.000477 | 0.33535 | 4.83 | |
| | | | | | | 0.1200 0.4799 138 | 220.0 | 140.0 | 0.02360 | 0.09760 0.02550 |
| 86 | 1863 | 1945 | 1 | 0 | 0 | 23.63 | 0.000477 | 0.20459 | 4.83 | |
| | | | | | | 0.1200 0.4748 138 | 220.0 | 140.0 | 0.01500 | 0.05890 0.05890 |
| 87 | 1866 | 1868 | 1 | 0 | 0 | 144.51 | 0.000957 | 0.45125 | 26.88 | |
| | | | | | | 0.0390 0.3937 345 | 900.0 | 700.0 | 0.00500 | 0.04780 0.72230 |
| 88 | 1866 | 1913 | 1 | 0 | 0 | 49.00 | 0.000957 | 0.15287 | 26.88 | |
| | | | | | | 0.0390 0.3939 345 | 900.0 | 700.0 | 0.00190 | 0.01790 0.27030 |
| 89 | 1867 | 1868 | 1 | 0 | 0 | 49.08 | 0.000957 | 0.15312 | 26.88 | |
| | | | | | | 0.0390 0.3929 345 | 900.0 | 700.0 | 0.00170 | 0.01620 0.24530 |
| 90 | 1867 | 1869 | 1 | 0 | 0 | 25.00 | 0.000957 | 0.07798 | 26.88 | |
| | | | | | | 0.0428 0.3904 345 | 400.0 | 400.0 | 0.00090 | 0.00820 0.12390 |
| 91 | 1907 | 1908 | 1 | 0 | 0 | 5.68 | 0.000477 | 0.04917 | 4.83 | |
| | | | | | | 0.1200 0.4660 138 | 220.0 | 140.0 | 0.00240 | 0.01390 0.00390 |
| 92 | 1907 | 1910 | 1 | 0 | 0 | 6.19 | 0.000477 | 0.05359 | 4.83 | |
| | | | | | | 0.1200 0.4676 138 | 220.0 | 140.0 | 0.00270 | 0.01520 0.00420 |

SYSTEM DATA - 7

| | | | | | | | | | | | | | |
|----|------|------|---|---|---|--------|----------|---------|-------|-------|---------|---------|---------|
| 93 | 1908 | 1909 | 1 | 0 | 0 | 0.72 | 0.000477 | 0.00623 | 4.83 | | | | |
| | | | | | | 0.1200 | 0.5026 | 138 | 220.0 | 140.0 | 0.00050 | 0.00190 | 0.00050 |
| 94 | 1913 | 1915 | 1 | 0 | 0 | 40.00 | 0.000957 | 0.12478 | 26.88 | | | | |
| | | | | | | 0.0390 | 0.3928 | 345 | 900.0 | 700.0 | 0.00160 | 0.01510 | 0.22800 |
| 95 | 1915 | 1916 | 1 | 0 | 0 | 74.02 | 0.000957 | 0.23098 | 26.88 | | | | |
| | | | | | | 0.0390 | 0.3940 | 345 | 900.0 | 700.0 | 0.00260 | 0.02450 | 0.37000 |
| 96 | 1928 | 1969 | 1 | 0 | 0 | 32.00 | 0.000477 | 0.27707 | 4.83 | | | | |
| | | | | | | 0.1200 | 0.4820 | 138 | 220.0 | 140.0 | 0.02572 | 0.10658 | 0.02790 |
| 97 | 1948 | 2495 | 1 | 0 | 0 | 11.00 | 0.000000 | 0.00000 | 0.00 | | | | |
| | | | | | | 0.1200 | 0.4935 | 138 | 220.0 | 140.0 | 0.00760 | 0.02920 | 0.00750 |
| 98 | 1964 | 1965 | 1 | 0 | 0 | 13.00 | 0.000780 | 0.13308 | 6.68 | | | | |
| | | | | | | 0.0780 | 0.4673 | 230 | 480.0 | 350.0 | 0.00200 | 0.01140 | 0.02430 |

C
C
C
C

C*****
C*****
C*****

C The following items of Transmission Line data are to be used for the
C Transmission Improvement Case.

C (a) Add the following two transmission lines.

C

| | | | | | | | | | | | | | |
|-----|------|------|---|---|---|--------|----------|---------|-------|-------|---------|---------|---------|
| 99 | 1681 | 1837 | 1 | 0 | 0 | 34.00 | 0.000477 | 0.29439 | 4.83 | | | | |
| | | | | | | 0.1014 | 0.4750 | 138 | 220.0 | 140.0 | 0.01810 | 0.08480 | 0.02250 |
| 100 | 1681 | 1901 | 1 | 0 | 0 | 51.00 | 0.000477 | 0.44162 | 4.83 | | | | |
| | | | | | | 0.1143 | 0.4724 | 138 | 220.0 | 140.0 | 0.03060 | 0.12650 | 0.31100 |

C

C (b) Increase the MW ratings of Transmission Line 12 by replacing it
C with the following.

C

| | | | | | | | | | | | | | |
|----|------|------|---|---|---|--------|----------|---------|-------|-------|---------|---------|---------|
| 12 | 1681 | 1813 | 1 | 0 | 0 | 1.84 | 0.000477 | 0.01593 | 4.83 | | | | |
| | | | | | | 0.1200 | 0.4852 | 138 | 320.0 | 280.0 | 0.00110 | 0.00470 | 0.00120 |

C

C*****
C*****
C*****

C

C

C *** Transformer Information ***

C-----

C There are two data lines for each transformer.

C Data Line 1:

C Col. 2- 3 : progressive number of transformer

C Col. 6- 9 : identification number for 1st node to which transformer
C is connected

C Col. 12-15 : identification number for 2nd node connection

C Col. 18 : identification of weather zone to which transformer belongs

C Col. 21 : week transformer maintenance begins

C Col. 24 : week transformer maintenance ends

C Col. 32-37 : probability of transformer unavailability

C Col. 43-49 : failure rate in failures per year

C Col. 54-59 : repair duration in hours per repair

C Data Line 2:

C Col. 18-24 : transformer resistance in pu

C Col. 28-34 : transformer reactance in pu

C Col. 37-43 : maximum transformer transmission rating in MW
C (short term overload)

C Col. 46-52 : transformer rated capacity in MVA

C Col. 56-61 : transformer resistance in per cent

SYSTEM DATA - 8

C Col. 64-70 : transformer reactance in per cent

| C----- | | | | | | | | | | |
|--------|------|------|---|---|---|---------|---------|--------|--------|---------------|
| C | | | | | | | | | | |
| 1 | 158 | 167 | 1 | 0 | 0 | 0.0000 | 0.00000 | 0.00 | | |
| | | | | | | 0.00300 | 0.04510 | 252.00 | 224.00 | 0.3000 4.5100 |
| 2 | 167 | 168 | 1 | 0 | 0 | 0.0000 | 0.00000 | 0.00 | | |
| | | | | | | 0.00200 | 0.03050 | 443.00 | 392.00 | 0.2000 3.0500 |
| 3 | 167 | 168 | 1 | 0 | 0 | 0.0000 | 0.00000 | 0.00 | | |
| | | | | | | 0.00100 | 0.03050 | 443.00 | 392.00 | 0.1000 3.0500 |
| 4 | 1803 | 1827 | 1 | 0 | 0 | 0.0011 | 0.05006 | 192.72 | | |
| | | | | | | 0.00030 | 0.02940 | 570.00 | 504.00 | 0.0300 2.9400 |
| 5 | 1803 | 1827 | 1 | 0 | 0 | 0.0011 | 0.05006 | 192.72 | | |
| | | | | | | 0.00030 | 0.02940 | 570.00 | 504.00 | 0.0300 2.9400 |
| 6 | 1803 | 1828 | 1 | 0 | 0 | 0.0011 | 0.05006 | 192.72 | | |
| | | | | | | 0.00030 | 0.01390 | 570.00 | 504.00 | 0.0300 1.3900 |
| 7 | 1805 | 1830 | 1 | 0 | 0 | 0.0011 | 0.05006 | 192.72 | | |
| | | | | | | 0.00190 | 0.09520 | 158.00 | 140.00 | 0.1900 9.5200 |
| 8 | 1806 | 1829 | 1 | 0 | 0 | 0.0011 | 0.05006 | 192.72 | | |
| | | | | | | 0.00090 | 0.03500 | 252.00 | 225.00 | 0.0900 3.5000 |
| 9 | 1806 | 1829 | 1 | 0 | 0 | 0.0011 | 0.05006 | 192.72 | | |
| | | | | | | 0.00090 | 0.02356 | 338.00 | 300.00 | 0.0900 2.3560 |
| 10 | 1806 | 1915 | 1 | 0 | 0 | 0.0011 | 0.05006 | 192.72 | | |
| | | | | | | 0.00040 | 0.03300 | 509.00 | 450.00 | 0.0400 3.3000 |
| 11 | 1807 | 1851 | 1 | 0 | 0 | 0.0011 | 0.05006 | 192.72 | | |
| | | | | | | 0.00090 | 0.03520 | 267.00 | 236.00 | 0.0900 3.5200 |
| 12 | 1807 | 1851 | 1 | 0 | 0 | 0.0011 | 0.05006 | 192.72 | | |
| | | | | | | 0.00090 | 0.03520 | 267.00 | 236.00 | 0.0900 3.5200 |
| 13 | 1830 | 1866 | 1 | 0 | 0 | 0.0011 | 0.05006 | 192.72 | | |
| | | | | | | 0.00029 | 0.01360 | 452.00 | 400.00 | 0.0290 1.3600 |
| 14 | 1830 | 1948 | 1 | 0 | 0 | 0.0011 | 0.05006 | 192.72 | | |
| | | | | | | 0.00240 | 0.09620 | 158.00 | 140.00 | 0.2400 9.6200 |
| 15 | 1836 | 1837 | 1 | 0 | 0 | 0.0011 | 0.05006 | 192.72 | | |
| | | | | | | 0.00090 | 0.06010 | 359.00 | 318.00 | 0.0900 6.0100 |
| 16 | 1836 | 1837 | 1 | 0 | 0 | 0.0011 | 0.05006 | 192.72 | | |
| | | | | | | 0.00050 | 0.03340 | 509.00 | 450.00 | 0.0500 3.3400 |
| 17 | 1838 | 1839 | 1 | 0 | 0 | 0.0011 | 0.05006 | 192.72 | | |
| | | | | | | 0.00090 | 0.02356 | 338.00 | 300.00 | 0.0900 2.3560 |
| 18 | 1839 | 1850 | 1 | 0 | 0 | 0.0011 | 0.05006 | 192.72 | | |
| | | | | | | 0.00040 | 0.03300 | 509.00 | 450.00 | 0.0400 3.3000 |
| 19 | 1839 | 1850 | 1 | 0 | 0 | 0.0011 | 0.05006 | 192.72 | | |
| | | | | | | 0.00100 | 0.04330 | 340.00 | 340.00 | 0.1000 4.3300 |
| 20 | 1849 | 1868 | 1 | 0 | 0 | 0.0011 | 0.05006 | 192.72 | | |
| | | | | | | 0.00041 | 0.03160 | 331.00 | 293.00 | 0.0410 3.1600 |
| 21 | 1851 | 1916 | 1 | 0 | 0 | 0.0011 | 0.05006 | 192.72 | | |
| | | | | | | 0.00240 | 0.06000 | 452.00 | 400.00 | 0.2400 6.0000 |
| 22 | 1867 | 1907 | 1 | 0 | 0 | 0.0011 | 0.05006 | 192.72 | | |
| | | | | | | 0.00050 | 0.03070 | 331.00 | 293.00 | 0.0500 3.0700 |
| 23 | 1867 | 1907 | 1 | 0 | 0 | 0.0011 | 0.05006 | 192.72 | | |
| | | | | | | 0.00050 | 0.03070 | 331.00 | 293.00 | 0.0500 3.0700 |
| 24 | 1900 | 1901 | 1 | 0 | 0 | 0.0011 | 0.05006 | 192.72 | | |
| | | | | | | 0.00100 | 0.04330 | 338.00 | 340.00 | 0.1000 4.3300 |

C
C
C*****
C*****
C*****

SYSTEM DATA - 9

C
 C The following item of Transformer data is to be used for the
 C Transmission Improvement Case.
 C Replace Transformer 15 (318 MVA) with the 450 MVA one below, which has a
 C different impedance and a higher rating (the one below being identical
 C to Transformer 16.)
 C
 C 15 1836 1837 1 0 0 0.0011 0.05006 192.72
 C 0.00050 0.03340 509.00 450.00 0.0500 3.3400

C
 C*****
 C*****
 C*****

C*** Generating Unit Information ***

C-----
 C Col. 3- 6 : identification number of node to which generator
 C is connected
 C Col. 9-10 : week generator maintenance begins
 C Col. 13-14 : week generator maintenance ends
 C Col. 16-20 : minimum generator capacity in MW
 C Col. 23-28 : maximum generator capacity in MW
 C Col. 30-35 : minimum generator reactive capability in MVAR
 C Col. 37-41 : maximum generator reactive capability in MVAR
 C Col. 44-47 : probable unavailability of generator in pu
 C Col. 50-55 : failure rate in failures per year
 C Col. 57-62 : repair duration in hours per repair
 C Col. 64-68 : cost of generation in \$/MWh
 C Col. 71-78 : name of generator
 C-----

C
 C 1. NB Power Resources
 C

| | | | | | | | | | | | |
|------|----|----|------|-------|--------|-------|------|--------|--------|------|-----------|
| 1677 | 14 | 18 | 0.0 | 100.0 | -66.0 | 66.0 | 0.10 | 9.733 | 100.00 | 65.0 | ST.ROSE1 |
| 1800 | 0 | 0 | 5.0 | 120.0 | -80.0 | 38.0 | 0.00 | 0.000 | 0.00 | 35.0 | BEECHWOOD |
| 1802 | 0 | 0 | 20.0 | 30.0 | -35.0 | 15.5 | 0.00 | 0.000 | 0.00 | 33.0 | GR.FALL1 |
| 1809 | 0 | 0 | 0.0 | 660.0 | -610.0 | 316.0 | 0.00 | 0.000 | 0.00 | 35.5 | MACTAQC |
| 1807 | 0 | 0 | 0.0 | 20.0 | -28.2 | 18.0 | 0.12 | 29.864 | 40.00 | 50.0 | CHATMCFB |
| 1811 | 15 | 18 | 0.0 | 60.0 | -56.9 | 51.7 | 0.12 | 29.864 | 40.00 | 40.0 | GRLAKE08 |
| 1811 | 31 | 34 | 0.0 | 170.0 | -100.0 | 80.0 | 0.12 | 29.864 | 40.00 | 30.0 | GRLAKE09 |
| 1812 | 0 | 0 | 0.0 | 25.0 | -12.0 | 18.0 | 0.10 | 9.733 | 100.00 | 75.0 | MONCTNGT |
| 1813 | 10 | 15 | 0.0 | 44.5 | -18.0 | 31.5 | 0.10 | 24.333 | 40.00 | 45.0 | CT.BAY01 |
| 1813 | 0 | 0 | 10.0 | 12.3 | -7.7 | 8.3 | 0.10 | 24.333 | 40.00 | 25.0 | CT.BAY02 |
| 1813 | 19 | 24 | 0.0 | 100.0 | -66.0 | 66.0 | 0.10 | 24.333 | 40.00 | 34.0 | CT.BAY03 |
| 1813 | 25 | 30 | 0.0 | 97.0 | -66.0 | 66.0 | 0.10 | 24.333 | 40.00 | 40.0 | CT.BAY04 |
| 1813 | 0 | 0 | 0.0 | 10.0 | -5.0 | 5.0 | 0.00 | 0.000 | 0.00 | 80.0 | INTLOAD1 |
| 1826 | 14 | 18 | 0.0 | 103.0 | -66.0 | 66.0 | 0.10 | 24.333 | 40.00 | 37.0 | DALHOU01 |
| 1826 | 23 | 27 | 0.0 | 203.0 | -130.0 | 100.0 | 0.12 | 29.864 | 40.00 | 30.0 | DALHOU02 |
| 1836 | 23 | 29 | 0.0 | 335.0 | -125.0 | 160.0 | 0.10 | 24.333 | 40.00 | 37.0 | C.COVE01 |
| 1836 | 30 | 36 | 0.0 | 335.0 | -125.0 | 160.0 | 0.10 | 24.333 | 40.00 | 32.0 | C.COVE02 |
| 1836 | 37 | 43 | 0.0 | 335.0 | -125.0 | 160.0 | 0.10 | 24.333 | 40.00 | 34.0 | C.COVE03 |
| 1843 | 19 | 22 | 0.0 | 657.0 | -450.0 | 415.0 | 0.12 | 11.946 | 100.00 | 5.0 | LEPRAU01 |
| 1847 | 0 | 0 | 0.0 | 12.0 | -6.0 | 6.0 | 0.00 | 0.000 | 0.00 | 80.0 | INTLOAD2 |
| 1910 | 0 | 0 | 0.0 | 40.0 | -40.0 | 20.0 | 0.00 | 0.000 | 0.00 | 0.0 | GF.TOB.6 |
| 1910 | 0 | 0 | 0.0 | 15.0 | -7.0 | 7.0 | 0.00 | 0.000 | 0.00 | 80.0 | INTLOAD3 |
| 1913 | 27 | 30 | 0.0 | 450.0 | -250.0 | 220.0 | 0.12 | 29.864 | 40.00 | 28.0 | BELDUN01 |
| 1948 | 0 | 0 | 0.0 | 15.0 | -7.0 | 7.0 | 0.00 | 0.000 | 0.00 | 80.0 | INTLOAD4 |
| 1965 | 19 | 23 | 0.0 | 100.0 | -66.0 | 66.0 | 0.10 | 9.733 | 100.00 | 65.0 | MILBNK01 |
| 1965 | 24 | 28 | 0.0 | 100.0 | -66.0 | 66.0 | 0.10 | 9.733 | 100.00 | 65.0 | MILBNK02 |
| 1969 | 29 | 33 | 0.0 | 100.0 | -66.0 | 66.0 | 0.10 | 9.733 | 100.00 | 65.0 | MILBNK03 |
| 1969 | 34 | 38 | 0.0 | 100.0 | -66.0 | 66.0 | 0.10 | 9.733 | 100.00 | 65.0 | MILBNK04 |

SYSTEM DATA - 10

1971 0 0 0.0 25.0 -12.0 18.0 0.10 9.733 100.00 75.0 GRMANAGT

C

C

C Three of the NB Power Resources listed above are hydro generating stations.

C It is necessary to give the value of available energy for each of these

C stations.

C

C Col. 3-6 : identification number of node to which generator

C is connected (as above)

C Col. 9-12: energy limit of hydro-generators in GWH per year

C Col.16-23: name of generator.

C

1800 478 BEECHWOOD

1802 210 GR.FALL1

1809 1609 MACTAQUC

C

C 2. Inter-change System Supporting Resources

C

| | | | | | | | | | | | |
|------|---|---|-----|-------|--------|-------|------|--------|-------|-------|----------|
| 168 | 0 | 0 | 0.0 | 150.0 | -25.0 | 40.0 | 0.10 | 24.333 | 40.00 | 90.0 | NS.SYS01 |
| 168 | 0 | 0 | 0.0 | 150.0 | -25.0 | 40.0 | 0.10 | 24.333 | 40.00 | 90.0 | NS.SYS02 |
| 168 | 0 | 0 | 0.0 | 119.0 | -100.0 | 100.0 | 0.00 | 0.000 | 0.00 | 0.0 | NS.SYS04 |
| 700 | 0 | 0 | 0.0 | 250.0 | -75.0 | 75.0 | 0.10 | 24.333 | 40.00 | 100.0 | NE.SYS01 |
| 700 | 0 | 0 | 0.0 | 250.0 | -75.0 | 75.0 | 0.10 | 24.333 | 40.00 | 100.0 | NE.SYS02 |
| 1844 | 0 | 0 | 0.0 | 10.0 | 0.0 | 20.0 | 0.10 | 24.333 | 40.00 | 100.0 | PE.SYS01 |
| 1869 | 0 | 0 | 0.0 | 300.0 | -50.0 | 100.0 | 0.05 | 11.526 | 40.00 | 120.0 | HQ.SYS01 |
| 1896 | 0 | 0 | 0.0 | 10.0 | -5.0 | 5.0 | 0.10 | 24.333 | 40.00 | 100.0 | MP.SYS01 |
| 9996 | 0 | 0 | 0.0 | 100.0 | -50.0 | 50.0 | 0.05 | 11.526 | 40.00 | 120.0 | HQ.SYS02 |
| 9997 | 0 | 0 | 0.0 | 0.0 | -125.0 | 425.0 | 0.00 | 0.000 | 0.00 | 0.0 | CHES.SVC |

C

C

C

C*** Typical Grouping of Weeks into Monthly Periods

C

| Jan | Feb | Mar | Apr | May | June | July | Aug | Sept | Oct | Nov | Dec |
|-----|-----|-----|-----|-----|------|------|-----|------|-----|-----|-----|
| 5 | 4 | 4 | 4 | 5 | 4 | 5 | 4 | 4 | 5 | 4 | 4 |

C

C

C

C

C*** Load Model Information ***

C Three kinds of Load Models are given in this section.

C The load diagrams given in sub-section I are 6 step load duration

C curves for 4 different types of load for each month. They provide

C a reasonably detailed load model for evaluation. Alternatively

C a more simplified model is presented in sub-section II. It is a

C fixed 5 load-level probability distribution of loads for three seasons.

C Subsection III provides a generic chronological weekly load shape

C which can be applied to the actual load data of Model I to produce

C detailed chronological load models for each month of each load type.

C The building of these chronological models is left to the user.

C

C I. Monthly Load Diagrams

C

C First Line : Period in hours for a typical week.

C Line 2-13 : Monthly Load in per unit of annual peak for each period.

C

C

C TYPE 1 (100% variable loads)

C

SYSTEM DATA - 11

| | 0-10 | 10-49 | 49-83 | 83-117 | 117-151 | 151-168 |
|------|-------|-------|-------|--------|---------|---------|
| Jan. | 1.000 | 0.850 | 0.730 | 0.580 | 0.450 | 0.300 |
| Feb. | 0.930 | 0.850 | 0.730 | 0.580 | 0.450 | 0.300 |
| Mar. | 0.885 | 0.770 | 0.650 | 0.510 | 0.400 | 0.260 |
| Apr. | 0.745 | 0.660 | 0.560 | 0.450 | 0.341 | 0.227 |
| May | 0.660 | 0.561 | 0.476 | 0.383 | 0.290 | 0.193 |
| June | 0.570 | 0.520 | 0.460 | 0.350 | 0.260 | 0.173 |
| July | 0.510 | 0.452 | 0.384 | 0.305 | 0.236 | 0.158 |
| Aug. | 0.540 | 0.470 | 0.420 | 0.330 | 0.250 | 0.165 |
| Sep. | 0.570 | 0.520 | 0.460 | 0.350 | 0.260 | 0.173 |
| Oct. | 0.665 | 0.590 | 0.500 | 0.383 | 0.290 | 0.193 |
| Nov. | 0.760 | 0.680 | 0.612 | 0.486 | 0.378 | 0.251 |
| Dec. | 0.890 | 0.780 | 0.673 | 0.534 | 0.415 | 0.276 |

C

C

C TYPE 2 (mixed variable & base loads)

C

| | 0-10 | 10-49 | 49-83 | 83-117 | 117-151 | 151-168 |
|------|-------|-------|-------|--------|---------|---------|
| Jan. | 1.000 | 0.910 | 0.867 | 0.802 | 0.727 | 0.660 |
| Feb. | 0.930 | 0.910 | 0.867 | 0.802 | 0.727 | 0.660 |
| Mar. | 0.885 | 0.830 | 0.770 | 0.710 | 0.650 | 0.590 |
| Apr. | 0.745 | 0.700 | 0.656 | 0.607 | 0.550 | 0.500 |
| May | 0.660 | 0.595 | 0.558 | 0.516 | 0.468 | 0.425 |
| June | 0.570 | 0.540 | 0.500 | 0.463 | 0.420 | 0.381 |
| July | 0.510 | 0.483 | 0.456 | 0.421 | 0.382 | 0.347 |
| Aug. | 0.540 | 0.500 | 0.456 | 0.421 | 0.382 | 0.347 |
| Sep. | 0.570 | 0.540 | 0.500 | 0.463 | 0.420 | 0.381 |
| Oct. | 0.660 | 0.620 | 0.570 | 0.516 | 0.468 | 0.425 |
| Nov. | 0.760 | 0.720 | 0.690 | 0.650 | 0.610 | 0.553 |
| Dec. | 0.890 | 0.848 | 0.799 | 0.739 | 0.670 | 0.608 |

C

C

C TYPE 3 (base loads)

C

| | 0-10 | 10-49 | 49-83 | 83-117 | 117-151 | 151-168 |
|------|-------|-------|-------|--------|---------|---------|
| Jan. | 1.000 | 1.000 | 1.000 | 1.000 | 1.000 | 1.000 |
| Feb. | 1.000 | 1.000 | 1.000 | 1.000 | 1.000 | 1.000 |
| Mar. | 1.000 | 1.000 | 1.000 | 1.000 | 1.000 | 1.000 |
| Apr. | 1.000 | 1.000 | 1.000 | 1.000 | 1.000 | 1.000 |
| May | 1.000 | 1.000 | 1.000 | 1.000 | 1.000 | 1.000 |
| June | 1.000 | 1.000 | 1.000 | 1.000 | 1.000 | 1.000 |
| July | 1.000 | 1.000 | 1.000 | 1.000 | 1.000 | 1.000 |
| Aug. | 1.000 | 1.000 | 1.000 | 1.000 | 1.000 | 1.000 |
| Sep. | 1.000 | 1.000 | 1.000 | 1.000 | 1.000 | 1.000 |
| Oct. | 1.000 | 1.000 | 1.000 | 1.000 | 1.000 | 1.000 |
| Nov. | 1.000 | 1.000 | 1.000 | 1.000 | 1.000 | 1.000 |
| Dec. | 1.000 | 1.000 | 1.000 | 1.000 | 1.000 | 1.000 |

C

C

C TYPE 4 (HQ contract)

C

| | 0-10 | 10-49 | 49-83 | 83-117 | 117-151 | 151-168 |
|------|-------|-------|-------|--------|---------|---------|
| Jan. | 1.000 | 0.850 | 0.400 | 0.000 | 0.000 | 0.000 |
| Feb. | 1.000 | 0.850 | 0.400 | 0.000 | 0.000 | 0.000 |
| Mar. | 0.000 | 0.000 | 0.000 | 0.000 | 0.000 | 0.000 |
| Apr. | 0.000 | 0.000 | 0.000 | 0.000 | 0.000 | 0.000 |
| May | 0.000 | 0.000 | 0.000 | 0.000 | 0.000 | 0.000 |
| June | 0.000 | 0.000 | 0.000 | 0.000 | 0.000 | 0.000 |
| July | 0.000 | 0.000 | 0.000 | 0.000 | 0.000 | 0.000 |
| Aug. | 0.000 | 0.000 | 0.000 | 0.000 | 0.000 | 0.000 |

SYSTEM DATA - 13

C Two different hydro models are provided in this section. Hydro Model I
C is consistent with Load Model I while Hydro Model II is consistent with Load
C Model II.

C

C-----

C

C I. Prescheduled peak shaving load adjustment model by month.

C

C First Line : Period in hours for a typical week.

C Lines 2-13 : Monthly Modeling Diagrams.

C Scheduled hydro generation in per unit of the rated
C capacity for the station.

C-----

C

C 1. Beechwood Hydro Station

C

| | 0-10 | 10-49 | 49-83 | 83-117 | 117-151 | 151-168 |
|------|---------|---------|---------|---------|---------|---------|
| Jan. | 0.66667 | 0.52940 | 0.32350 | 0.05880 | 0.02940 | 0.02940 |
| Feb. | 0.67650 | 0.47060 | 0.41180 | 0.05880 | 0.02940 | 0.02940 |
| Mar. | 0.81180 | 0.50000 | 0.41180 | 0.08820 | 0.02940 | 0.02940 |
| Apr. | 1.00000 | 0.94120 | 0.79410 | 0.70590 | 0.52940 | 0.35290 |
| May | 1.00000 | 1.00000 | 1.00000 | 0.85290 | 0.64710 | 0.52940 |
| June | 0.82350 | 0.64710 | 0.58820 | 0.41180 | 0.20590 | 0.02940 |
| July | 0.64710 | 0.54710 | 0.41180 | 0.17650 | 0.02940 | 0.02940 |
| Aug. | 0.61760 | 0.50000 | 0.38230 | 0.17650 | 0.02940 | 0.02940 |
| Sep. | 0.70590 | 0.52940 | 0.29410 | 0.11760 | 0.02940 | 0.02940 |
| Oct. | 0.70590 | 0.52940 | 0.47060 | 0.35290 | 0.02940 | 0.02940 |
| Nov. | 0.79410 | 0.67650 | 0.50000 | 0.29410 | 0.08820 | 0.02940 |
| Dec. | 0.85290 | 0.76470 | 0.41180 | 0.29410 | 0.02940 | 0.02940 |

C

C

C 2. Grand Falls 138 Hydro Station

C

| | 0-10 | 10-49 | 49-83 | 83-117 | 117-151 | 151-168 |
|------|---------|---------|---------|---------|---------|---------|
| Jan. | 1.00000 | 1.00000 | 1.00000 | 0.66667 | 0.33333 | 0.33333 |
| Feb. | 1.00000 | 1.00000 | 1.00000 | 1.00000 | 0.33333 | 0.33333 |
| Mar. | 1.00000 | 1.00000 | 1.00000 | 1.00000 | 0.33333 | 0.33333 |
| Apr. | 1.00000 | 1.00000 | 1.00000 | 1.00000 | 1.00000 | 1.00000 |
| May | 1.00000 | 1.00000 | 1.00000 | 1.00000 | 1.00000 | 1.00000 |
| June | 1.00000 | 1.00000 | 1.00000 | 1.00000 | 1.00000 | 0.83333 |
| July | 1.00000 | 1.00000 | 1.00000 | 1.00000 | 0.83333 | 0.33333 |
| Aug. | 1.00000 | 1.00000 | 1.00000 | 1.00000 | 0.33333 | 0.16666 |
| Sep. | 1.00000 | 1.00000 | 1.00000 | 1.00000 | 0.83333 | 0.50000 |
| Oct. | 1.00000 | 1.00000 | 1.00000 | 1.00000 | 1.00000 | 0.33333 |
| Nov. | 1.00000 | 1.00000 | 1.00000 | 1.00000 | 1.00000 | 0.50000 |
| Dec. | 1.00000 | 1.00000 | 1.00000 | 1.00000 | 0.66667 | 0.33333 |

C

C

C 3. Mactaquac Hydro Station

C

| | 0-10 | 10-49 | 49-83 | 83-117 | 117-151 | 151-168 |
|------|---------|---------|---------|---------|---------|---------|
| Jan. | 0.75760 | 0.46970 | 0.16670 | 0.00000 | 0.00000 | 0.00000 |
| Feb. | 0.60610 | 0.32580 | 0.21210 | 0.02270 | 0.00000 | 0.00000 |
| Mar. | 0.72730 | 0.45610 | 0.21210 | 0.03790 | 0.00000 | 0.00000 |
| Apr. | 1.00000 | 0.84090 | 0.68180 | 0.50760 | 0.32580 | 0.11360 |
| May | 1.00000 | 1.00000 | 1.00000 | 0.76520 | 0.49240 | 0.30300 |
| June | 0.76520 | 0.62120 | 0.46970 | 0.28790 | 0.05030 | 0.00000 |
| July | 0.60610 | 0.43940 | 0.32270 | 0.14390 | 0.00000 | 0.00000 |
| Aug. | 0.50450 | 0.38180 | 0.28030 | 0.13640 | 0.00000 | 0.00000 |
| Sep. | 0.52270 | 0.37880 | 0.27270 | 0.11360 | 0.00000 | 0.00000 |

SYSTEM DATA - 14

Oct. 0.65910 0.44700 0.35610 0.18940 0.00000 0.00000
 Nov. 0.74240 0.54550 0.41670 0.26520 0.00000 0.00000
 Dec. 0.90910 0.56820 0.32580 0.08330 0.00000 0.00000

C
 C
 C

C 11. Seasonal Thermal-Equivalent Hydro Model

C

C Col. 1- 6 : Hydro Plant Name.
 C Col. 9-12 : Node location identification number.
 C Col. 13-20 : Annual energy production in GWh.
 C Col. 21-26 : Summer energy in per unit of annual total.
 C Col. 27-32 : Intermediate energy in per unit of annual total.
 C Col. 33-38 : Winter energy in per unit of annual total.
 C Col. 39-44 : Maximum equivalent thermal cost for dispatch.
 C Col. 45-50 : Summer cost in per unit of maximum cost.
 C Col. 51-56 : Intermediate cost in per unit of maximum cost.
 C Col. 57-62 : Winter cost in per unit of maximum cost.

C

C

| | | | | | | | | | |
|--------|------|------|------|------|------|------|-----|-----|-----|
| BEECHW | 1800 | 478 | .313 | .449 | .238 | 35.0 | .87 | .87 | .99 |
| GRFALL | 1802 | 210 | .358 | .354 | .288 | 33.0 | .87 | .87 | .99 |
| MACTQC | 1809 | 1609 | .264 | .345 | .391 | 35.5 | .87 | .87 | .99 |

C

C

C

C

C*** Common Mode Pairs of Lines ***

C

 C Col. 4-12 : nodes making up first line subject to common mode failure
 C Col. 19-27 : nodes making up second line subject to common mode failure
 C Col. 35-44 : probability of one line being out of service
 C Col. 55-64 : probability of both lines being out of service

C

C

| | | | |
|-----------|-----------|------------|------------|
| 1681-1717 | 1717-1747 | 0.00000000 | 0.00024327 |
| 1776-1839 | 1776-1901 | 0.00000000 | 0.00031959 |
| 1805-1824 | 1806-1824 | 0.00000000 | 0.00041022 |
| 1807-1832 | 1811-1832 | 0.00000000 | 0.00055332 |
| 1712-1807 | 1712-1812 | 0.00000000 | 0.00079659 |
| 1800-1930 | 1827-1930 | 0.00000000 | 0.00042453 |
| 1809-1861 | 1810-1861 | 0.00000000 | 0.00014072 |
| 1825-1852 | 1852-1946 | 0.00000000 | 0.00022514 |
| 1844-1854 | 1854-1863 | 0.00000000 | 0.00023850 |
| 1800-1817 | 1802-1817 | 0.00000000 | 0.00031005 |
| 1806-1928 | 1677-1928 | 0.00000000 | 0.00047462 |
| 1802-1804 | 1804-1849 | 0.00000000 | 0.00006678 |
| 1839-1945 | 1863-1945 | 0.00000000 | 0.00022514 |
| 1800-1847 | 1827-1847 | 0.00000000 | 0.00042220 |
| 1829-1964 | 1851-1964 | 0.00000000 | 0.00060220 |

C

C

C

C

C

C

C

C

C

C

C

SYSTEM DATA - 15

C
C
C
C*** Weather Condition Modelling Information ***
C-----
C Number of geographic zones = 1
C
C Number of weather seasons = 2
C Winter : December - March, 4 months
C Non-winter : April - November, 8 months
C
C Duration of adverse weather
C winter : 15%
C non-winter : 5%
C
C Percentage of outages occurring in adverse weather = 90%
C for both seasons
C
C Forced outage rates (FOR) applicable for different weather.
C adverse weather = 5.4 * annual average FOR as specified in
C Transmission data.
C normal weather = 0.6 * annual average FOR as specified in
C Transmission data.
C-----

APPENDIX II
MONTHLY LOAD DURATION CURVE DATA

NB Power - CIGRE Reliability Test System Load Duration Curves

| | Jan. | Feb. | Mar. | Apr. | May | Jun. | Jul. | Aug. | Sep. | Oct. | Nov. | Dec. |
|------------------------|-------------|-------------|-------------|-------------|-------------|-------------|-------------|-------------|-------------|-------------|-------------|-------------|
| 0 | 100.00 | 100.00 | 100.00 | 100.00 | 100.00 | 100.00 | 100.00 | 100.00 | 100.00 | 100.00 | 100.00 | 100.00 |
| 2 | 94.09 | 93.85 | 95.30 | 95.46 | 97.50 | 97.76 | 95.19 | 93.82 | 94.25 | 93.81 | 94.01 | 94.99 |
| 4 | 92.52 | 92.19 | 93.32 | 93.09 | 94.71 | 95.34 | 93.79 | 92.79 | 93.19 | 92.32 | 92.59 | 93.39 |
| 6 | 91.43 | 91.46 | 92.03 | 91.87 | 92.46 | 94.05 | 92.93 | 91.73 | 92.29 | 90.79 | 91.39 | 92.03 |
| 8 | 90.19 | 90.44 | 90.69 | 90.37 | 91.04 | 92.87 | 91.99 | 90.99 | 91.57 | 89.99 | 90.79 | 91.14 |
| 10 | 89.29 | 89.39 | 89.45 | 89.59 | 90.39 | 91.89 | 91.25 | 90.49 | 90.29 | 89.19 | 89.89 | 90.09 |
| 12 | 88.06 | 88.56 | 88.39 | 88.79 | 89.59 | 91.29 | 90.39 | 89.76 | 89.49 | 88.69 | 89.25 | 88.96 |
| 14 | 87.49 | 87.39 | 87.47 | 88.19 | 88.69 | 90.81 | 89.89 | 89.29 | 88.89 | 87.97 | 88.69 | 88.07 |
| 16 | 86.38 | 86.79 | 86.77 | 87.59 | 87.98 | 90.19 | 89.29 | 88.69 | 88.29 | 87.09 | 88.19 | 87.38 |
| 18 | 85.39 | 85.89 | 86.29 | 86.87 | 87.19 | 89.43 | 88.79 | 88.29 | 87.89 | 86.69 | 87.69 | 86.49 |
| 20 | 84.40 | 85.39 | 85.69 | 85.89 | 86.39 | 88.79 | 88.21 | 87.89 | 87.49 | 85.99 | 87.29 | 85.81 |
| 22 | 83.42 | 84.78 | 84.92 | 85.49 | 85.72 | 88.19 | 87.32 | 87.32 | 86.99 | 85.42 | 86.69 | 85.12 |
| 24 | 82.68 | 84.26 | 84.18 | 85.09 | 85.23 | 87.69 | 86.83 | 86.59 | 86.61 | 84.88 | 86.29 | 84.43 |
| 26 | 82.18 | 83.78 | 83.54 | 84.58 | 84.68 | 87.17 | 86.34 | 86.09 | 86.19 | 84.54 | 85.87 | 83.58 |
| 28 | 81.65 | 83.28 | 82.72 | 84.18 | 84.08 | 86.59 | 85.79 | 85.55 | 85.79 | 83.98 | 85.49 | 83.15 |
| 30 | 80.78 | 82.68 | 81.98 | 83.58 | 83.18 | 85.99 | 84.98 | 85.09 | 84.88 | 83.69 | 84.98 | 82.38 |
| 32 | 80.17 | 82.08 | 81.27 | 82.98 | 82.58 | 85.45 | 84.48 | 84.68 | 84.58 | 83.18 | 84.74 | 81.77 |
| 34 | 79.18 | 81.58 | 80.48 | 82.60 | 82.18 | 84.68 | 83.98 | 84.18 | 83.88 | 82.88 | 84.40 | 81.28 |
| 36 | 78.48 | 80.98 | 79.68 | 82.28 | 81.48 | 84.16 | 83.50 | 83.88 | 83.18 | 82.58 | 83.98 | 80.88 |
| 38 | 77.91 | 80.58 | 79.08 | 81.82 | 81.18 | 83.38 | 82.88 | 83.28 | 82.88 | 82.08 | 83.62 | 80.04 |
| 40 | 77.48 | 80.10 | 78.58 | 81.48 | 80.68 | 82.68 | 82.52 | 82.78 | 81.98 | 81.68 | 83.18 | 79.48 |
| 42 | 76.98 | 79.76 | 78.08 | 80.74 | 80.38 | 81.64 | 81.88 | 82.13 | 81.48 | 81.08 | 82.78 | 78.68 |
| 44 | 76.48 | 79.38 | 77.38 | 80.38 | 79.78 | 80.98 | 81.38 | 81.58 | 80.80 | 80.74 | 82.18 | 78.08 |
| 46 | 75.85 | 78.88 | 76.78 | 79.76 | 79.36 | 80.26 | 80.56 | 81.03 | 80.26 | 80.28 | 81.78 | 77.35 |
| 48 | 75.28 | 78.68 | 76.28 | 79.28 | 78.87 | 79.78 | 79.57 | 80.58 | 79.28 | 79.97 | 81.22 | 76.78 |
| 50 | 74.47 | 78.08 | 75.48 | 78.78 | 77.98 | 78.88 | 79.08 | 79.68 | 78.68 | 79.28 | 80.58 | 75.88 |
| 52 | 73.99 | 77.73 | 74.67 | 78.18 | 77.38 | 78.38 | 78.08 | 78.99 | 77.68 | 78.98 | 80.14 | 75.00 |
| 54 | 73.37 | 76.99 | 74.37 | 77.58 | 76.68 | 77.38 | 77.10 | 78.58 | 76.78 | 78.08 | 79.40 | 74.27 |
| 56 | 72.71 | 76.38 | 73.61 | 77.08 | 76.01 | 76.26 | 76.28 | 77.68 | 76.18 | 77.41 | 78.88 | 73.27 |
| 58 | 71.92 | 75.70 | 73.17 | 76.48 | 75.02 | 75.52 | 75.32 | 76.98 | 75.32 | 76.62 | 77.98 | 72.57 |
| 60 | 71.09 | 75.16 | 72.43 | 75.88 | 74.13 | 75.18 | 74.47 | 75.88 | 74.17 | 75.94 | 77.28 | 71.99 |
| 62 | 70.44 | 74.41 | 71.87 | 74.77 | 72.72 | 74.27 | 73.62 | 75.35 | 73.37 | 75.08 | 76.38 | 71.12 |
| 64 | 69.32 | 74.07 | 71.47 | 74.09 | 71.46 | 73.39 | 72.47 | 74.26 | 72.19 | 74.16 | 75.50 | 70.65 |
| 66 | 68.56 | 73.42 | 70.77 | 73.47 | 70.07 | 71.87 | 70.17 | 72.57 | 71.27 | 72.87 | 74.15 | 69.87 |
| 68 | 67.58 | 72.88 | 70.28 | 72.61 | 69.07 | 70.81 | 68.09 | 70.48 | 70.11 | 71.78 | 73.37 | 68.88 |
| 70 | 66.87 | 72.19 | 69.67 | 71.57 | 68.27 | 69.37 | 66.77 | 69.13 | 69.27 | 70.79 | 72.07 | 68.17 |
| 72 | 65.50 | 71.67 | 69.23 | 70.49 | 66.90 | 67.83 | 65.50 | 68.13 | 68.13 | 69.50 | 71.07 | 67.67 |
| 74 | 64.61 | 71.27 | 68.31 | 69.79 | 65.80 | 66.77 | 64.75 | 67.37 | 67.17 | 68.27 | 70.49 | 66.91 |
| 76 | 63.92 | 70.87 | 67.67 | 69.07 | 64.76 | 66.05 | 63.32 | 66.57 | 66.35 | 67.22 | 69.57 | 65.97 |
| 78 | 62.53 | 70.15 | 66.93 | 68.37 | 63.43 | 65.31 | 62.26 | 65.97 | 65.81 | 66.57 | 68.65 | 65.47 |
| 80 | 61.66 | 69.27 | 66.35 | 67.87 | 62.74 | 64.66 | 61.66 | 65.25 | 65.17 | 65.47 | 67.67 | 64.84 |
| 82 | 60.85 | 68.67 | 65.67 | 67.33 | 61.25 | 64.16 | 61.16 | 64.76 | 64.22 | 65.07 | 66.73 | 63.36 |
| 84 | 59.76 | 68.27 | 65.07 | 66.87 | 60.16 | 63.00 | 60.66 | 64.36 | 63.48 | 64.66 | 65.99 | 62.76 |
| 86 | 59.18 | 67.68 | 64.38 | 66.27 | 59.38 | 62.36 | 60.16 | 63.96 | 62.96 | 63.88 | 65.45 | 61.36 |
| 88 | 58.19 | 66.93 | 63.22 | 65.77 | 58.96 | 61.26 | 59.69 | 63.46 | 62.40 | 63.36 | 64.76 | 60.02 |
| 90 | 57.00 | 65.69 | 62.00 | 65.27 | 57.96 | 60.26 | 59.10 | 62.96 | 61.26 | 62.64 | 64.16 | 58.56 |
| 92 | 56.01 | 65.07 | 60.76 | 64.62 | 56.86 | 59.86 | 58.51 | 62.51 | 59.98 | 61.86 | 63.12 | 56.41 |
| 94 | 54.27 | 63.40 | 59.56 | 63.98 | 55.76 | 59.08 | 57.62 | 62.03 | 58.98 | 60.49 | 62.28 | 54.42 |
| 96 | 49.88 | 61.85 | 55.99 | 62.18 | 55.06 | 57.34 | 56.93 | 60.86 | 57.04 | 59.54 | 61.26 | 52.85 |
| 98 | 47.12 | 59.90 | 52.84 | 59.80 | 54.14 | 55.64 | 53.14 | 58.98 | 51.39 | 57.83 | 60.48 | 51.52 |
| 100 | 39.34 | 56.16 | 43.74 | 55.26 | 52.45 | 51.15 | 48.05 | 41.44 | 40.94 | 54.85 | 55.46 | 47.05 |
| Peak Load in MW | 3156 | 2960 | 2887 | 2432 | 2209 | 1942 | 1767 | 1854 | 1962 | 2199 | 2550 | 2913 |

APPENDIX III

BASE CASE LOAD FLOW RESULTS

OUTPUT FOR AREA 1 {N.B. POW}

| FROM BUS | | AREA | | BUS DATA | | GEN | | LOAD | | SHUNT | | TO BUS | | LINE DATA | | TRANSFORMER | | RATING A | |
|---------------|------|-------|-------|----------|---------|---------|---------|---------|---------|---------|---------------|--------|----------|-----------|--------|-------------|---------|----------|-----|
| NAME | ZONE | PU/KV | ANGLE | MM/MVAR | MM/MVAR | MM/MVAR | MM/MVAR | MM/MVAR | MM/MVAR | MM/MVAR | MM/MVAR | NAME | CKT AREA | MW | MVAR | RATIO | ANGLE | % | MVA |
| 1677 CARAQT | 138 | 1 | 1.020 | -9.6 | 100.0 | 135.7 | 0.0 | 0.0 | 0.0 | 0.0 | 1806 BATHST | 8 | 138 | 1 | -30.9 | -14.6 | 24 | 140 | |
| 1679 LANCST | 4 | 138 | 1 | 1.005 | 1.2 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 1828 110694 | 138 | 99 | 1 | -4.8 | -1.3 | 3 | 140 | |
| 1681 IRVREF | 4 | 138 | 1 | 0.993 | -2.6 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 1837 C.COVE | 4 | 138 | 1 | -101.5 | -42.0 | 57 | 190 | |
| 1712 111856EQ | 138 | 5 | 0.939 | -18.4 | 0.0 | 149.2 | 0.0 | 0.0 | 0.0 | 0.0 | 1717 LAKEWDEQ | 138 | 99 | 1 | 96.7 | 7.0 | 51 | 190 | |
| 1717 LAKEWDEQ | 138 | 4 | 0.978 | -6.0 | 0.0 | 31.0 | 0.0 | 0.0 | 0.0 | 0.0 | 1813 C. BAY | 4 | 138 | 1 | -129.6 | -15.3 | 94 | 140 | |
| 1747 PHSFLO | 138 | 4 | 1.016 | -4.4 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 1807 NEMCST | 138 | 99 | 1 | -83.5 | -14.6 | 65 | 140 | |
| 1776 1149-EQL | 138 | 4 | 1.027 | -5.3 | 0.0 | 46.2 | 0.0 | 0.0 | 0.0 | 0.0 | 1812 MONCTN | 5 | 138 | 99 | 1 | -65.7 | -16.4 | 51 | 140 |
| 1800 BEECHW | 138 | 1 | 1.033 | -0.4 | 0.0 | 13.5 | 0.0 | 0.0 | 0.0 | 0.0 | 1681 IRVREF | 4 | 138 | 99 | 1 | -95.4 | -1.3 | 51 | 190 |
| 1802 GRFALL | 138 | 1 | 1.039 | -4.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 1747 PHSFLO | 138 | 99 | 1 | -33.8 | -30.1 | 24 | 190 | |
| 1803 KESWIC | 2 | 345 | 1 | 1.031 | 2.5 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 1717 LAKEWDEQ | 138 | 99 | 1 | 34.3 | 32.2 | 24 | 190 | |
| 1804 117562 | 138 | 1 | 1.039 | -4.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 1901 NORTN1 | 138 | 1 | 1 | -34.3 | -32.2 | 24 | 190 | |
| 1805 EELRVR | 9 | 138 | 1 | 1.038 | -4.1 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 1839 SALBRY | 5 | 138 | 99 | 1 | 43.4 | -19.9 | 33 | 140 |
| | | | | | | | | | | | 1901 NORTN1 | 138 | 99 | 1 | -89.6 | 6.4 | 62 | 140 | |
| | | | | | | | | | | | 1817 111144 | 1 | 138 | 1 | 40.6 | -15.1 | 30 | 140 | |
| | | | | | | | | | | | 1847 112572 | 1 | 138 | 1 | -12.7 | 7.6 | 10 | 140 | |
| | | | | | | | | | | | 1890 BEEG12 | 113.8 | 1 | 1 | -40.0 | -18.1 | 0.971UN | | |
| | | | | | | | | | | | 1891 BEEG3 | 113.8 | 1 | 1 | -40.0 | -9.0 | 0.971UN | | |
| | | | | | | | | | | | 1896 TINKER61 | 138 | 99 | 6 | 7.0 | -2.5 | 5 | 140 | |
| | | | | | | | | | | | 1930 1126WP | 138 | 1 | 1 | 5.9 | 17.1 | 13 | 140 | |
| | | | | | | | | | | | 1804 117562 | 138 | 1 | 1 | 76.9 | -10.7 | 39 | 190 | |
| | | | | | | | | | | | 1817 111144 | 1 | 138 | 1 | -46.9 | 15.8 | 34 | 140 | |
| | | | | | | | | | | | 1888 GR.FGH | 16.60 | 1 | 1 | -30.0 | -5.1 | 0.970UN | | |
| | | | | | | | | | | | 1827 KESWIC | 2 | 138 | 1 | -30.3 | 13.4 | 0.993RG | 6 | 504 |
| | | | | | | | | | | | 1827 KESWIC | 2 | 138 | 2 | -30.3 | 13.4 | 0.993RG | 6 | 504 |
| | | | | | | | | | | | 1828 KESWIC | 2 | 230 | 1 | 207.4 | -24.3 | 1.000RG | 40 | 504 |
| | | | | | | | | | | | 1836 C.COVE | 4 | 345 | 1 | -255.5 | 13.4 | 35 | 700 | |
| | | | | | | | | | | | 1843 LEPRAU | 345 | 1 | 1 | -258.5 | -0.5 | 36 | 700 | |
| | | | | | | | | | | | 1868 STANDR | 345 | 1 | 1 | 335.3 | -24.3 | 47 | 700 | |
| | | | | | | | | | | | 9997 CHSTER30 | 345 | 99 | 3 | 32.0 | 8.9 | 5 | 700 | |
| | | | | | | | | | | | 1802 GRFALL | 138 | 1 | 1 | -76.9 | 10.8 | 39 | 190 | |
| | | | | | | | | | | | 1849 STANDR | 138 | 1 | 1 | 62.0 | -14.4 | 32 | 190 | |
| | | | | | | | | | | | 1824 TETGHEQ | 138 | 99 | 1 | 42.6 | -4.6 | 29 | 140 | |
| | | | | | | | | | | | 1826 DALHOU | 9 | 138 | 1 | -304.2 | 4.6 | 95 | 310 | |
| | | | | | | | | | | | 1830 EELRVR | 9 | 230 | 1 | 50.3 | -4.6 | 0.992UN | 35 | 140 |
| | | | | | | | | | | | 1865 111036 | 9 | 138 | 1 | 6.8 | -5.9 | 6 | 140 | |
| | | | | | | | | | | | 1948 EELRAD11 | 138 | 1 | 1 | 188.6 | 8.5 | 26 | 700 | |

OUTPUT FOR AREA 1 {N.B. POW}

| BUS DATA | | | | LINE DATA | | | | | | | | | | | | |
|----------|-----------|------------|----------|-------------|--------------|---------------|--------|------|----------|-------|------|-------------------|-------|-------------|-----|------|
| FROM BUS | AREA ZONE | VOLT PU/KV | ANGLE | GEN MW/MVAR | LOAD MW/MVAR | SHUNT MW/MVAR | TO BUS | NAME | CKT AREA | MW | MVAR | TRANSFORMER RATIO | ANGLE | RATING A %I | MVA | |
| 1806 | BATHST 8 | 138 | 1 1.047 | -7.6 | 0.0 | 130.5 | 0.0 | 1677 | CARAQT | 138 | 1 | 31.3 | 11.8 | 23 | 140 | |
| | | | 22 144.5 | | 0.0 | 53.0 | -43.9 | 1824 | TETGCHEQ | 138 | 99 | 4.7 | 21.9 | 15 | 140 | |
| | | | | | | | | 1829 | BATHST 8 | 230 | 1 | -13.3 | -31.3 | 14 | 225 | |
| | | | | | | | | 1829 | BATHST 8 | 230 | 2 | -20.3 | -46.2 | 0.953UN | 16 | 300 |
| | | | | | | | | 1915 | BATHST 8 | 345 | 1 | -169.1 | 18.6 | 0.988UN | 36 | 450 |
| | | | | | | | | 1928 | 110694 | 138 | 1 | -16.2 | 3.3 | 11 | 140 | |
| | | | | | | | | 2497 | BMSMEL | 138 | 1 | 52.4 | 12.9 | 37 | 140 | |
| 1807 | NEWCST | 138 | 1 1.040 | -7.3 | 0.0 | 191.0 | 0.0 | 1712 | 111856EQ | 138 | 99 | 87.7 | 33.7 | 65 | 140 | |
| | | | 22 143.5 | | 0.0 | 74.0 | -75.7 | 1832 | NBSCALEQ | 138 | 99 | -47.1 | 28.0 | 38 | 140 | |
| | | | | | | | | 1851 | NEWCST 6 | 230 | 1 | -76.7 | -28.6 | 0.987UN | 33 | 236 |
| | | | | | | | | 1851 | NEWCST 6 | 230 | 2 | -76.7 | -28.6 | 0.987UN | 33 | 236 |
| | | | | | | | | 1969 | MLLBNK | 138 | 99 | -78.3 | -2.9 | 40 | 190 | |
| 1809 | MACTQC 2 | 138 | 1 1.044 | 5.3 | 0.0 | 20.7 | 0.0 | 1827 | KESWIC 2 | 138 | 1 | 156.6 | 19.5 | 54 | 280 | |
| | | | 2 144.0 | | 0.0 | 5.0 | 0.0 | 1827 | KESWIC 2 | 138 | 2 | 155.5 | 19.5 | 54 | 280 | |
| | | | | | | | | 1861 | RAINSLEQ | 138 | 99 | 167.2 | 42.9 | 87 | 190 | |
| | | | | | | | | 1870 | MACTG1 | 213.8 | 1 | -100.0 | -17.1 | 0.945UN | | |
| | | | | | | | | 1871 | MACTG2 | 213.8 | 1 | -100.0 | -17.3 | 0.945UN | | |
| | | | | | | | | 1872 | MACTG3 | 213.8 | 1 | -100.0 | -17.1 | 0.945UN | | |
| | | | | | | | | 1873 | MACTG4 | 213.8 | 1 | -100.0 | -18.1 | 0.945UN | | |
| | | | | | | | | 1874 | MACTG5 | 213.8 | 1 | -100.0 | -17.4 | 0.945UN | | |
| | | | | | | | | 1875 | MACTG6 | 213.8 | 1 | 0.0 | 0.0 | 0.945UN | | |
| 1810 | MARYSV 2 | 138 | 1 1.013 | 1.2 | 0.0 | 159.6 | 0.0 | 1811 | GRLAKE 2 | 138 | 1 | -20.4 | -1.8 | 14 | 140 | |
| | | | 2 139.8 | | 0.0 | 41.0 | 0.0 | 1845 | NASH03 | 2 138 | 1 | -45.6 | -18.6 | 35 | 140 | |
| | | | | | | | | 1846 | NASH12 | 2 138 | 1 | -47.9 | -18.8 | 36 | 140 | |
| | | | | | | | | 1861 | RAINSLEQ | 138 | 99 | -45.6 | -1.8 | 32 | 140 | |
| 1811 | GRLAKE 2 | 138 | 1 1.020 | 2.6 | 0.0 | 46.2 | 0.0 | 1810 | MARYSV 2 | 138 | 1 | 20.5 | -1.0 | 14 | 140 | |
| | | | 2 140.7 | | 0.0 | 30.0 | 0.0 | 1812 | MONCTN 5 | 138 | 1 | 98.2 | -12.5 | 69 | 140 | |
| | | | | | | | | 1832 | NBSCALEQ | 138 | 99 | 65.0 | -9.7 | 46 | 140 | |
| | | | | | | | | 1887 | GRLKGN | 213.8 | 1 | -60.0 | -1.9 | 0.975UN | | |
| | | | | | | | | 1921 | GRLKU9 | 19.0 | 1 | -169.9 | -4.8 | 1.025LK | | |
| 1812 | MONCTN 5 | 138 | 1 1.014 | -10.9 | 0.0 | 350.6 | 0.0 | 1712 | 111856EQ | 138 | 99 | 68.0 | 26.8 | 51 | 140 | |
| | | | 22 140.0 | | 0.0 | 87.5 | -46.3 | 1811 | GRLAKE 2 | 138 | 1 | -92.8 | 28.7 | 68 | 140 | |
| | | | | | | | | 1839 | SALBRY 5 | 138 | 1 | -133.1 | -34.4 | 71 | 190 | |
| | | | | | | | | 1839 | SALBRY 5 | 138 | 2 | -133.1 | -34.4 | 71 | 190 | |
| | | | | | | | | 1945 | 119024 | 138 | 99 | -26.1 | -9.9 | 20 | 140 | |
| | | | | | | | | 1946 | 112408 | 138 | 99 | -33.6 | -18.1 | 27 | 140 | |
| | | | | | | | | 1947 | MONCTA | 569.0 | 1 | 0.0 | 0.0 | 0.980RG | 0 | 134. |

OUTPUT FOR AREA 1 {N.B. POW}

| BUS DATA | | | | LINE DATA | | | | | | | | | | | | | | | | | | |
|----------|-----------|------|------------------|-------------|--------------|---------------|--------|-------|----------|-----|------|-------------------|---------|-------------|-----|----|--------|--------|---------|---------|-----|-----|
| FROM BUS | AREA ZONE | NAME | VOLT PU/KV ANGLE | GEN MW/MVAR | LOAD MW/MVAR | SHUNT MW/MVAR | TO BUS | NAME | CKT AREA | MW | MVAR | TRANSFORMER RATIO | ANGLE | RATING A %I | MVA | | | | | | | |
| 1847 | 112572 | 1 | 138 | 1 | 1.023 | 0.9 | 0.0 | 0.0 | 55.0 | 0.0 | 0.0 | 1800 | BEECHW | 138 | 1 | 1 | 12.8 | -11.9 | 12 | 140 | | |
| 1849 | STANDR | 138 | 1 | 1.038 | -5.2 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 1827 | KESWIC | 2 | 138 | 1 | 1 | -67.8 | -3.0 | 47 | 140 | |
| 1850 | SALBRY | 5 | 345 | 1 | 0.978 | -5.1 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 1804 | 117562 | 138 | 1 | 1 | -61.6 | 14.8 | 32 | 190 | | |
| 1851 | NEWCST | 6 | 230 | 1 | 1.037 | -5.9 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 1865 | 111036 | 9 | 138 | 1 | 1 | -4.7 | -3.7 | 4 | 140 | |
| 1852 | 110871 | 5 | 138 | 1 | 1.018 | -10.7 | 0.0 | 21.9 | 0.0 | 0.0 | 0.0 | 1868 | STANDR | 345 | 1 | 1 | 66.3 | -11.1 | 0.979UN | 22 | 293 | |
| 1853 | HARDRD | 5 | 138 | 1 | 1.006 | -14.8 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 168 | ONSLW | 345 | 99 | 5 | 7.1 | -38.4 | 10 | 400 | | |
| 1854 | MILD47 | 4 | 138 | 1 | 1.002 | -0.9 | 0.0 | 4.8 | 0.0 | 0.0 | 0.0 | 1839 | SALBRY | 5 | 138 | 1 | 1 | 193.1 | 81.6 | 0.919RG | 48 | 450 |
| 1855 | RAINSLEQ | 138 | 2 | 140.5 | 2.1 | 0.0 | 0.0 | 1.2 | 0.0 | 0.0 | 0.0 | 1839 | SALBRY | 5 | 138 | 2 | 1 | 149.8 | 86.9 | 0.910RG | 52 | 340 |
| 1856 | MILD65 | 4 | 138 | 1 | 1.004 | -0.7 | 0.0 | 26.0 | 0.0 | 0.0 | 0.0 | 1900 | MORTN3 | 345 | 1 | 1 | -341.6 | -24.9 | 0.920UN | 50 | 700 | |
| 1857 | 1119042 | 138 | 5 | 137.7 | -13.2 | 0.0 | 0.0 | 6.6 | 0.0 | 0.0 | 0.0 | 1916 | NEWCAS | 6 | 345 | 1 | 1 | -8.4 | -89.8 | 13 | 700 | |
| 1858 | 111036 | 9 | 138 | 1 | 1.040 | -4.4 | 0.0 | 119.2 | 0.0 | 0.0 | 0.0 | 1807 | NEWCST | 138 | 1 | 1 | 76.7 | 30.7 | 0.987RG | 34 | 236 | |
| 1859 | EELRVR | 9 | 345 | 1 | 1.037 | -5.3 | 0.0 | 30.0 | 0.0 | 0.0 | 0.0 | 1807 | NEWCST | 138 | 2 | 1 | 76.7 | 30.7 | 0.987RG | 34 | 236 | |
| 1860 | EDMSTN | 1 | 345 | 1 | 1.003 | -10.3 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 1828 | KESWIC | 2 | 230 | 1 | 1 | -95.3 | 1.4 | 26 | 350 | |
| 1861 | 112572 | 1 | 138 | 1 | 1.023 | 0.9 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 1916 | NEWCAS | 6 | 345 | 1 | 1 | -31.8 | -90.3 | 0.920UN | 23 | 400 |
| 1862 | 110871 | 5 | 138 | 1 | 1.018 | -10.7 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 1964 | MBKTP | 230 | 1 | 1 | -26.3 | 27.4 | 10 | 350 | | |
| 1863 | 1119042 | 138 | 2 | 140.5 | 2.1 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 1825 | MECOK | 5 | 138 | 1 | 1 | 46.3 | -2.2 | 32 | 140 | |
| 1864 | 111036 | 9 | 138 | 1 | 1.040 | -4.4 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 1946 | 112408 | 138 | 1 | 1 | -68.2 | -3.3 | 48 | 140 | | |
| 1865 | EELRVR | 9 | 345 | 1 | 1.037 | -5.3 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 1844 | MURRCR | 5 | 138 | 1 | 2 | 20.1 | -15.2 | 18 | 140 | |
| 1866 | EDMSTN | 1 | 345 | 1 | 1.003 | -10.3 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 1863 | 119042 | 138 | 1 | 1 | -24.9 | 14.0 | 20 | 140 | | |
| 1867 | 112572 | 1 | 138 | 1 | 1.023 | 0.9 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 1813 | C. BAY | 4 | 138 | 1 | 1 | 98.2 | 5.7 | 70 | 140 | |
| 1868 | 111036 | 9 | 138 | 1 | 1.040 | -4.4 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 1837 | C. COVE | 4 | 138 | 1 | 1 | -124.2 | -12.3 | 89 | 140 | |
| 1869 | EELRVR | 9 | 345 | 1 | 1.037 | -5.3 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 1809 | MACTQC | 2 | 138 | 99 | 1 | -165.2 | -32.5 | 87 | 190 | |
| 1870 | EDMSTN | 1 | 345 | 1 | 1.003 | -10.3 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 1810 | MARYSV | 2 | 138 | 99 | 1 | 46.0 | 2.5 | 32 | 140 | |
| 1871 | 112572 | 1 | 138 | 1 | 1.023 | 0.9 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 1813 | C. BAY | 4 | 138 | 1 | 1 | 113.7 | 9.3 | 81 | 140 | |
| 1872 | 111036 | 9 | 138 | 1 | 1.040 | -4.4 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 1837 | C. COVE | 4 | 138 | 1 | 1 | -113.7 | -9.3 | 81 | 140 | |
| 1873 | EELRVR | 9 | 345 | 1 | 1.037 | -5.3 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 183 | SPRNHIL | 138 | 99 | 5 | -12.5 | -5.2 | 10 | 140 | | |
| 1874 | EDMSTN | 1 | 345 | 1 | 1.003 | -10.3 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 1854 | HARDRD | 5 | 138 | 1 | 1 | 25.1 | -15.8 | 21 | 140 | |
| 1875 | 112572 | 1 | 138 | 1 | 1.023 | 0.9 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 1945 | 119024 | 138 | 1 | 1 | -78.4 | -13.1 | 57 | 140 | | |
| 1876 | 111036 | 9 | 138 | 1 | 1.040 | -4.4 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 1805 | EELRVR | 9 | 138 | 1 | 1 | -6.8 | 4.3 | 6 | 140 | |
| 1877 | EELRVR | 9 | 345 | 1 | 1.037 | -5.3 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 1849 | STANDR | 138 | 1 | 1 | 4.7 | -4.8 | 5 | 140 | | |
| 1878 | EDMSTN | 1 | 345 | 1 | 1.003 | -10.3 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 1830 | EELRVR | 9 | 230 | 1 | 1 | 192.5 | 32.8 | 1.001UN | 47 | 400 |
| 1879 | 112572 | 1 | 138 | 1 | 1.023 | 0.9 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 1868 | STANDR | 345 | 1 | 1 | 45.1 | -4.4 | 6 | 700 | | |
| 1880 | 111036 | 9 | 138 | 1 | 1.040 | -4.4 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 1913 | BEIDUN | 9 | 345 | 1 | 1 | -237.6 | -28.4 | 33 | 700 | |
| 1881 | EELRVR | 9 | 345 | 1 | 1.037 | -5.3 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 1868 | STANDR | 345 | 1 | 1 | -437.9 | -53.2 | 63 | 700 | | |
| 1882 | EDMSTN | 1 | 345 | 1 | 1.003 | -10.3 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 1869 | WADHYQ | 345 | 1 | 4 | 200.4 | 12.0 | 50 | 400 | | |
| 1883 | 112572 | 1 | 138 | 1 | 1.023 | 0.9 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 1907 | EDMSTN | 12 | 138 | 1 | 1 | 118.8 | 20.6 | 0.967RG | 41 | 293 |
| 1884 | 111036 | 9 | 138 | 1 | 1.040 | -4.4 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 1907 | EDMSTN | 12 | 138 | 2 | 1 | 118.8 | 20.6 | 0.967RG | 41 | 293 |

OUTPUT FOR AREA 1 {N.B. POW}

| BUS DATA | | | | GEN | | | | LOAD | | | | SHUNT | | | | LINE DATA | | | | TO | |
|---------------|-------|-----------|------------------|---------|-------------|--------------|---------------|----------------|------|----------|--------|-------|---------|-------|-----------|-----------|-----|-------------|--|----|--|
| FROM BUS | NAME | AREA ZONE | VOLT PU/KV ANGLE | MW/MVAR | GEN MW/MVAR | LOAD MW/MVAR | SHUNT MW/MVAR | NAME | AREA | CKT AREA | MW | MVAR | RATIO | ANGLE | RATING %I | MVA | BUS | TRANSFORMER | | | |
| 1886 C.BYG4 | 413.8 | 1 | 1.035 | 1.3 | 97.0 | 0.0 | 0.0 | 1813 C. BAY 4 | 138 | 1 | 97.0 | 66.0 | 1.000LK | | | | | | | | |
| 1887 GRLKGN | 213.8 | 1 | 1.000 | 7.2 | 60.0 | 0.0 | 0.0 | 1811 GRLAKE 2 | 138 | 1 | 60.0 | 6.8 | 0.975LK | | | | | | | | |
| 1888 GR.FGH | 16.60 | 1 | 1.023 | 0.1 | 30.0 | 0.0 | 0.0 | 1802 GRFALL | 138 | 1 | 30.0 | 7.4 | 0.970LK | | | | | | | | |
| 1890 BEEG12 | 113.8 | 1 | 1.022 | 1.8 | 40.0 | 0.0 | 0.0 | 1800 BEECHW | 138 | 1 | 40.0 | 20.0 | 0.971LK | | | | | | | | |
| 1891 BEEG3 | 113.8 | 1 | 1.022 | 3.6 | 40.0 | 0.0 | 0.0 | 1800 BEECHW | 138 | 1 | 40.0 | 12.0 | 0.971LK | | | | | | | | |
| 1900 NORTN3 | 345 | 4 | 0.991 | -0.7 | 0.0 | 0.0 | 0.0 | 1836 C. COVE 4 | 345 | 1 | -469.1 | -55.9 | | 68 | 700 | | | | | | |
| 1901 NORTN1 | 138 | 4 | 1.033 | -3.5 | 0.0 | 0.0 | 0.0 | 1850 SALBRY 5 | 345 | 1 | 344.4 | 19.6 | | 50 | 700 | | | | | | |
| 1907 EDMSTN12 | 138 | 12 | 1.032 | -12.2 | 0.0 | 0.0 | 0.0 | 1901 NORTN1 | 138 | 1 | 124.7 | 36.4 | 0.946RG | 39 | 340 | | | | | | |
| 1908 114084 | 138 | 1 | 1.028 | -13.2 | 0.0 | 0.0 | 0.0 | 1747 PHSFLO | 138 | 1 | 34.3 | 33.3 | | 24 | 190 | | | | | | |
| 1909 IROQUA | 138 | 1 | 1.027 | -13.3 | 0.0 | 122.7 | 0.0 | 1776 1149-EQL | 138 | 99 | 90.2 | -3.6 | | 62 | 140 | | | | | | |
| 1910 IROQUB | 138 | 1 | 1.025 | -13.1 | 0.0 | 37.0 | 0.0 | 1900 NORTN3 | 345 | 1 | -124.5 | -29.7 | 0.946UN | 36 | 340 | | | | | | |
| 1913 BELDUN 9 | 345 | 1 | 1.045 | -3.0 | 0.0 | 0.0 | 0.0 | 1867 EDMSTN 1 | 345 | 1 | -118.7 | -16.5 | 0.967UN | 40 | 293 | | | | | | |
| 1914 BELGEN | 19.0 | 1 | 1.035 | 1.0 | 450.0 | 0.0 | 0.0 | 1867 EDMSTN 1 | 345 | 2 | -118.7 | -16.5 | 0.967UN | 40 | 293 | | | | | | |
| 1915 BATHST 8 | 345 | 1 | 1.031 | -4.7 | 0.0 | 0.0 | 0.0 | 1908 114084 | 138 | 1 | -122.7 | -5.4 | | 85 | 140 | | | | | | |
| | | 8 | 355.6 | | 0.0 | 0.0 | 0.0 | 1909 IROQUA | 138 | 1 | 122.8 | 5.6 | | 85 | 140 | | | | | | |
| | | | | | 0.0 | 0.0 | 0.0 | 1908 114084 | 138 | 1 | -122.7 | -5.4 | | 85 | 140 | | | | | | |
| | | | | | 0.0 | 0.0 | 0.0 | 1907 EDMSTN12 | 138 | 1 | -113.9 | -24.3 | | 81 | 140 | | | | | | |
| | | | | | 0.0 | 0.0 | 0.0 | 1866 EELVR 9 | 345 | 1 | 238.6 | 8.5 | | 33 | 700 | | | | | | |
| | | | | | 0.0 | 0.0 | 0.0 | 1914 BELGEN | 19.0 | 1 | -449.4 | -74.6 | 0.975UN | 58 | 756 | | | | | | |
| | | | | | 0.0 | 0.0 | 0.0 | 1915 BATHST 8 | 345 | 1 | 210.8 | 66.1 | | 30 | 700 | | | | | | |
| | | | | | 0.0 | 0.0 | 0.0 | 1913 BELDUN 9 | 345 | 1 | 450.0 | 108.0 | 0.975LK | 59 | 756 | | | | | | |
| | | | | | 0.0 | 0.0 | 0.0 | 1806 BATHST 8 | 138 | 1 | 169.2 | -9.8 | 0.988RG | 37 | 450 | | | | | | |
| | | | | | 0.0 | 0.0 | 0.0 | 1913 BELDUN 9 | 345 | 1 | -210.1 | -83.7 | | 31 | 700 | | | | | | |
| | | | | | 0.0 | 0.0 | 0.0 | 1916 NEWCAS 6 | 345 | 1 | 40.9 | 93.5 | | 14 | 7006 | | | | | | |

OUTPUT FOR AREA 1 {N.B. POW}

| BUS DATA | | | | LINE DATA | | | | | | | | | | | |
|----------|-----------|------------|-------|-------------|--------------|---------------|--------|-------|----------|-----|------|-------------------|-------|-----------|-----|
| FROM BUS | AREA ZONE | VOLT PU/KV | ANGLE | GEN MW/MVAR | LOAD MW/MVAR | SHUNT MW/MVAR | TO BUS | NAME | CKT AREA | MW | MVAR | TRANSFORMER RATIO | ANGLE | RATING %I | MVA |
| 1916 | NEWCAS | 6 | 345 | 1 | 1.003 | -5.1 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 6 | | | | | 346.0 | | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 1921 | GRLKU9 | 19.0 | 1 | 1.000 | 6.8 | 170.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 2 | | | | | 19.00 | | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 1928 | 110694 | 138 | 1 | 1.047 | -7.1 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 8 | | | | | 144.5 | | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 1930 | 1126MP | 138 | 1 | 1.018 | -0.5 | 0.0 | 50.3 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 1 | | | | | 140.4 | | 20.8 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 1945 | 119024 | 138 | 1 | 1.018 | -10.7 | 0.0 | 6.6 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 5 | | | | | 140.4 | | 1.5 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 1946 | 112408 | 138 | 1 | 1.020 | -10.6 | 0.0 | 6.6 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 5 | | | | | 140.7 | | 1.5 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 1947 | MONCTA | 569.0 | 1 | 1.035 | -10.9 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 5 | | | | | 71.44 | | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 1948 | EELRAD11 | 138 | 1 | 1.038 | -4.1 | 0.0 | 108.8 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 11 | | | | | 143.3 | | 43.4 | -21.6 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 1964 | MBNKTP | 230 | 1 | 1.034 | -5.8 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 8 | | | | | 237.9 | | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 1965 | MLLBK | 230 | 1 | 1.037 | -5.2 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 8 | | | | | 238.6 | | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 1969 | MLLBK | 138 | 1 | 1.048 | -5.9 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 8 | | | | | 144.6 | | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 1971 | PENFLD | 138 | 1 | 1.026 | 0.6 | 25.0 | 58.7 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 3 | | | | | 141.6 | | 18.6 | -10.5 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 1986 | MBKGT1 | 13.8 | 1 | 1.000 | 0.5 | 97.5 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 8 | | | | | 13.80 | | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 1987 | MBKGT2 | 13.8 | 1 | 0.985 | -5.2 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 8 | | | | | 13.60 | | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |

OUTPUT FOR AREA 1 {N.B. POW}

| BUS DATA | | | | LINE DATA | | | | | | | | | | | | | | | | | | | |
|----------|-----------|------------|-------|-------------|--------------|---------------|--------|------|----------|-----|------|-------------------|-------|------------|----------|-----|-------|-----|---------|-------|---------|----|-----|
| FROM BUS | AREA ZONE | VOLT PU/KV | ANGLE | GEN MW/MVAR | LOAD MW/MVAR | SHUNT MW/MVAR | TO BUS | NAME | CKT AREA | MW | MVAR | TRANSFORMER RATIO | ANGLE | RATING A % | MVA | | | | | | | | |
| 1988 | MBKGT3 | 13.8 | 1 | 1.000 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 100.0 | 9.3R | 138 | 1 | 1 | 100.0 | 9.3 | 0.950LK | 80 | 125 | | |
| 1989 | MBKGT4 | 13.8 | 1 | 0.996 | -5.9 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 1969 | MLLBNK | 138 | 1 | 1 | 0.0 | 0.0 | 0.950LK | 0 | 125 |
| 2495 | NBIPC | 11 | 138 | 1 | 1.034 | -4.6 | 0.0 | 0.0 | 29.7 | 0.0 | 0.0 | 0.0 | 0.0 | 1969 | MLLBNK | 138 | 1 | 1 | 0.0 | 0.0 | 0.950LK | 0 | 125 |
| | | | 21 | 142.7 | | | 0.0 | 0.0 | 7.5 | 0.0 | 0.0 | 0.0 | 0.0 | 1948 | EELRAD11 | 138 | 1 | 1 | -29.7 | -7.5 | | 21 | 140 |
| 2496 | ROTHPR | 138 | 1 | 0.994 | -2.3 | 0.0 | 0.0 | 0.0 | 89.1 | 0.0 | 0.0 | 0.0 | 0.0 | 1813 | C. BAY 4 | 138 | 1 | 1 | -89.1 | -22.3 | | 66 | 140 |
| | | | 21 | 137.2 | | | 0.0 | 0.0 | 22.3 | 0.0 | 0.0 | 0.0 | 0.0 | 1806 | BATHST 8 | 138 | 1 | 1 | -52.0 | -13.1 | | 37 | 140 |
| 2497 | BKSMEL | 138 | 1 | 1.031 | -9.3 | 0.0 | 0.0 | 0.0 | 52.0 | 0.0 | 0.0 | 0.0 | 0.0 | 1830 | EELRVR 9 | 230 | 1 | 1 | -68.9 | -17.3 | | 20 | 350 |
| | | | 21 | 142.3 | | | 0.0 | 0.0 | 13.1 | 0.0 | 0.0 | 0.0 | 0.0 | 1829 | BATHST 8 | 230 | 1 | 1 | -60.0 | -16.4 | | 18 | 350 |
| 2498 | NBIPC | 11 | 230 | 1 | 1.032 | -7.0 | 0.0 | 0.0 | 68.9 | 0.0 | 0.0 | 0.0 | 0.0 | | | | | | | | | | |
| | | | 21 | 237.3 | | | 0.0 | 0.0 | 17.3 | 0.0 | 0.0 | 0.0 | 0.0 | | | | | | | | | | |
| 2499 | CONSBH | 8 | 230 | 1 | 1.008 | -7.5 | 0.0 | 0.0 | 60.0 | 0.0 | 0.0 | 0.0 | 0.0 | | | | | | | | | | |
| | | | 21 | 231.8 | | | 0.0 | 0.0 | 16.4 | 0.0 | 0.0 | 0.0 | 0.0 | | | | | | | | | | |

OUTPUT FOR AREA 2 { }

| BUS DATA | | | | LINE DATA | | | | | | | | | | | | | | | | | | | |
|----------|-----------|------------|-------|-------------|--------------|---------------|--------|------|----------|-----|------|-------------------|-------|------------|----------|-----|---|---|-------|------|--|----|------|
| FROM BUS | AREA ZONE | VOLT PU/KV | ANGLE | GEN MW/MVAR | LOAD MW/MVAR | SHUNT MW/MVAR | TO BUS | NAME | CKT AREA | MW | MVAR | TRANSFORMER RATIO | ANGLE | RATING A % | MVA | | | | | | | | |
| 1844 | MURROR | 5 | 138 | 2 | 1.009 | -15.2 | 0.0 | 0.0 | 60.0 | 0.0 | 0.0 | 0.0 | 0.0 | 1825 | MEMCOK 5 | 138 | 1 | 1 | -39.9 | 5.4 | | 29 | 140 |
| | | | 5 | 139.3 | | | 0.0 | 0.0 | -20.0 | 0.0 | 0.0 | 0.0 | 0.0 | 1854 | HARDRD 5 | 138 | 1 | 1 | -20.1 | 14.6 | | 18 | 140E |

OUTPUT FOR AREA 3 { }

| BUS DATA | | | | LINE DATA | | | | | | | | | | | | | | | | | | | |
|----------|-----------|------------|-------|-------------|--------------|---------------|--------|-------|----------|-----|------|-------------------|-------|------------|----------|-----|----|---|--------|-------|--|----|------|
| FROM BUS | AREA ZONE | VOLT PU/KV | ANGLE | GEN MW/MVAR | LOAD MW/MVAR | SHUNT MW/MVAR | TO BUS | NAME | CKT AREA | MW | MVAR | TRANSFORMER RATIO | ANGLE | RATING A % | MVA | | | | | | | | |
| 700 | ORRING30 | 345 | 3 | 1.027 | 1.2 | 0.0 | 0.0 | 230.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 1843 | LEPRAU | 345 | 1 | 1 | -198.1 | -41.1 | | 28 | 700 |
| | | | 30 | 354.2 | | | 0.0 | 54.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 9997 | CHSTER30 | 345 | 1 | 3 | -31.9 | -12.9 | | 5 | 700 |
| 9997 | CHSTER30 | 345 | 3 | 1.025 | 1.6 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 700 | ORRING30 | 345 | 1 | 3 | 31.9 | -34.3 | | 7 | 700 |
| | | | 30 | 353.6 | | | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 1803 | KESWIC 2 | 345 | 99 | 1 | -31.9 | -8.4 | | 5 | 700E |

OUTPUT FOR AREA 4 { }

| BUS DATA | | | | GEN | | | | LOAD | | | | SHUNT | | | | LINE DATA | | | | | | | |
|----------|-----------|------|------------|-------|---------|---------|-------|---------|---------|---------|---------|---------|---------|---------|--------|-----------|----------|--------|-------|-------------------|-------|-------------|-----|
| FROM BUS | AREA ZONE | NAME | VOLT PU/KV | ANGLE | MW/MVAR | MW/MVAR | ANGLE | MW/MVAR | MW/MVAR | MW/MVAR | MW/MVAR | MW/MVAR | MW/MVAR | MW/MVAR | TO BUS | NAME | CKT AREA | MW | MVAR | TRANSFORMER RATIO | ANGLE | RATING A %I | MVA |
| 1869 | MADHYQ | 345 | 4 | 1.000 | -11.2 | 0.0 | 200.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 1867 | EDMSTN | 1 345 | 1 | -200.0 | -21.2 | | | 50 | 400 |
| 9996 | EELHYQ | 230 | 4 | 1.032 | -7.2 | 0.0 | 200.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 1830 | EELVR | 9 230 | 99 | -200.0 | -1.2 | | | 55 | 350 |

OUTPUT FOR AREA 5 { }

| BUS DATA | | | | GEN | | | | LOAD | | | | SHUNT | | | | LINE DATA | | | | | | | | |
|----------|-----------|------|------------|-------|---------|---------|-------|---------|---------|---------|---------|---------|---------|-----------|--------|-----------|-------|-------|-------------------|-------|-------------|-----|-----|-----|
| FROM BUS | AREA ZONE | NAME | VOLT PU/KV | ANGLE | MW/MVAR | MW/MVAR | ANGLE | MW/MVAR | MW/MVAR | MW/MVAR | MW/MVAR | MW/MVAR | MW/MVAR | TO BUS | NAME | CKT AREA | MW | MVAR | TRANSFORMER RATIO | ANGLE | RATING A %I | MVA | | |
| 157 | MACCAN | 138 | 5 | 1.007 | -12.5 | 0.0 | 12.6 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 183 | SPRINGHIL | 138 99 | 5 | -7.1 | -0.6 | | | 5 | 140 | | |
| | | | 36 | 139.0 | | 0.0 | 5.1 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 1825 | MEMCOK | 5 138 | 99 | 1 | -5.5 | -4.5 | | | 5 | 140 | |
| 158 | ONSLW | 138 | 5 | 1.045 | -8.5 | 0.0 | 50.1 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 167 | ONSLW | 230 1 | 5 | -94.1 | -47.8 | 0.950UN | | 45 | 224 | | |
| | | | 36 | 144.2 | | 0.0 | 90.5 | -54.6 | 0.0 | 0.0 | 0.0 | 0.0 | 183 | SPRINGHIL | 138 1 | 5 | 44.0 | 11.9 | | | 31 | 140 | | |
| 167 | ONSLW | 230 | 5 | 1.016 | -6.4 | 0.0 | 31.4 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 158 | ONSLW | 138 1 | 5 | 94.4 | 52.4 | 0.950LK | | 47 | 224 | | |
| | | | 36 | 233.6 | | 0.0 | 112.7 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 168 | ONSLW | 345 1 | 5 | -64.2 | -81.5 | 0.960UN | | 26 | 392 | | |
| 168 | ONSLW | 345 | 5 | 1.000 | -5.5 | 119.1 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 168 | ONSLW | 345 2 | 5 | -61.6 | -83.6 | 0.960UN | | 26 | 392 | | |
| | | | 36 | 345.0 | | 210.8R | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 167 | ONSLW | 230 1 | 5 | 64.4 | 84.6 | 0.960LK | | 27 | 392 | | |
| 183 | SPRINGHIL | 138 | 5 | 1.008 | -12.4 | 0.0 | 23.6 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 167 | ONSLW | 230 2 | 5 | 61.7 | 86.8 | 0.960LK | | 27 | 392 | | |
| | | | 36 | 139.1 | | 0.0 | 7.1 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 1850 | SALBRY | 5 345 | 99 | 1 | -7.0 | 39.3 | | | 10 | 400 | |
| | | | | | | 0.0 | 23.6 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 157 | MACCAN | 138 99 | 5 | 7.1 | 0.0 | | | | | 5 | 140 |
| | | | | | | 0.0 | 7.1 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 158 | ONSLW | 138 1 | 5 | -43.2 | -13.2 | | | | | 32 | 140 |
| | | | | | | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 1863 | 119042 | 138 99 | 1 | 12.6 | 5.4 | | | | | 10 | 140 |

OUTPUT FOR AREA 6 { }

| BUS DATA | | | | GEN | | | | LOAD | | | | SHUNT | | | | LINE DATA | | | | | | |
|----------|-----------|------|------------|-------|---------|---------|-------|---------|---------|---------|---------|---------|---------|--------|--------|-----------|------|------|-------------------|-------|-------------|------|
| FROM BUS | AREA ZONE | NAME | VOLT PU/KV | ANGLE | MW/MVAR | MW/MVAR | ANGLE | MW/MVAR | MW/MVAR | MW/MVAR | MW/MVAR | MW/MVAR | MW/MVAR | TO BUS | NAME | CKT AREA | MW | MVAR | TRANSFORMER RATIO | ANGLE | RATING A %I | MVA |
| 1896 | TINKER61 | 138 | 6 | 1.037 | -2.3 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 1800 | BEECHW | 138 99 | 1 | -7.0 | 2.7 | | | 5 | 140 |
| | | | 10 | 143.1 | | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 1817 | 111144 | 1 138 | 1 | 7.0 | -2.7 | | | 5 | 140E |

GENERATOR SUMMARY:

| BUS | NAME | BSVLT | #MAC | TYP | MW | MVAR | QMAX | QMIN | VSCHED | VACTUAL | REM |
|------------------|----------|-------|------|-----|--------|-------|--------|---------|----------|---------|------|
| 168 | ONSLOW | 345 | 4 | 2 | 119.1 | 210.8 | 450.0 | -150.0 | 1.0000 | 1.0000 | |
| 700 | ORRING30 | 345 | 3 | -2 | 0.0 | 0.0 | 0.0 | 0.0 | 1.0000 | 1.0265 | |
| 1677 | CARAQT | 138 | 1 | 2 | 100.0 | 8.1 | 60.0 | -40.0 | 1.0200 | 1.0200 | |
| 1844 | MURRCR | 5 138 | 1 | -2 | 0.0 | 0.0 | 0.0 | 0.0 | 1.0000 | 1.0091 | |
| 1869 | MADHYQ | 345 | 1 | 2 | 0.0 | 18.8 | 210.0 | -100.0 | 1.0000 | 1.0000 | |
| 1870 | MACTG1 | 213.8 | 1 | 2 | 100.0 | 24.1 | 52.0 | -52.0 | 1.0000 | 1.0000 | |
| 1871 | MACTG2 | 213.8 | 1 | 2 | 100.0 | 24.2 | 52.0 | -52.0 | 1.0000 | 1.0000 | |
| 1872 | MACTG3 | 213.8 | 1 | 2 | 100.0 | 24.1 | 52.0 | -52.0 | 1.0000 | 1.0000 | |
| 1873 | MACTG4 | 213.8 | 1 | 2 | 100.0 | 24.8 | 52.0 | -52.0 | 1.0000 | 1.0000 | |
| 1874 | MACTG5 | 213.8 | 1 | 2 | 100.0 | 24.2 | 54.0 | -54.0 | 1.0000 | 1.0000 | |
| 1875 | MACTG6 | 213.8 | 1 | -2 | 0.0 | 0.0 | 0.0 | 0.0 | 1.0000 | 0.9864 | |
| 1876 | LEPRG1 | 426.0 | 1 | 2 | 657.0 | 5.8 | 415.0 | -230.0 | 1.0200 | 1.0200 | |
| 1877 | C.CVG1 | 419.0 | 1 | 2 | 335.0 | 77.0 | 160.0 | -98.0 | 1.0000 | 1.0000 | |
| 1878 | C.CVG2 | 419.0 | 1 | 2 | 335.0 | 77.0 | 160.0 | -98.0 | 1.0000 | 1.0000 | |
| 1879 | C.CVG3 | 419.0 | 1 | 2 | 335.0 | 77.0 | 160.0 | -98.0 | 1.0000 | 1.0000 | |
| 1880 | DALHG1 | 913.8 | 1 | 2 | 103.0 | 12.4 | 66.0 | -20.0 | 1.0000 | 1.0000 | |
| 1881 | DALHG2 | 919.0 | 1 | 2 | 203.0 | 26.0 | 100.0 | -60.0 | 1.0000 | 1.0000 | |
| 1883 | C.BYG1 | 413.8 | 1 | 2 | 44.5 | 4.6 | 31.5 | -12.0 | 1.0000 | 1.0000 | |
| 1884 | C.BYG2 | 46.90 | 1 | 2 | 12.3 | 3.6 | 8.3 | -5.5 | 1.0000 | 1.0000 | |
| 1885 | C.BYG3 | 413.8 | 1 | 2 | 100.0 | 10.6 | 66.0 | -46.0 | 1.0000 | 1.0000 | |
| 1886 | C.BYG4 | 413.8 | 1 | -2 | 97.0 | 66.0 | 66.0 | -46.0 | 1.0100 | 0.9951 | 1813 |
| 1887 | GRLKGN | 213.8 | 1 | 2 | 60.0 | 6.8 | 37.0 | -15.0 | 1.0000 | 1.0000 | |
| 1888 | GR.FGH | 16.60 | 1 | 2 | 30.0 | 7.4 | 15.4 | -15.4 | 1.0227 | 1.0227 | |
| 1890 | BEEG12 | 113.8 | 1 | 2 | 40.0 | 20.0 | 35.2 | -36.0 | 1.0217 | 1.0217 | |
| 1891 | BEEG3 | 113.8 | 1 | 2 | 40.0 | 12.0 | 20.0 | -20.0 | 1.0217 | 1.0217 | |
| 1896 | TINKER61 | 138 | 2 | -2 | 0.0 | 0.0 | 0.0 | 0.0 | 1.0000 | 1.0366 | |
| 1910 | IROQUB | 138 | 1 | 2 | 40.0 | 9.3 | 30.0 | -30.0 | 1.0250 | 1.0250 | |
| 1914 | BELGEN | 19.0 | 1 | 2 | 450.0 | 108.0 | 320.0 | -250.0 | 1.0450 | 1.0450 | 1913 |
| 1921 | GRLKU9 | 19.0 | 1 | 2 | 170.0 | 17.1 | 83.0 | -40.0 | 1.0000 | 1.0000 | |
| 1947 | MONCTA | 569.0 | 1 | -2 | 0.0 | 0.0 | 0.0 | 0.0 | 1.0000 | 1.0353 | |
| 1971 | PENFLD | 138 | 1 | -2 | 25.0 | 18.0 | -12.0 | 18.0 | 1.0150 | 1.0263 | |
| 1986 | MBKGT1 | 13.8 | 1 | 3 | 97.5 | 19.0 | 66.0 | -20.0 | 1.0000 | 1.0000 | |
| 1987 | MBKGT2 | 13.8 | 1 | -2 | 0.0 | 0.0 | 0.0 | 0.0 | 1.0000 | 0.9855 | |
| 1988 | MBKGT3 | 13.8 | 1 | 2 | 100.0 | 9.3 | 66.0 | -20.0 | 1.0000 | 1.0000 | |
| 1989 | MBKGT4 | 13.8 | 1 | -2 | 0.0 | 0.0 | 0.0 | 0.0 | 1.0000 | 0.9955 | |
| 9996 | EELHYQ | 230 | 1 | 2 | 0.0 | 38.8 | 50.0 | -50.0 | 1.0325 | 1.0325 | |
| 9997 | CHSTER30 | 345 | 1 | 2 | 0.0 | -42.7 | 425.0 | -125.0 | 1.0250 | 1.0250 | |
| SUBSYSTEM TOTALS | | | | | 3993.4 | 942.3 | 3350.4 | -1868.9 | MVABASE= | 5864.6 | |

BUSES WITH VOLTAGE GREATER THAN 1.0500:

X—— BUS ——X AREA V(PU) V(KV) X—— BUS ——X AREA V(PU) V(KV)
 = NONE =

BUSES WITH VOLTAGE LESS THAN 0.9500:

X—— BUS ——X AREA V(PU) V(KV) X—— BUS ——X AREA V(PU) V(KV)
 1712 111856EQ 138 1 0.9391 129.60

| FROM AREA | | 1 | | N.B. POW | | | | | |
|-----------------------------|-------|--------|-------|----------|----------|---------|-------|-------|-------|
| TO AREA 2 | | | | | | | | | |
| X | FROM | X | X | TO | X | CKT | MW | MVAR | |
| | 1825 | MEMCOK | 5 138 | 1844* | MURRCR | 5 138 1 | 39.9 | -5.4 | |
| | 1854 | HARDRD | 5 138 | 1844* | MURRCR | 5 138 1 | 20.1 | -14.6 | |
| TOTAL FROM AREA 1 TO AREA 2 | | | | | | | | 60.0 | -20.0 |
| TO AREA 3 | | | | | | | | | |
| X | FROM | X | X | TO | X | CKT | MW | MVAR | |
| | 1803 | KESWIC | 2 345 | 9997* | CHSTER30 | 345 99 | 31.9 | 8.4 | |
| | 1843* | LEPRAU | 345 | 700 | ORRING30 | 345 1 | 200.6 | -59.4 | |
| TOTAL FROM AREA 1 TO AREA 3 | | | | | | | | 232.6 | -51.0 |
| TO AREA 4 | | | | | | | | | |
| X | FROM | X | X | TO | X | CKT | MW | MVAR | |
| | 1830 | EELRVR | 9 230 | 9996* | EELHYQ | 230 99 | 200.0 | 1.2 | |
| | 1867 | EDMSTN | 1 345 | 1869* | MADHYQ | 345 1 | 200.0 | 21.2 | |
| TOTAL FROM AREA 1 TO AREA 4 | | | | | | | | 400.0 | 22.4 |
| TO AREA 5 | | | | | | | | | |
| X | FROM | X | X | TO | X | CKT | MW | MVAR | |
| | 1825 | MEMCOK | 5 138 | 157* | MACCAN | 138 99 | 5.5 | 4.5 | |
| | 1850 | SALBRY | 5 345 | 168* | ONSLOW | 345 99 | 7.0 | -39.3 | |
| | 1863 | 119042 | 138 | 183* | SPRNHIL | 138 99 | -12.6 | -5.4 | |
| TOTAL FROM AREA 1 TO AREA 5 | | | | | | | | 0.0 | -40.3 |
| TO AREA 6 | | | | | | | | | |
| X | FROM | X | X | TO | X | CKT | MW | MVAR | |
| | 1800 | BEECHW | 138 | 1896* | TINKER61 | 138 99 | 7.0 | -2.7 | |
| | 1817 | 111144 | 1 138 | 1896* | TINKER61 | 138 1 | -7.0 | 2.7 | |
| TOTAL FROM AREA 1 TO AREA 6 | | | | | | | | 0.0 | 0.0 |
| TOTAL FROM AREA 1 | | | | | | | | 692.5 | -88.9 |

| AREA | GENERATION | FROM | TO | TO BUS | TO LINE | FROM | TO | LOSSES | DESIRED |
|----------|------------|------|--------|--------|---------|----------|---------|--------|---------|
| | | | LOAD | SHUNT | SHUNT | CHARGING | NET INT | | NET INT |
| 1 | 3874.3 | | 3097.0 | 0.0 | 0.0 | 0.0 | 692.5 | 54.8 | 690.0 |
| N.B. POW | 716.6 | | 910.0 | -340.9 | 0.0 | 768.3 | -88.9 | 1004.8 | |
| 2 | 0.0 | | 60.0 | 0.0 | 0.0 | 0.0 | -60.0 | 0.0 | 0.0 |
| | 0.0 | | -20.0 | 0.0 | 0.0 | 0.0 | 20.0 | 0.0 | |
| 3 | 0.0 | | 230.0 | 0.0 | 0.0 | 0.0 | -232.6 | 2.6 | 0.0 |
| | -42.7 | | 54.0 | 0.0 | 0.0 | 174.4 | 51.0 | 26.7 | |
| 4 | 0.0 | | 400.0 | 0.0 | 0.0 | 0.0 | -400.0 | 0.0 | 0.0 |
| | 57.6 | | 80.0 | 0.0 | 0.0 | 0.0 | -22.4 | 0.0 | |
| 5 | 119.1 | | 117.7 | 0.0 | 0.0 | 0.0 | 0.0 | 1.3 | 0.0 |
| | 210.8 | | 215.4 | -54.6 | 0.0 | 4.6 | 40.3 | 14.3 | |
| 6 | 0.0 | | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| | 0.0 | | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | |
| TOTALS | 3993.4 | | 3904.7 | 0.0 | 0.0 | 0.0 | 0.0 | 88.7 | 690.0 |
| | 942.3 | | 1239.4 | -395.5 | 0.0 | 947.2 | 0.0 | 1045.9 | |

APPENDIX IV

ENEL REPORT

The Computing Program SICRET
for
Adequacy Evaluation of a Composite Power System

1. FOREWORD

In planning studies of composite power systems (generation plus transmission) simulation methods based on the Monte-Carlo technique allow the system adequacy to be quantitatively evaluated even in the most complex cases.

The numerical adequacy indices can be quantified and introduced into the overall economic optimization of the system.

The SICRET program is intended for the study of a system including thermal and hydraulic generation and a transmission network of the meshed type.

It is mainly used during planning of transmission systems in order to verify their overall adequacy and the convenience of reinforcing some particular part of the network. It can be also used for the determination of the basic characteristics of the main transmission system components, such as overhead lines carrying capacity, substation layout, etc.

2. METHODOLOGY

The quantitative evaluation of the power system reliability in steady-state conditions (adequacy) is obtained through a "risk index" which expresses, in a probabilistic way, the comparison at given time between the steady-state generated and transmitted capacity with the components available at the time, and the load to be supplied. This index does not take into account the transients of the system when forced outages occur.

The static index obtained by the program is the yearly Expected Energy Not Supplied (EENS in MWh/Year) due to deficiency of the generation and/or transmission system, and takes into account the active power system constraints.

As to the "how", the system risk is broken down according to the main primal causes as follows:

- lack of total available generations capacity (risk due to lack of power);
- insufficient capability of lines and/or transformers (risk due to network overloading);
- insufficient local generating capacity in isolated areas or nodes due to line outages (risk due to network splitting or to node isolation).

All the above quoted indices can be obtained for the system as a whole and for each load bus, "where" the deficiency occurs.

The results may also be subdivided according to the meteorological conditions ("when") in which the load shedding occurs.

In order to evaluate the composite power system

adequacy, the Monte-Carlo simulation method is applied according to the followings:

- a) the reference period of time (one calendar year), during which the system behaviour is examined, is divided into elementary intervals, each lasting one hour. The assumption is made that the state of the system is constant during such intervals and that all its changes occur at the beginning of the interval;
- b) the power system state is characterized in each hour by the following elements:
 - i. the load of each network node;
 - ii. the availability of the system components (generators, lines, etc.) (1);
 - iii. the operation policies (unit commitment, load shedding, network connection, etc.)
- c) the changes in the system state are caused by:
 - i. the events that are generally random, and thus unpredictable by the operation staff, which cause variations of component availability and of the load demand;
 - ii. the dispatching actions in order to match the system state with the above mentioned changes. Such actions are carried out in order to obtain the best service quality (pure adequacy policies) or the best compromise between service quality and economy (mixed adequacy and economy policies).

The Monte-Carlo simulation is carried out considering a sufficiently wide number of time intervals ("sampled hours"). In each hour:

- a possible system configuration is randomly determined starting from the probabilistic availability distribution of each system component (generating units, lines, transformers, D.C.-A.C. conversion stations, etc.), and from the load diagrams;
- the action of the Dispatching Center is simulated by means of the more or less complex selected policies;
- the variables of interest in planning or designing stages (energy curtailments, frequency and amount of load-shedding, statistics of power flows in the lines, etc...) are evaluated using the linear formulation of the network equations (d.c. load-flow);

(1) As far as the availability of the overhead lines is concerned, it is possible to model the outage concentration due to the occurrence of adverse weather conditions and the common mode outages.

The total number of hours considered (sample size) must be representative of the reference period, usually fixed in a "calendar year", during which the system composition is assumed to remain constant, and so extended that the results of the Monte-Carlo simulation will have the required confidence.

The system situations and the order of their examination are obtained by random sampling of the hours of constitute the calendar year. This type of Monte-Carlo approach is usually called "non sequential" as compared to a "sequential approach" by which the hours of the year are examined in chronological order.

The "non sequential approach" is applicable when the power system, with thermal or hydraulic generation, is such that the primary energy sources (fuel or water) may be considered always available. On these assumptions, in fact, the system state in each hour does not depend on the occurrences and on the system operation in the preceding ones.

3. LOAD SHEDDING POLICIES

3.1 Lack of generation capacity

If the system is modelled as a "one area system" the load amount to be shed, in order to match demand and generation availability, is broken down among all load busses proportionally to their load.

If the system is subdivided in two or more areas (or subsystems), the total load to be shed is shared among areas proportionally to the relevant generation power unavailability; for each area the actual load shedding is done proportionally to the load of each bus.

3.2 Lack of transmission capacity

Should line or transformer overloads occur for a given system situation, remedial actions (redispatching and load-shedding) are modelled by taking into account both the fuel cost variation of each unit (in respect of the optimum dispatching) and the cost of the load curtailments necessary to eliminate such overloads.

In this case load shedding is performed accordingly to node-branch sensitivity coefficients, consistent with d.c. load-flow model, by using a linear programming technique.

4. OUTPUT OF THE PROGRAM

SICRET program supplies both System and local Adequacy Indices as follows.

A) SYSTEM INDICES

- * EENS (Expected Energy not Supplied)
- LOLP (Loss of Load Probability for the weekly peak hours)
- LOLE (Loss of Load Expectation in hours/year)

each subdivided by:

- main primal causes
 - Lack of generation capacity
 - Lack of transmission capacity
 - Node isolation or Network splitting
- weather conditions

- * YEARLY EXPECTED FUEL COSTS

For the total generation system and for each type of generating unit

B) LOCAL INDICES

- * EENS for each load bus and subdivided by primal causes
- * LINE CAPACITY MARGINAL GAIN (MWh/MW)
- * STATISTICS OF LINE AND TRANSFORMER POWER FLOWS
 - according to the economic power dispatching
 - after redispatching actions

4.1 Characteristics, size and computing resources

PROGRAM LIMITS:

500 busses
800 links
300 generators

COMPILER:

FORTRAN IV OR FORTRAN V - FORTRAN 77

COMPUTER:

IBM 3081/K
APOLLO DN-3000

CPU TIME

For analysing a composite system of 400 Nodes, 550 branches, 140 generating units, by 1000 randomly sampled system situations:

60 min. on APOLLO DN 3000 Work-station (1 MIPS machine)
3 min. on IBM 3081/K.

ADEQUACY EVALUATION: AN APPLICATION OF ENEL'S SICRET PROGRAM TO THE NEW BRUNSWICK POWER SYSTEM (*)

by

O. Bertoldi - S. Scalcino
R&D Department

L. Salvaderi
Planning Department

ENEL - Italy

ABSTRACT

The New Brunswick Power system was examined with the ENEL's Monte Carlo based program for composite system analysis. Several results are produced which are usable for planning purposes.

The effect of Interruptible Loads on system adequacy in the framework of Demand Side Management is studied with a view to evaluating them appropriately when adopting special tariffs for such industrial consumers.

The authors believe that the paper represents an example of real planning.

1. INTRODUCTION

The paper deals with the application of the SICRET program, set up by ENEL for its planning practice in the early seventies [1.2.3.4], to the evaluation of the adequacy of the New Brunswick Power (NBP) system in a given year of its future development.

The paper's framework is the activity of CIGRE W.G. 38.03 (T.F. 38.03.10) whose principal activity was the carrying out of a test case with different computing tools. In the paper, no discussion is made on the relative merits-demerits of Monte Carlo simulation and Contingency Selection methods since the subject has been debated in various previous papers. The reader may find an application, and the related comparisons, of these two approaches to IEEE RTS system in [5]. The papers [6-7] deal extensively with the features of the various computer programs available for composite-system adequacy evaluation and with the cautions with which the results should be interpreted.

The system data were assigned by NBP, after a cross discussion with ENEL experts.

(*) Already published as Paper WG 38.03/1 in the Volume of the CIGRE Symposium on Power System Reliability (Montreal September 16-18, 1991)

Two system structures have been examined:

- i) "Reference system";
- ii) "Improved System", corresponding to the reinforcement of the Reference system.

In order to compare the results obtained by the WG Members, for each of the two system structures two modelling situations have been proposed and examined:

- 1) Complete real system yearly behaviour, that is with various load levels, forced and planned outages of the generating units etc: this situation will be referred to as "Unconstrained";
- ii) Simplified behaviour under a set of technical prescriptions (only one load level, no maintenance etc.): this situation will be referred to as "Constrained".

Beginning with the existence of Interruptible Loads (ILs) in the NBP system, a methodology for their evaluation in the framework of Demand Side Management (DSM) has been introduced.

2. SYSTEM MODELLING

2.1 - Demand

Three types of loads have been considered:

- "Normal" loads, for a total of : 3045 MW
- Interruptible Loads (ILs) for a total of: 52 MW
- External sales (Es),
with obligation to supply : 808 MW
- Total : 3905 MW

To obtain the total load (PL) to be supplied, the transmission system losses (83 MW) were added.

As a result, the total system load, ILs included, is PL = 3988 MW

By assigning to the transmission system losses an approximate load factor, the total energy demand (EL) comes to 20209 GWh.

2.2 - Generation system

The NBP system is mixed; its capability at the winter peak load is as follows:

- Thermal Pg_{it} = 3472 MW
- Hydro Pg_{ih} = 650 MW
- Total internal Pgi = 4122 MW
- External resources Pge_x = 1338 MW
- Total capability Pg = 5460 MW

The hydro capability is lower than the hydro installed capacity, due to the energy limitations at the winter peak.

The total installed capacity is 5660 MW.

In addition, NB Power suggested to consider 4 fictitious units, for a total of 52 MW, in order to net the Interruptible Loads (ILs). Such units, 100% available, should be dispatched after the internal units but before the recourse to the external resources obtained through the interconnections. The impact of ILs on the risk index will be emphasized later.

2.3 - Reserve margin

The reserve margin (capability at winter peak-winter peak load), is internationally recognized as a parameter to make comparisons among various systems.

In our case, two reserve margins can be evaluated, according to the different modelling of the ILs:

- by taking into account just the capability Pg :
 $r = (Pg/PL-1) \times 100 = 36.9\%$;
- by taking into account also the contribution of the fictitious generators (Pg_{IL}), netting the ILs (Pg* = Pg + Pg_{IL}) :
 $r^* = (Pg^*/PL-1) \times 100 = 38.2\%$.

In both cases, the reserve margin is well higher than internationally found in the "normal practice".

2.4 - The effect of the Interruptible Loads

It is worthwhile to discuss the relationship between the system adequacy and the possibility offered to the system planner by the Interruptible Loads (ILs). In fact, the ILs option is increasingly promoted by utilities in the general framework of Demand Side Management (DSM). Customers sign contracts in which they agree to reduce, when asked, their demand to a predetermined level. Utilities/customers mutual needs and advantages should take into account on one side the generation (and transmission) constraints of the utility, on the other side the production constraints of the consumers.

Because of the nature of industrial processes, the mean duration and the frequency of the load curtailments, as well as their yearly duration and seasonal allocation, are key issues for ILs evaluation. The sequential Monte Carlo [2-6], by which the behaviour of each generating unit and the load are simulated hour by hour chronologically, is

needed.

When planning, two situations having the desired adequacy can be compared: the first one obtained with the ILs option, the second one with the traditional installation of peaking combustion turbines (CTs). The "value" of the ILs for the Utility can be obtained by the expenses (capital and fuel) of the CTs that can be deferred.

In the present application, the non sequential Monte Carlo was used, so that only the expected yearly duration of the generation system difficulties can be investigated and not their frequency and duration.

Despite this limitation, two cases have been run for the unconstrained situation, which can be assumed to represent the following planning policies:

1) NBP is satisfied with the system adequacy corresponding to Pg and PL and does not consider any special tariff and the "potential" ILs are shed after the recourse to the imports;

1i) NBP would consider to improve the system adequacy and has the option of installing CTs dispatched before the imports, or of agreeing special tariffs for the ILs consumers.

This methodology is general and can be applied when financial or siting constraints affect the expansion of generating system.

2.5 - Transmission system

The complete NBP system has been simulated with three voltage levels 345-230-138 kV, by a suitable equivalent of the loads (and losses) of the 69 kV network.

The total MW losses mentioned in par. 2.1 (83 MW), have been proportionally shared among the busses with loads higher than 100 MW and added to them.

The total number of busses with load is 53, out of the 88 simulated. Moreover, each load has been subdivided in 1 MW elementary loads so that the simulated loads are about 4000.

Two capability limits, "normal" and "emergency", have been assigned by NBP for the transmission lines. In our evaluations, the "normal" limits have been adopted. The most frequent values are 700/350/140 MW for 345/230/138 kV lines respectively.

2.6 - Failure bunching effect

The forced outage probability of NBP transmission lines during adverse weather has been assumed to be 9 times higher than in normal weather.

The occurrence of the adverse weather is uniformly distributed all along the year, without distinction among the seasons, for 730 hrs out of the total 8736 simulated.

2.7 - "Constrained" situation

The following simplifications were suggested by the Task Force in order to make easier the comparison of results obtained by using very differing methodologies:

- Load: only the yearly peak load, lasting 8736 hrs, examined. Annualized parameters, in particular risk indices, are obtained;
- Outages: no planned maintenance of the generating units is taken into account. Furthermore, no common mode outages for the pairs of 138 kV lines feeding the directly tapped loads are considered.
- Failure bunching: the relative duration of the adverse weather is supposed higher (15% of the year) than the above mentioned 730/8736= 8.4%, that is coincident with the winter period.
- Hydro dispatching: a simplified situation was assumed.

The above mentioned assumptions have contrasting effects on composite system adequacy.

In general the constrained situation does not provide any real help to a planning process based on a cost vs benefit approach.

3. RESULTS

3.1 - Unconstrained situation

3.1.1 - Risk indices and fuel costs

Adequacy risk indices and fuel costs have been obtained for the two system structures, as shown in Table I. The values in the table refer to the case when the ILs are considered "normal" loads, that is without any tariff reduction, and are shed after recourse to the imports.

Table I - Unconstrained situation (Energy Demand EL = 20209 GWh/yr): Risk Indices & Fuel Costs

| | System structure | |
|----------------------------|------------------------------|----------------------------|
| | Reference | Improved |
| EENS (MWh/yr) (p.u. EL) | 4458 2.2×10^{-4} | 1911 9×10^{-5} |
| - lack of G capacity | 411 | 411 |
| - lack of T capacity | 2479 | 12 |
| - node isolation | 1288 | 1288 |
| - network splitting | 280 | 280 |
| Fuel Costs (M\$/yr) | | |
| - Internal NBP | 403.8 | 404.7 |
| - NBP+Imports | 415.6 | 412.2 |

The following comments can be made:

1) In contrast with the presumption drawn by the high reserve margin, the contribution of the lack of capacity (HL1) to the total EENS is low but not excessively so. Its value (411 MWh/yr) corresponds to about 2×10^{-5} EL, which is a reasonable parameter for many systems having far lower reserve margins (roughly 22-25%) than the present one. This could be due to the fact that about 53% of the total capability is carried by only 8 unit having sizes of 6-16% of the total generating capability;

ii) The overall adequacy of the NBP composite system (HL2) is largely dictated by the effect of the transmission system, which increases the risk index by about one-half an order of magnitude compared to the values for the busbar system (HL1). Since the SICRET program utilizes d.c. load-flow, it is reasonable to expect that the system could also have some voltage problems and that the risk indices could be even higher than those calculated.

iii) Local reinforcement, namely the addition of two lines, the upgrading of another and the substitution of one transformer in the Courtenay Bay Area, provides considerable benefit, corresponding to a decrease of 2240(*) MWh/yr in the EENS. This figure could be used for a cost vs benefit comparison. At an average "unit risk cost" of 2 \$/kWh, it corresponds to a benefit of about US \$ 4.4 million/yr, that is, about US \$ 31 million. The fuel benefits correspond to US \$ 24 million. The resulting total amount of money represents the potential benefit that should be compared with the capital expenses necessary for the network improvements. This comparison was not possible since NBP did not supply the line costs.

iv) The system reinforcement has no effect on the EENS due to node isolation and network splitting since the improvements take place in busses not contributing to such phenomena.

3.1.2 - Interruptible Loads

Fig.1 shows the Load and Generation Duration Curves (LDC & GDC) without and with the fictitious units.




Fig. 1 - Load and Generation Duration Curves

Table II gives the main results concerning the ILS behaviour when applying the two said planning policies. When the special tariff option is not present ("No") the MWh/yr gives the contribution of the industrial consumers to the system risk index; when the tariff option is applied ("Yes") the MWh/yr represents the amount of energy that the industrial consumers are requested to disconnect in order to allow the utility to keep the planned adequacy.

Table II - Effect of DSM Clause on ILS supply (ILS demand: 454 GWh/yr)

| EENS (MWh/yr) by DSM clause | System structure | | | |
|-----------------------------|------------------|-------|---------------|-------|
| | Reference | | Improved | |
| | Tariff option | | Tariff option | |
| | No | Yes | No | Yes |
| - lack of G cap. | 132 | 17160 | 132 | 17160 |
| - lack of T capacity | 227 | 22080 | 2 | 2430 |
| - Total | 359 | 39240 | 134 | 19590 |

The impact on the ILS is higher in the Reference structure, the less adequate one, than for the Improved structure; the time of recourse to the ILS clause increases from 371 hrs to 745 hrs respectively.

For the Reference system, the existence of special tariffs for the industrial consumers, subjected to yearly curtailments of 326 hrs (in the case of a busbar system) and of 745 hrs (when network constraints are taken into account), would allow NPB to spare the capital cost and the fuel cost of 52 MW of CTs. It would also improve the generation system (HL1) adequacy since the relevant EENS will decrease from 411 to 279 MWh/yr.

The duration (745 hrs) of the yearly curtailments appears to be in rather good accord with current DSM practice. Using this result, some cost-benefit comparison could be attempted in order to make the appropriate agreements with the industrial consumers interested in such DSM strategy.

3.1.3 - G & T systems Interaction

To obtain a better idea of the influence of the network on the total composite system adequacy (HL2), the portion of EENS due to lack of transmission capacity in sound network situations has been obtained as follows:

Table III - Effect of Transmission System Capacity Constraints

| EENS (MWh/yr) | System structure | |
|--|------------------|----------|
| | Reference | Improved |
| - lack of G capacity | 411 | 411 |
| - lack of T capacity | 2479 | 12 |
| (out of which in sound network situations) | 1435 | 2 |

In the case of network sound and all generating units available, the load flow does not show any

overload. Consequently, the above mentioned EENS due to overloads (1435 MWh/yr for the Reference system) are clearly due to interference between the generator outages and local problems arising from insufficient transmission capacity.

3.1.4 - Other output

Table IV shows the contributions to the risk of the various buses, in decreasing order.

Table IV - Load point risk indices: EENS (MWh/yr) due to lack of transmission capacity

| BUS | | System structure | | |
|-------|--------|------------------|-------|---------------|
| | | Reference | | Improved EENS |
| | | EENS | % | |
| 1860 | MILD47 | 1364 | 55 | - |
| 1813 | C.BAY1 | 470(*) | 19 | 2 |
| 2496 | ROTHPR | 450 | 18 | - |
| 1807 | NEWCA1 | 115 | 5 | - |
| 1681 | IRVREF | 36 | 1.5 | - |
| | | | | |
| Total | | 2479 | 100 | 12 |

(*) Out of which 227 relevant to the ILS

Table V presents the index "Capability Marginal Gain" (CMG) of the transmission lines. CMG is defined as the potential decrease in load shedding, due to overloading of each line, obtained by increasing the capability limit of the concerned line by 1 MW.

Table V - Line marginal gains (MWh/MW)

| Line from BUS to BUS | System structure | |
|----------------------------|------------------|----------|
| | Reference | Improved |
| 1807(NEWCA1)-1969(MILBK1) | 15 | 0.4 |
| 1831(C.BAY1) -1860(MILD47) | 20 | - |
| 1837(C.COV1) -1860(MILD47) | 155 | 0.2 |

The contents of Tables IV and V confirm that the reinforced system was obtained with appropriate action.

Fig. 2 shows the distribution of the power flows, as resulting by the probabilistic combination of load levels, generation and network component availability and operation policies in one of the most loaded lines of the system. Reference [8] explains how such output may be used for system planning and component design studies.




Fig. 2 - Power flow duration curve on the line from Bus C.COV1 to Bus MILD47 (rating = 140 MW, power flow in normal situation = 131 MW)

3.1.5 - Computing resources

The Montecarlo Simulation has been carried out by means of groups of 1200 sampled hours each.

The statistical analysis of the EENS relevant to HL1 and HL2, obtained for each group, shows that the correlation is not so good ($r = 0.65$).

Consequently, one could not profit from the generalized regression techniques [9] aimed at improving the confidence limit of the results. Sufficient accuracy (standard deviation of 0.1 p.u.) has been reached with a sample size of 12.000 hours (10 groups).

CPU time requested (IBM 3090): 2 min. for adequacy indices evaluation, and further 1.5 min. for fuel costs and power flows statistics.

3.2 Constrained situation

Paragraph 2.7 indicated the reasons why the results of the constrained situation are not of great significance.

Nevertheless, the annualized indices obtained for the constrained situation are given in Table VI.

Table VI - Constrained situation: Risk Indices

| | System structure | |
|-------------------------|------------------|----------|
| | Reference | Improved |
| EENS (MWh/yr) | 93879 | 23555 |
| - lack of G capacity | 20874 | 20874 |
| - lack of T capacity | 71486 | 1162 |
| - node isolation | 569 | 569 |
| - network splitting | 950 | 950 |
| LOLE (G system)(hrs/yr) | 114 | 114 |

LOLE index has been computed by excluding fictitious generators and assuming that the load has standard deviation of 0.

The contribution to EENS of "node isolation" is lower than for the unconstrained system since the loads making the prevailing contribution are tapped directly on 138 kV lines. In the unconstrained situation common-mode failures are assumed for the two sections of such lines, while in the unconstrained situation this is not the case.

4. CONCLUSIONS

4.1 The ENEL's Monte Carlo based SICRET program, was applied to NBP system but no attempt was made to compare Monte Carlo with contingency evaluation methods since this subject has been covered many times.

4.2 After discussions with NBP to assess the proper system input data, the NBP was examined. The system under its actual behaviour, Unconstrained situation, has been investigated as in a real planning study. In particular the load diagram, generating unit forced and planned outages, overhead lines outages, weather effect were carefully modelled.

4.3 A constrained situation, involving simplified modelling of the system was also considered so as to allow comparison with the results obtained by other tools. It is felt that the corresponding annualized results cannot be profitably used for real system planning.

4.4 In view of the increasing attention being given by many utilities to Demand Side Management, the possibilities offered by the Interruptible Loads (ILs) has been presented. The power of the sequential Monte Carlo simulation and associated methodology used to determine the real "value" of the ILs option to the utility and to the consumers has been demonstrated. Some results, obtained with the non sequential Monte Carlo for NBP have been also discussed and the caution to be exercised when no frequency and duration parameters are obtained has been outlined.

4.5 The effects of the various models on the risk indices have been discussed. Various output, besides the adequacy risk indices and fuel costs, have been produced and their utilization for system planning and component design have been discussed.

4.6 The study is offered for discussions. In particular the authors would appreciate a feedback from NBP concerning the applicability of the presented methodology to the real planning of its system.

5. ACKNOWLEDGMENTS

The authors are indebted to Mr E.Giamperi and Mr. C. Tagliabue for their helpful contribution.

6. REFERENCES

[1] P. Noferi, L. Paris
 "Quantitative Evaluation of Power System Reliability in Planning Studies"
 IEEE Trans.PAS-91,N.2, March/April, 1972.

[2] P. Noferi, L.Paris, L. Salvaderi
 "Monte Carlo Method for Power System Evaluation in Transmission and Generation Planning"
 Proceedings of Annual Reliability and Maintainability Symposium, IEEE 75 CHO 918-3RQC, Washington, January 1975

[3] O. Bertoldi, L. Salvaderi, S. Scalcino
 "Monte Carlo Approach in Planning Studies: An Application to IEEE RTS"
 IEEE Trans. PS Vol 3.n.3 pp 1146-1154 Aug.1988

[4] O. Bertoldi, S. Scalcino, J.C. Dodu, J. Verseille, C.J. Ray, W.S. Farrant
 "Comparing Mathematical Models Used at CEGB, EDF and ENEL to assess Composite System Adequacy in the Planning Stage" - CIGRE 1990 Session, 38-102

- [5] R. Billinton, L. Salvaderi
"A Comparison Between Two Fundamentally Different Approaches To Composite System Reliability Evaluation"
IEEE Trans.PAS Vol 104, n.12, pp3486-3492, Dec 1985
- [6] R.Billinton, E. Khan
"A Comparison of Existing Computer Programs for Composite System Adequacy Evaluation"
CEA Spring Meeting, Toronto, Ontario, March 1989
- [7] L. Salvaderi, R. Allan, R. Billinton, J. Endrenyi, D. Mc Gillis, M. Lauby, P. Manning, R. Ringlee
"State of the art of Composite-System Reliability Evaluation" - CIGRE Session, Paper 38-104, Paris 26th August- 1st September 1990
- [8] L. Paris, F.Reggiani, M. Valtorta
"Possibilities To Increase Transmission Line Loading in Well Developed Electrical Networks"
CIGRE Session, Paper 31-13, 2-29 August, Paris 1974
- [9] G.C. Oliveira, M.V.F. Pereira, S.H.F. Cunha
"A Technique for Reducing Computational Effort in Monte-Carlo Based Composite Reliability Evaluation" - IEEE 1989 WM 174-4 PWRs

 *
 * SECRET PROGRAM *
 *

RELIABILITY STUDY ON

NEW BRUNSWICK POWER SYSTEM

BASE CASE - NOVEMBER 1990 - "Unconstrained Generalized Analysis"

COMMON MODE OUTAGES - ACTUAL LOAD DIAGRAMS - YEARLY ADVERSE WEATHER

HIGHER PRIORITY LEVEL FOR INTERRUPTIBLE LOADS IN CASE OF LOAD SHEDDING

TOTAL INSTALLED CAPACITY = 5659. MW
 PEAK POWER DEMAND = 3988. MW
 RESERVE MARGIN (at winter peak) = 36.9 %

MONTECARLO SIMULATION CARRIED OUT BY MEANS OF 1 SAMPLE OF:

10000 TESTS IN NORMAL WEATHER CONDITIONS

2000 TESTS IN ADVERSE WEATHER

RISK INDICES

| WEATHER CONDITION | LACK OF POWER | | ISOLATED NODE | | NETWORK SPLITTING | | LINE OVERLOAD | |
|-------------------|---------------|--------|---------------|--------|-------------------|--------|---------------|--------|
| | LOLE | LOLP | LOLE | LOLP | LOLE | LOLP | LOLE | LOLP |
| NORMAL | 2.6 | 0.0015 | 19.0 | 0.0024 | 2.6 | 0.0004 | 87.6 | 0.0539 |
| BAD | 0.2 | 0.0015 | 17.3 | 0.0240 | 1.7 | 0.0025 | 6.9 | 0.0535 |
| STORMY | 0.0 | 0.0000 | 0.0 | 0.0000 | 0.0 | 0.0000 | 0.0 | 0.0000 |

CURTAILED ENERGY (MWH/YEAR)

| WEATHER CONDITIONS | HOURS/YEAR | LACK OF POWER | ISOLATED NODE | NETWORK SPLITTING | LINE OVERLOAD | TOTAL |
|--------------------|------------|---------------|---------------|-------------------|---------------|--------|
| NORMAL | 8036.0 | 389.8 | 649.9 | 242.1 | 2290.2 | 3572.0 |
| BAD | 724.0 | 21.7 | 637.9 | 48.4 | 188.8 | 896.8 |
| TOTAL | | 411.4 | 1287.9 | 290.4 | 2479.1 | 4468.8 |

CURTAILED ENERGY (MWH/YEAR)

| * WHERE * | | * WHY * | | | | | TOTAL | TOTAL |
|-----------|-------|---------------|---------------|-------------------|---------------|--------|----------|--------|
| NO | NODE | LACK OF POWER | ISOLATED NODE | NETWORK SPLITTING | LINE OVERLOAD | | WEIGHTED | |
| * 1 | 169 | NSFICT | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | |
| * 2 | 1843 | LEPRAU | 3.5 | 0.0 | 0.0 | 0.0 | 3.5 | |
| * 3 | 1913 | BELOUN | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | |
| * 4 | 1800 | BEECHW | 5.9 | 0.0 | 0.0 | 0.0 | 5.9 | |
| * 5 | 1802 | GRFALL | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | |
| * 6 | 1809 | MACTOC | 3.0 | 0.0 | 0.0 | 0.0 | 3.0 | |
| * 7 | 1677 | CARACT | 6.1 | 0.0 | 0.0 | 0.0 | 6.1 | |
| * 8 | 1807 | NEWCA1 | 8.9 | 0.0 | 0.0 | 114.5 | 123.4 | |
| * 9 | 1811 | GRLAKE | 1.5 | 0.0 | 0.0 | 0.0 | 1.5 | |
| * 10 | 1813 | C.BAY1 | 8.1 | 0.0 | 0.0 | 243.6 | 251.7 | |
| * 11 | 1826 | DALHOU | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | |
| * 12 | 1836 | C.COV3 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | |
| * 13 | 1910 | IROQUB | 9.4 | 28.7 | 48.0 | 0.0 | 86.0 | |
| * 14 | 1965 | MILBK2 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | |
| * 15 | 1969 | MILBK1 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | |
| * 16 | 1812 | MONCTN | 11.5 | 0.0 | 0.0 | 0.8 | 12.2 | |
| * 17 | 1971 | PENFLD | 8.4 | 7.3 | 0.0 | 0.0 | 15.8 | |
| * 18 | 168 | ONSLO3 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | |
| * 19 | 700 | ORRING | 38.1 | 0.0 | 0.0 | 0.0 | 38.1 | |
| * 20 | 1844 | MURRCR | 2.1 | 0.0 | 0.0 | 1.2 | 3.4 | |
| * 21 | 1869 | MADHYQ | 13.0 | 0.0 | 0.3 | 0.0 | 13.3 | |
| * 22 | 1896 | TINKER | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | |
| * 23 | 9996 | EELHYQ | 13.0 | 0.0 | 0.0 | 0.0 | 13.0 | |
| * 24 | 1948 | EELRAL | 6.1 | 0.0 | 0.0 | 0.0 | 6.1 | |
| * 25 | 1847 | 112572 | 6.4 | 113.0 | 0.0 | 0.0 | 119.5 | |
| * 26 | 157 | MACCAN | 0.5 | 0.0 | 0.0 | 0.0 | 0.5 | |
| * 27 | 158 | ONSLO1 | 1.8 | 0.0 | 0.0 | 0.0 | 1.8 | |
| * 28 | 167 | ONSLO2 | 1.1 | 0.0 | 0.0 | 0.0 | 1.1 | |
| * 29 | 183 | SPRNGH | 0.8 | 0.0 | 0.0 | 0.0 | 0.8 | |
| * 30 | 1679 | LANCST | 15.1 | 72.5 | 0.0 | 2.3 | 89.9 | |
| * 31 | 1681 | IRVREF | 1.2 | 0.0 | 0.0 | 35.7 | 36.8 | |
| * 32 | 1712 | RICHBT | 6.7 | 582.9 | 0.0 | 0.0 | 589.6 | |
| * 33 | 1717 | 114963 | 4.3 | 58.7 | 0.0 | 21.2 | 84.2 | |
| * 34 | 1776 | 114981 | 1.5 | 17.9 | 0.0 | 1.0 | 20.5 | |
| * 35 | 1804 | 117562 | 0.9 | 12.1 | 0.0 | 0.0 | 13.0 | |
| * 36 | 1805 | EELRV1 | 1.1 | 0.0 | 0.0 | 0.0 | 1.1 | |
| * 37 | 1806 | BATHS1 | 5.8 | 0.0 | 0.0 | 0.0 | 5.8 | |
| * 38 | 1810 | MARYSV | 23.8 | 0.0 | 0.0 | 0.2 | 24.0 | |
| * 39 | 1817 | 111144 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | |
| * 40 | 1824 | 111528 | 2.1 | 138.9 | 0.0 | 0.0 | 140.9 | |
| * 41 | 1825 | MEMCOK | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | |
| * 42 | 1827 | KESWK1 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | |
| * 43 | 1828 | KESWK2 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | |
| * 44 | 1829 | BATHS2 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | |
| * 45 | 1830 | EELRV2 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | |
| * 46 | 1832 | 110553 | 0.5 | 33.7 | 0.0 | 0.0 | 34.2 | |
| * 47 | 1834 | OAKBAY | 8.6 | 94.2 | 26.4 | 16.3 | 145.5 | |
| * 48 | 1835 | 110421 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | |
| * 49 | 1837 | C.COV1 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | |
| * 50 | 1838 | SALBR2 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | |
| * 51 | 1839 | SALBR1 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | |
| * 52 | 1845 | NASH03 | 3.0 | 0.0 | 0.0 | 0.5 | 3.4 | |
| * 53 | 1846 | NASH12 | 3.0 | 0.0 | 0.0 | 0.0 | 3.0 | |
| * 54 | 1849 | STAND1 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | |
| * 55 | 1850 | SALBR3 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | |
| * 56 | 1851 | NEWCA2 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | |
| * 57 | 1852 | 110871 | 0.7 | 39.5 | 0.0 | 0.5 | 40.7 | |
| * 58 | 1854 | HARDRD | 0.2 | 5.6 | 0.0 | 0.0 | 5.8 | |
| * 59 | 1860 | MILD47 | 0.8 | 0.0 | 0.0 | 1363.6 | 1364.4 | |
| * 60 | 1861 | DOAKST | 17.1 | 0.0 | 75.9 | 0.0 | 93.0 | |
| * 61 | 1862 | MILD65 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | |
| * 62 | 1863 | 119042 | 2.1 | 0.0 | 0.0 | 0.0 | 2.1 | |
| * 63 | 1865 | 111036 | 0.1 | 0.0 | 0.0 | 0.0 | 0.1 | |
| * 64 | 1866 | EELRV3 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | |
| * 65 | 1867 | EDMST3 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | |
| * 66 | 1868 | STAND3 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | |
| * 67 | 1900 | NORTN3 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | |
| * 68 | 1901 | NORTN1 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | |
| * 69 | 1907 | EDMST1 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | |
| * 70 | 1908 | 114084 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | |
| * 71 | 1909 | IROQUA | 7.9 | 0.0 | 113.5 | 0.0 | 121.5 | |
| * 72 | 1915 | BATHS3 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | |
| * 73 | 1916 | NEWCA3 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | |
| * 74 | 1928 | 110684 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | |
| * 75 | 1930 | 1126MP | 7.2 | 82.7 | 0.0 | 0.0 | 89.9 | |
| * 76 | 1945 | 119024 | 0.2 | 0.0 | 0.0 | 0.1 | 0.4 | |
| * 77 | 1946 | 112408 | 0.2 | 0.0 | 0.0 | 0.1 | 0.4 | |
| * 78 | 1964 | MBNKTP | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | |
| * 79 | 2495 | NBIPC1 | 2.0 | 0.0 | 0.0 | 0.0 | 2.0 | |
| * 80 | 2496 | ROTHPR | 3.2 | 0.0 | 0.0 | 450.1 | 453.3 | |
| * 81 | 2497 | BRMINE | 2.5 | 0.0 | 0.0 | 0.0 | 2.5 | |
| * 82 | 2498 | NBIPC2 | 4.7 | 0.0 | 0.0 | 0.0 | 4.7 | |
| * 83 | 2499 | CONSBH | 2.9 | 0.0 | 0.0 | 0.0 | 2.9 | |
| * 84 | 91813 | INTER1 | 25.5 | 0.0 | 0.0 | 227.4 | 252.9 | |
| * 85 | 91847 | INTER2 | 30.6 | 0.0 | 0.0 | 0.0 | 30.6 | |
| * 86 | 91910 | INTER3 | 38.3 | 0.0 | 26.4 | 0.0 | 64.7 | |
| * 87 | 91948 | INTER4 | 38.3 | 0.0 | 0.0 | 0.0 | 38.3 | |
| * 88 | 1803 | KESWK3 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | |
| * TOTAL | | | 411.4 | 1287.9 | 290.4 | 2479.1 | 4468.8 | 8551.0 |

APPENDIX V
ELECTRICIDADE DE PORTUGAL REPORT

THE NEW BRUNSWICK SYSTEM SIMULATION
EXERCISE OF CIGRE WG 38.03.10

Contribution of Electricidade
de Portugal with the ZANZIBAR model

by

JOÃO RICARDO
EDP

PAULO BÁRCIA
UNL

(PORTUGAL)

Keywords: System and network planning - Composite models-New Brunswick system-ZANZIBAR model.

I also am indebted to my family, who lost several weekends because of "the damned work for CIGRE".

Abstract - This paper resumes the results obtained with Zanzibar model on the WG 38.03.10 exercise of simulation of the New Brunswick system with several composite simulation models. The paper also gives a broad idea of the model simulation capabilities.

2 - THE ZANZIBAR model - A short functional description.

1 - Introduction

1.1 - The present document is the final report of the NB system simulation exercise carried out at Electricidade de Portugal, S.A., using the ZANZIBAR model. This report describes the main lines of the model, the input/output facilities of the program and the results obtained for the NB system for HL1 and HL2 cases.

2.1 - Zanzibar is a computer program for the assessment of power system adequacy. It has been designed and implemented at Electricidade de Portugal, EDP in the early 80's, by Dr. Paulo Bárcia to be used as a transport network planning tool. Some improvements have been made so far, enhancing its capabilities.

1.2 - Acknowledgments are in order for several people who helped me in this work. The first goes to Dr. Paulo Bárcia, the author of ZANZIBAR in the late 70's (first results in 79), early 80's first upgrade in 82). Dr. Paulo Bárcia made all necessary code changes to support special load types in this particular exercise.

In the following lines, we present a summary of the present features of this program.

2.2 - Zanzibar is a composite model, simulating both the power generators as well as the transport network. Monte Carlo technique is employed to produce a non-sequential simulation of one year of system operation.

The second goes to Eng^o Jorge Morais who helped in the early stages of the study, and to Mrs. Isabel Ferrão and Ana Valeriano who typed all the successive versions of this report.

As for generation, different types of power stations can be represented. Special emphasis has been given to the simulation of the hydro component, which, in Portugal, accounts for more than 45% of total generated energy. Hydro power stations are simulated as follows:

And last, but not the least, acknowledgments are also due to WG 38.03.10, and, in special, to Bill Marshall, who prepared the first set of data and has been always ready to answer our questions about data and modeling details.

. Three hydrologic situations are possible: wet, intermediate and dry. Each one has its own given probability of occurrence.

. Three year seasons are possible: winter, intermediate and summer. For our climate, their probability is 0,5, 0,25 and 0,25, by the same order.

. Each hydro power stations has a maximum given energy cost: for each combination of hydro

João RICARDO - Electricidade de Portugal, Av. EUA, 55 - 1708 LISBOA Telef. (1)8470212 Telex 18874-EDP RE P

Paulo BÁRCIA - Universidade Nova de Lisboa, Faculdade de Economia, Travessa Estevão Pinto - 1800 LISBOA

situation/season, a multiplier $1 \ll 0$ affects that cost to define its effective cost. Therefore, each hydro power station has nine equivalent production costs, one of each is chosen for each Monte Carlo case.

- . In each study, a complete year is simulated. Each power station has a maximum possible producible energy. In practice, a $\pm 10\%$ deviation is accepted.

Several different generators can be simulated at each node. Maximum and minimum power output limits can be specified. Total unavailability can be broken down into two components, non-programmed, and programmed. The last one can be made to occur only in favourable conditions regarding year season and/or load diagram step and/or hydrologic situation. One only rule can be specified for all generators and another to network elements: different percentages of total unavailability can be assigned as non-programmed for generators and network elements.

Thermal generators can be simulated in a similar way in respect to unavailability. Their cost function can be any linear piecewise convex function.

Loads are represented either as constant loads or as variable loads. The variable ones are defined by a 5 step diagram. The probability of occurrence of each diagram step is conditional to the year season, ie, a matrix of 15 conditional probabilities (5 load steps x 3 year seasons) is defined for all variable loads. The curtailment cost function can be given for any load, as a specific linear piecewise concave function.

Network elements (lines, transformers, etc.) are represented in the usual way. As was said, distinction can be made between programmed and non-programmed unavailability with the same facilities as for generating units. Common failures can be considered, defining groups of lines/transformers that will be put down should any other element in the same group become unavailable.

A global overview of how the program operates can be given as follows:

a - Data reading and preliminary calculations - dynamic ordering and factorization of admittance matrix, stratification, calculations, etc. All network data handling uses sparsity techniques.

b - In each Monte Carlo case:

- . Year season and hydrologic situation are sampled. Load diagram step is also sampled, conditional to the year season. Cost of each hydro power station can then be calculated, according with year season, hydrologic situation and accumulated v.s. maximum year producible energy.
- . Availability situation of each power station and network element, including loads, is assessed.
- . Productions in power stations are defined with an optimisation procedure, minimising production and network "losses" plus cost of

curtailed energy, taking into consideration MW limits of all elements. A DC approach is used, but real losses are simulated changing slightly loads in adjacent busbars of each line. The program can take into consideration any given set of lines or transformers to add contingency restrictions.

The optimisation problem is solved using the dual problem with limited variables and also a technique of relaxation, using an iterative constraint search.

2.3 - Outputs of all Monte Carlo simulations are stored. At the end, several outputs and statistics are available.

The program can also be used to perform other studies as DC load flows and optimal productions plans taking into consideration network MW restrictions.

A list of some possible outputs of Zanzibar is given:

- For each load: average, standard deviation (SD) and frequency of load curtailment.
- For each generator: average and SD of output; effective unavailability in Monte Carlo simulations; total (1 year) generated energy.
- For network branches: average and frequency of power flow in each direction (sending \rightarrow receiving and receiving \rightarrow sending); average marginal deficiency, ie, in how much total MW curtailment would have been reduced, if MW rating of each branch was increased by 1 MW.
- For each area and for the whole system: reserve margin, average and SD of "losses", average, SD and frequency of EENS, both total values and partial values due to failures of network and generating capacity.

These are standard printouts. More detailed information is available on request:

- Histograms of generators, loads, flows, load curtailment (in individual loads or global) and branch "losses".
- Detailed outputs of particular Monte Carlo case namely those where load curtailments have occurred or those which the model was unable to solve.

It is possible to go back to each of those cases, analyse it in detail to see what actually has been responsible for the load curtailment and make further analysis. Interface is provided for AC load flow.

- A companion program, Zangraf, can produce geographic outputs of load flow.
- Special outputs are possible such as admittance matrices, initial load flow solutions, simplex tableaux, simplex and stratification related data, etc.

3 - The ZANZIBAR model: load-curtailment philosophy

For each Monte-Carlo case, the program solves a linear programming (LP) problem which consists of minimising the total production cost in power

stations plus the total load curtailment cost subject to:

- Network equations in linear (DC) approximation.
- Bounds on power station output.
- Bounds on load curtailment at each node.
- Bounds on branch flows.

So, the load curtailment philosophy is the one imposed by the solution of the above optimisation problem.

Note that, in order to avoid degeneracies in the LP, costs are perturbed with small noise, so that costs will be all slightly different, even if some of them are given of equal value.

This perturbation changes from one Monte-Carlo case to another.

Origin classification of curtailed energy between generation and network follows a very simple criterium.

For each Monte-Carlo simulation let PA be the total production capacity available and LD be the total load demand; the curtailment due to generation is defined as $CG = LD - PA$.

The total curtailment, CT, is the sum of the load curtailed at each busbar. Then the curtailment due to the transmission network, CN, is defined as $CN = CT - CG$.

Of course this is only meaningful for the whole system and not for each area individually.

4 - Simulation of the New Brunswick case with ZANZIBAR. Some details in system representation.

In other parts of this paper we describe, in detail, both the simulation and representation facilities of ZANZIBAR. This gives a detailed overview of the program in general functional terms.

Here, we address some general representation and simulation details regarding the NB case. Taking, as reference, the degree of system representation subjacent to the "November data set", some approximations had to be done, since ZANZIBAR, at its present state, is not able to cope, in some aspects, with such representation level.

4.1 - Zanzibar does not perform a sequential one year simulation. It uses a non-sequential approach.

4.2 - Zanzibar does not use AC representation, although losses are approximated by changing loads in a inner iteration with DC optimal flow, for each Monte Carlo case, according with calculated losses from DC branch flows.

4.3 - As a consequence of 4.1, it is not possible to assign scheduled unavailabilities to exact weeks along the year. Also, it is not possible to simulate the "weather condition modelling" changing non-programmed unavailability according

with year season.

Recalling that ZANZIBAR considers three year seasons, three hydrologic year conditions and 5 load diagram steps, what has actually been done is:

. To specify a percentage of total unavailability programmed:

50% for generators

0% for lines and transformers.

. To allow thermal programmed maintenance only in summer and not in the highest load diagram step.

. Unavailability is equally distributed all over the year for lines and transformers.

4.4 - All variable loads are simulated according with the "type II seasonal load model" - page 11/14 of "November data set". One only model is possible for all loads. Nevertheless, to simulate more closely the two 200 MW "type 4 - HQ contract" at 1869 and 9996 busbars, Dr. Bárcia changed the code to cope with these situations. The loads are active with 200 MW only in winter and at the two higher load diagram steps and in half of the Monte Carlo cases.

All constant loads of constant part of variable loads are correctly simulated.

4.5 - Hydro power stations are simulated as "seasonal thermal-equivalent hydro model" of page 13/14 of "November data set".

4.6 - In all other aspects, data is exactly the one referred in the "November data set". All details treated in various telexes between Mr. William Marshall and us were considered. We emphasise the fact normal MVA rating have been considered for lines and transformers.

4.7 - It is worth nothing that the DC load-flow or the optimisation procedure do fail to solve some Monte Carlo cases. This happens for fifty cases, more or less, in a study of 5 thousand. The final results for the study is therefore affected by these "forgotten" cases which would make those results worse.

5 - New Brunswick system simulations with ZANZIBAR The HL1 equivalent case

In this case, the HL2 "Constrained Base Case" was run with the modifications suggested by Mr. William Marshall so that all network elements (lines and transformers) are 100% available with a very high MVA rating. This last value was set to 9000 MVA throughout for both lines and transformers.

Also, the MW powers of the hydro power stations have been corrected.

Two runs have been made, one with 4000 and the other with 8000 Monte Carlo simulations. The results show only small differences, as expected, since lines and transformers - the elements with small probability of failure - are 100% available. The figures of the 8000 case will be considered in this documented.

Main results are the following:

| | |
|--------------------------|----------------|
| * Total generated energy | : 34894.4 GW.h |
| " consumed | : 34190.8 |

Total consumed + curtailed : 34206.3
 Total curtailed energy : 15,5 GW.h
 Equivalent interr. time : 3h 57m 41s

All curtailed energy is due to generation failure

* Mean load curtailment
 * Average deficiency : 1,766 MW
 Standard dev. of estimator : 0,286 MW
 Frequency of curtailment : 0,925%

These figures are for the whole system, including alien (non NB) busbars.

* Installed power : 5513 MW
 Peak load : 3904 MW
 % reserve : 41,2%

"Losses" in transmission

Average : 80,3 MW
 SDE : 0,88 MW

These figures are for the whole system.

(Remember that in ZANZIBAR, "losses" are simulated with a DC approach, ie, are not the real losses, but fall below the true value).

Please note:

1 - Since all branches in the network have "infinite" MVA rating, it is meaningless to present values of curtailment at the individual busbars.

2 - Since the network elements are not at stake, both from the point of view of reliability and in what concerns rating limitations, the optimization was always successfully completed in all 8000 simulations. There is not any "dropped situation", as in inevitable whenever important network limitations make optimization LP impossible to solve.

6 - New Brunswick system simulation with ZANZIBAR. The HL2 constrained case.

We remember that in the constrained case:

Load is constant at all busbars.
 No modelling of maintenance is done.
 The hydro power stations are always at top power: Mactaquac 500 MW, Beechwood 80 MW and Grand Falls 30 MW.
 No scheduled maintenance is considered.
 Common mode failures are not considered.

Main results obtained with ZANZIBAR running 32 000 Monte Carlo simulations follow. We start with the

system global indices, then figures regarding expected curtailment at busbars and last we show what network elements are imposing restrictions. This last item is given, for each branch, by the "average marginal deficiency" (AMD) value, i.e. the number of watts by which load curtailment would have been reduced, should the rating of the network element had been increased by 1 megawatt.

Both base case and improved case results are presented.

6.1 - Global system load curtailment values

| Situations: | Base | Network improvement |
|-------------------|-------|---------------------|
| Total | | |
| Average (MW) | 5,67 | 1,99 |
| STD (MW) | 0,157 | 0,140 |
| Frequency (%) | 20,4 | 1,80 |
| EENS (GW.h) | 50,8 | 17,4 |
| Due to generation | | |
| Average | 1,69 | 1,67 |
| STD | 0,136 | 0,135 |
| Frequency | 0,937 | 0,924 |
| EENS | 15,1 | 14,6 |
| Due to network | | |
| Average | 3,98 | 0,316 |
| STD | 0,085 | 0,039 |
| Frequency | 19,5 | 0,887 |
| EENS | 35,7 | 2,8 |

Notes:

- * STD - Standard deviation of average estimator.
- * The rationale for splitting EENS down to "due to generation" and "due to network" explained elsewhere in this report.
- * Figures are for the whole represented system, which includes the external (non NB) equivalents.

6.2 - Busbar curtailment data

All busbars having at least one situation of load reduction imposed by system failure are listed on Table I. On the top of the list come the busbars which better improved with network reinforcement.

Situation at busbars 1860, 1813, 1910, 1717, 1946, and 1679 show sharp improvement. Nevertheless, some others have high values of curtailment frequency.

TABLE I
HL2 CONSTRAINED CASE

BUSBAR LOAD CURTAILMENT

| | Base Case | | | Netw. Imp. | | |
|----------------|-------------|----------------|------------|-------------|----------------|------------|
| | AVC (MW) | STD (MW) | FRQ (%) | AVC (MW) | STD (MW) | FRQ (%) |
| Busbars | | | | | | |
| MILD47-1860 | 13,8 | 4,0 | 19 | 14,9 | 4,6 | 0,085 |
| C.BAY1-1813 | 33,8 | 17 | 3,3 | 179 | 32 | 0,085 |
| IROQUB-1910 | 104 | 33 | 0,11 | | No curtailment | |
| PENFLD-1971 | 35,6 | 9,8 | 0,038 | 32,9 | 4,1 | 0,019 |
| 114963-1717 | 45,2 | 26 | 0,17 | 67,4 | 27 | 0,010 |
| 112408-1946 | 4,93 | 0,26 | 0,35 | 6,58 | 0,14 | 0,29 |
| 114981-1776 | 17,1 | 4,5 | 0,18 | 18,6 | 5,5 | 0,11 |
| DAKBAY-1834 | 55,4 | 8,4 | 0,24 | 56,9 | 7,6 | 0,19 |
| LANCST-1679 | 61 | 27 | 0,10 | 69 | 23 | 0,088 |
| 110871-1852 | 21,9 | 0 | 0,006 | 21,9 | 0 | 0,006 |
| 110553-1832 | 8,9 | 2,1 | 0,10 | 9,1 | 2,1 | 0,10 |
| 1126MP-1930 | 48,2 | 13 | 0,19 | 35,8 | 13 | 0,17 |
| 117562-1804 | 14,9 | - | 0,003 | 14,9 | - | 0,003 |
| 111528-1824 | 18,4 | 3,5 | 0,063 | | No curtailment | |
| 119042-1863 | 28,8 | 15 | 0,26 | 38,2 | 15 | 0,27 |
| 119024-1945 | 6,01 | 0,089 | 0,013 | 6,6 | 0 | 0,025 |
| BATHSI-1806 | 103 | 46 | 0,25 | 107 | 43 | 0,25 |
| DOAKST-1861 | 4,4 | 1,8 | 0,54 | 4,5 | 1,8 | 0,55 |
| BEECHW-1800 | 23,7 | 2,1 | 0,091 | 23,4 | 3,3 | 0,11 |
| CARAQT-1677 | 91,5 | 44 | 0,13 | 88,0 | 45 | 0,13 |
| HARDRD-1854 | 4,5 | 1,2 | 0,022 | 4,8 | - | 0,003 |
| IROQUA-1909 | 104 | 33 | 0,11 | 107 | 33 | 0,10 |
| MARYSV-1810 | 124 | 56 | 0,038 | 124 | 56 | 0,038 |
| MACTQC-1809 | 20,7 | 0 | 0,013 | 20,7 | 0 | 0,013 |
| MONCTN-1812 | 157 | 81 | 0,40 | 150 | 81 | 0,43 |
| NASH03-1845 | 12,6 | 2,0 | 0,11 | 19,1 | 1,8 | 0,091 |
| NEWCA1-1807 | 36,8 | 40 | 0,069 | 35,7 | 41 | 0,072 |
| RICHTB-1712 | 34,9 | 16 | 0,088 | 33,4 | 14 | 0,091 |
| EELRAI-1948 | | No curtailment | | 93 | 25 | 0,078 |

Notes:

AVC - Average curtailment (whenever curtailment does occur),
in MW.

STD - Standard deviation of AVC estimator in MW.

FRQ - Curtailment frequency, in percent.

6.3 - Lines imposing load curtailment

Network elements that impose load curtailments by their low MW rating, in any of the Monte Carlo simulations, are listed below. Their AMD is also given. All network branches in this situation are lines.

| Branch | AMD (W/MW) | |
|-------------------------|------------|------------------|
| | Base Case | Improved Network |
| C.COV1-1837/MILD47-1860 | >1000 | 11,7 |
| NEWCA1-1807/MILBK1-1969 | 21,7 | 3,14 |
| 114981-1776/NORTN1-1901 | 12,3 | 4,87 |
| NORPSR-1747/NORTN1-1901 | 7,21 | 0 |
| IRVREF-1681/C.BAY1-1813 | 5,99 | 0 |
| C.COV1-1837/MILD65-1862 | 0,858 | 0 |
| 110684-1928/MILBK1-1969 | 0,055 | 0 |
| MACTQC-1809/DOAKST-1861 | 104 | 105 |
| RICHBT-1712/MONCTN-1812 | 2,43 | 2,50 |
| RICHBT-1712/NEWCA1-1807 | 1,76 | 1,77 |
| GRLAKE-1811/MONCTN-1812 | 0,915 | 1,22 |
| SALBR1-1839/119024-1945 | 0,605 | 0,605 |
| SALBR1-1839/112408-1946 | 0,280 | 0,280 |
| IRVREF-1681/NORTN1-1901 | 0 | 10,0 |

Last, we note that the line, 1809/1861 is also heavily loaded and has a very high AMD. This situation is not improved with the proposed network addition.

As a last comment, we refer that the total EENS in the base case is lower than the one mentioned in the New York meeting. Only two changes have been made in the data: maximum MW power in hydrostations (Beechwood - 1800 and Mactaquac - 1809) have been reduced to 80 MW and 500 MW and transformer ratings were set to "normal rating" instead of "short overload values". We recall that these changes were suggested by Mr. William Marshall for the constrained case.

The second change is meaningless in what EENS is concerned, since, even with reduced MW ratings (for instance, 0,93 x normal MVA rating) no transformer is responsible for any additional EENS.

As a matter of fact, the reduction of rated power of those hydro stations do account for a reduction of EENS in this constrained case. The justification must come from the fact that as hydro power is mobilised in areas near the loads, therefore, with better chances to reach loads, in spite of the heavy transmission problems faced.

The exact AMD value for the first line in the base case is not known because the printout field has only room for three integer digits. We know, for sure, that it is greater than 1000 W/MW.

The situation of the first 5 lines has a clear improvement with the network reinforcement. The first two lines are heavily loaded in the base case. Even with the network improvement, average load is still high. Note that the new line addition 1681/1901 has a considerable load from busbar 1681 to 1901.

TABLE II
HL2 CONSTRAINED CASE
Branch Flows

| Busbar I J | | Rating MW | — Base Case — | | | | — Improved Network — | | | |
|---------------|-----|--------------------|---------------|----------|----------|----------|----------------------|----------|----------|----------|
| | | | AV MW | FRQ % | AV MW | FRQ % | AV MW | FRQ % | AV MW | FRQ % |
| | | | I → J | J ← I | | | I → J | J ← I | | |
| 1837/1860 | 140 | 124 | 99,96 | 15,9 | 0,04 | 96 | 99,94 | 63,4 | 0,06 | |
| 1807/1969 | 140 | 10,9 | 0,54 | 111 | 99,46 | 8,9 | 0,73 | 93,3 | 99,27 | |
| 1776/1901 | 140 | 23,2 | 0,15 | 77,5 | 99,85 | 0 | 0 | 86,3 | 100 | |
| 1809/1861 | 190 | 168 | 100 | 0 | 0 | 169 | 100 | 0 | 0 | |
| 1681/1901 | 140 | — Not considered — | | | | 14 | 71,2 | 10 | 28,8 | |

Notes:

AV - Average flow, in MW.

FRQ - Frequency in %.

→ Flow from busbar I to busbar J, in MW.

← Flow from busbar J to busbar I, in MW.

7 - New Brunswick system simulation with ZANZIBAR. The HL2 unconstrained case.

As for the HL2 constrained case, 32 000 Monte Carlo simulations were run to reach the results that follow. From those, more or less 140 simulations have been dropped due to optimization problems.

7.1 - Global system data

| | |
|--------------------|---------|
| Installed capacity | 5713 MW |
| Peak load | 3879 MW |
| Reserve margin | 47,3 |
| "Losses" Average | 38,3 MW |
| STD | 0,42 MW |

Number of hydrologic situations considered 1 (intermediate)

Probability of each year season 1/3

Load diagram:

| Steps | Conditional probabilities | | |
|-------|---------------------------|---------|--------|
| | Summer | Interm. | Winter |
| 0,90 | 0 | 0 | 0,13 |
| 0,70 | 0 | 0,09 | 0,42 |
| 0,50 | 0,14 | 0,63 | 0,36 |
| 0,30 | 0,81 | 0,28 | 0,09 |
| 0,10 | 0,05 | 0 | 0 |

Scheduled maintenance for generators

- forbidden in the 0,9 load step
- allowed in Summer but not in intermediate and Winter and seasons.

See point 2.3 of "The ZANZIBAR model" for the definition of "losses" within a DC approach.

7.2 - Global system load curtailment values

| Situations: | Base | Network improvement |
|--------------------------|-------|---------------------|
| Total | | |
| Average (MW) | 0,611 | 0,237 |
| STD (MW) | 0,056 | 0,048 |
| Frequency (%) | 1,48 | 0,292 |
| EENS (GW.h) | 5,4 | 2,1 |
| Due to generation | | |
| Average | 0,171 | 0,170 |
| STD | 0,054 | 0,054 |
| Frequency | 0,079 | 0,079 |
| EENS | 1,5 | 1,5 |
| Due to network | | |
| Average | 0,440 | 0,067 |
| STD | 0,030 | 0,012 |
| Frequency | 1,41 | 0,217 |
| EENS | 3,9 | 0,6 |

Notes:

- * STD - Standard deviation of average curtailment estimator

* The rationale for splitting total EENS down to "due to generation" and "due to network" is explained elsewhere in this report (see "The ZANZIBAR model: load curtailment philosophy").

* Figures are for the whole represented system, which includes the external (non NB) equivalents.

7.3 - Busbar curtailment data

Busbars having at least one situation of load curtailment in the 32 000 Monte Carlo situations are listed in Table III. The first busbars are those whose situation improved after the network reinforcement.

TABLE III
HL2 UNCONSTRAINED CASE
BUSBAR LOAD CURTAILMENT

| | Base Case | | | Netw. Imp. | | |
|----------------|-------------|----------------|------------|-------------|----------------|------------|
| | AVC (MW) | STD (MW) | FRQ (%) | AVC (MW) | STD (MW) | FRQ (%) |
| Busbars | | | | | | |
| MILD47-1860 | 15,5 | 3,7 | 1,2 | - | no curtailment | - |
| 114963-1717 | 35,9 | 18 | 0,035 | - | no curtailment | - |
| C.BAY1-1813 | 33,6 | 13 | 0,55 | 57,0 | 11 | 0,035 |
| LANCST-1679 | 49,5 | 9,2 | 0,032 | 29,2 | 0 | 0,013 |
| HARDRD-1854 | 0,48 | 0 | 0,032 | 0,48 | 0 | 0,025 |
| BATHS1-1806 | 54,2 | 25 | 0,028 | 100 | 13 | 0,019 |
| OAKBAY-1834 | 24,1 | 6,4 | 0,116 | 27,4 | 6,0 | 0,091 |
| PENFLD-1971 | 21,6 | 13 | 0,025 | 21,6 | 14 | 0,019 |
| 110871-1852 | 12,4 | 0 | 0,013 | 95 | - | 0,003 |
| 110553-1832 | 1,0 | 0 | 0,022 | 1,0 | 0 | 0,025 |
| 117562-1804 | 6,5 | 1,0 | 0,013 | 6,5 | 1,0 | 0,013 |
| 1126MP-1930 | 29,8 | 6,4 | 0,041 | 29,8 | 6,4 | 0,041 |
| 112572-1847 | 24,5 | - | 0,003 | 24,5 | - | 0,003 |
| 119042-1863 | 57,0 | 4,6 | 0,013 | 57,0 | 4,6 | 0,013 |
| 119024-1945 | 0,66 | 0 | 0,010 | 0,66 | 0 | 0,010 |
| BEECHW-1800 | 19,1 | 1,9 | 0,019 | 18,7 | 2,0 | 0,019 |
| EELRA1-1948 | 59,6 | 12 | 0,022 | 72 | 12 | 0,022 |
| IROQUA-1909 | 72,5 | 16 | 0,019 | 72 | 16 | 0,019 |
| MARYSV-1810 | 82,5 | 48 | 0,013 | 89,3 | 42 | 0,013 |
| NASH03-1845 | 11,6 | 5,1 | 0,016 | 10,9 | 5,9 | 0,016 |
| NEWCA1-1807 | 132 | 22 | 0,022 | 161 | 22 | 0,022 |
| RICHT-1712 | 98,3 | - | 0,003 | 98,3 | - | 0,003 |
| DOAKST-1861 | 34,0 | 26 | 0,028 | 26,3 | 22 | 0,035 |
| 114981-1776 | 14 | 0 | 0,010 | 24,4 | 0 | 0,013 |
| MONCTN-1812 | 138 | 56 | 0,032 | 113 | 59 | 0,041 |
| 112408-1946 | - | no curtailment | - | 0,66 | 0 | 0,013 |
| MACTQC-1809 | - | no curtailment | - | 17,3 | 2,0 | 0,010 |
| MILD65-1862 | - | no curtailment | - | 10,4 | 2,6 | 0,006 |

Notes:

AVC - Average curtailment (whenever curtailment does occur), in MW.

STD - Standard deviation of AVC estimator in MW.

FRQ - Curtailment frequency, in percent.

The global situation, in the base case, is much better than in the constrained case, since loads, although with the same peak MW, are now modulated taking lower MW values most of the time.

Busbars that most benefit from network reinforcement are MILD47-1860 and C.BAY-1813. From curtailment frequencies of 1, 2% and 0,55%, reinforcement reduces those values to 0% and 0,035%. Other busbars like 1679, 1717, 1854, 1806, 1834, 1971 and 1852 show also some improvements.

Some other busbars (see end of list) exhibit higher curtailment frequencies, but with low absolute values.

7.4 - Lines imposing load curtailment

A few lines exhibit positive AMD. Only one has a triple digit AMD value in the base case, C.COV1-1837/MILD47-1860, indicating that this line is the cause for significant load curtailment. This situation is solved by the proposed network reinforcement, turning the AMD value of 235W/MW to zero.

Lines with non zero AMD are the following:

| Branch | AMD (W/MW) | |
|-------------------------|----------------|------------------|
| | Base Case | Improved Network |
| C.COV1-1837/MILD47-1860 | 235 | 0 |
| NORPSR-1747/NORTN1-1901 | 4,4 | 0 |
| MARYSV-1810/GRLAKE-1811 | 0,1 | 0 |
| 114981-1776/NORTN1-1901 | 0,44 | 0 |
| NEWCA1-1807/MILBK1-1969 | 1,9 | 0,12 |
| MACTQC-1809/DOAKST-1861 | 1,3 | 1,9 |
| 114981-1776/SALBR1-1839 | 0,31 | 0,31 |
| IRVREF-1681/NORTN1-1901 | not considered | 5,54 |

The new line 1681/1991 is imposing some load curtailment, although the network reinforcement clearly improves the situation. Probably it won't be sound, on an economic point of view, to make further reinforcements for the simulated load situation.

APPENDIX VI
ÉLECTRICITÉ DE FRANCE REPORT

STUDY OF NEW BRUNSWICK POWER SYSTEM with the MEXICO MODEL

Final report

F. Broussolle

Electricité De France
RESEARCH AND DEVELOPMENT DIVISION
OPTIMIZATION AND SIMULATION METHODS DEPARTMENT

Abstract

Within the framework of CIGRE WG 38-03, the purpose is to evaluate the reliability of a composite (generation and transmission) systems using several models.

This final report reviews the study of the New Brunswick system's reliability carried out by EDF with the help of the MEXICO model. It gives the approach and the final results of the study.

Keywords: network reliability, simulation, CIGRE, MEXICO.

CONTENTS

| | | | |
|---|------|---|---|
| | page | | |
| 1. PRESENTATION OF THE STUDY - HISTORICAL BACKGROUND | 2 | 2. MODELLING THE NBP SYSTEM FOR THE MEXICO PROGRAM | 4 |
| 1.1. Introduction | 2 | 2.1. Demand | 4 |
| 1.2. Tools used BY EDF to carry out CIGRE exercises | 2 | 2.2. Load curve | 4 |
| 1.2.1. EDF probabilistic tools for system planning | 2 | 2.3. Unavailabilities | 5 |
| 1.2.2. The simulation software programme MEXICO | 2 | 2.3.1. Unavailability of transmission lines | 5 |
| 1.2.3. The results given by MEXICO | 2 | 2.3.2. Availability of generators | 5 |
| 1.3. List of study cases run by Mexico | 3 | 2.4. Hydro generation | 5 |
| 1.3.1. case 1: HL1 Equivalent | 3 | 2.5. Exchange with neighbouring companies | 5 |
| 1.3.2. case 2: Peak load analysis - reference case | 3 | 2.5.1. exports: standard cases | 5 |
| 1.3.3. case 3: Peak load analysis with network improvements | 3 | 2.5.2. correlating exports and shared generators | 5 |
| 1.3.4. case 4: Complete year analysis without network improvements | 3 | 2.6. Values of failure cost | 5 |
| with network improvements | 3 | 2.7. Dividing the country into regions | 6 |
| 1.3.5. case 5: Complete year analysis with network improvements | 3 | 3. THE SIMULATION RESULTS | 6 |
| 1.3.6. case 6: Special case with correlation of export | 3 | 3.1. Tables of results | 6 |
| | | 3.2. Comments on the results | 8 |
| | | 4. CONCLUSIONS OF THE STUDY | 8 |

1. PRESENTATION OF THE STUDY - HISTORICAL BACKGROUND

1.1. Introduction

This study is the contribution of Eléctricité de France to the work of the CIGRE 38-03-10 Task Force. This task force was assigned the comparison of probabilistic models for adequacy evaluation of composite, generation and transmission, electric power systems.

In the first place, the main methods used to define the system reliability were described and collected in a book called "Power System Reliability Analysis Application Guide" published in 1987.

It was then decided to test the methods presented on the basis of a precise example so as to make an in-depth comparison of these methods. A system of a size sufficient though not excessive and incorporating all the generation types contemplated was used for observational comparison purposes: it is the New Brunswick (a relatively small Canadian province) system.

Data corresponding to this system were consequently supplied by the New Brunswick Power (N.B.P.) to all contractors or research institutes willing to test and compare the model(s) in their possession. The final aim of the working group is to demonstrate that these models give comparable results - though they sometimes may differ - to evaluate the system reliability.

The first runs of the models showed some difficulty in comparing the results; each programme having its own way to model the system. In order to make the comparison of the models easier, the group decided to revise the data and to define a graduate sequence of exercises with standard modelization of the New Brunswick Power electrical system.

The present report describes the results obtained by Electricité de France on the basis of the revised exercises definition.

These results are to be presented during the CIGRE symposium of Montréal on power system reliability in September 1991.

1.2. Tools used by EDF to carry out CIGRE exercises

1.2.1. EDF probabilistic tools for system planning

For transmission expansion planning EDF has developed and uses 3 probabilistic models, which cover specific scopes:

MERIDA, to evaluate expected yearly operation costs

MEXICO, to evaluate system adequacy.

ANASEC, to investigate systems failures.

Other tools including the CAST programme are available for in-depth evaluation of MEXICO results.

MEXICO was the most suitable program for the CIGRE comparison and was selected by EDF for this purpose. It is a general simulation software programme designed to carry out network reliability studies.

1.2.2. The simulation software programme MEXICO

MEXICO enables simulations of the composite system operation for the purpose of evaluating the reliability. It uses the Monte-Carlo method and runs as follows:

- a) a great number of situations existing on the system are chosen at random regarding generation and transmission equipment availability rates,
- b) in each situation and for a given preset consumption level, a linear programme determines the generation scheme which minimizes the sum of operating and failure costs in full respect of the network electrical equations (in the D.C. approximation) and the allowable flows in dipoles,
- c) the results achieved over all the situations analyzed are averaged out. The mathematical expectancy of power not served for a given consumption level, and, then, by integrating the result according to a load duration curve, the mathematical expectancy of energy not served over a given time period can thus be deduced (usually one year). This gives the E.E.N.S. ("Expected Energy Not Served") and other global and local indices,
- d) one value is given for the unavailability of each component. This value is to represent forced and planned outages. The dates of planned outages are assumed to be unknown 5 or 15 years ahead of time when the expansion planning process takes place,

correlation of unavailabilities: the unavailability of several equipments may be defined as correlated, positively or negatively. This option has been developed to cope with specific cases as common mode failure of pairs of lines.

- e) one value of load for each bus and a linear stepwise load duration curve are given for the whole system to cover the study period. A Gaussian distribution of load uncertainty is introduced to represent climatic and conjunctural uncertainty. This representation of the loads allows the use of a very efficient analytical way to cope with load variations.

MEXICO, which is written in FORTRAN, allows large-size networks - up to 500 buses, 1,000 thermal units, 1,200 dipoles - to be studied.

As regards the New Brunswick system, a run of MEXICO with the analysis of 5000 situations (which affords reliable results) needs a calculation time of about 5 minutes on a CRAY-YMP.

1.2.3. The results given by MEXICO

A simulation using MEXICO gives global results covering the whole selected study period and detailed information upon a well-defined consumption level, in general peak consumption.

The detailed inventory of results is the following:

Results covering the duration of the study:

- Total value of the global failure (E.E.N.S. in MWh), with the part due to network deficiencies and that due to the lack of generation means;
- Failure expectancy and probability for each stage of the demand duration curve, which permits an easy access to the L.O.L.E. value (Loss Of Load Expectation, in hours) globally and stagewise;
- The value of marginal gains on line reinforcements in case of failure (in MWh/MW) for lines under constraint.

Results covering an hour point:

- Mean value of the generation per region, cost bracket and generation unit for the demand under consideration,
- Mean value and standard deviation of the failure per region,
- Mean management cost per region and cost bracket,
- Histograms of the failure resulting from the lack of generation and network deficiencies,
- Mean generation, consumption and failure for each network bus,
- Mean flows and frequency of constraint for each line,
- Analog (though deterministic) results for the worst failure occurrence due to the network.

1.3. List of study cases run by Mexico

1.3.1. CASE 1: HL1 Equivalent

Simplified study case; November 90 data set is used and the following assumptions and changes are applied:

- (a) The peak load for each bus is assumed to occur over the entire year.
- (b) The maintenance of generators is ignored
- (c) Concept of "common mode" pair of lines is ignored.
- (d) Hydro generation capacities are set constant all year long:

| | |
|-------------|--------|
| Matacquac | 500 MW |
| Beechwood | 80 MW |
| Grand falls | 30 MW |
- (e) Network improvements are ignored.
- (f) Rating capacity of lines are defined infinite, ie:

| | |
|----------------|----------|
| unavailability | = 0 |
| flow limit | = 6000 M |
- (g) Exportations are set constant during all year and do not stop when NBP shared generators are not available.

1.3.2. CASE 2: Peak load analysis - reference case

Study case 2 is similar to the previous except that the simplification (f) is now rejected:

Lines and transformers are given their flow limits and unavailability rates as specified in the reference set of data dated November 1990.

1.3.3. CASE 3: Peak load analysis with network improvements

Study case 3 is similar to case 2 except that the network is slightly modified according to "Network Improvements":

- 318 MVA transformer 1836-1837 is replaced with a 4590 MVA transformer,
- A new line 1681-1837 is added,
- A new line 1681-1901 is added,
- Rating of line 1681-1813 is increased up to 280 MW.

1.3.4. CASE 4: Complete year analysis without network improvements

Up to case 3 the study was limited to the peak hour. Cases 4 to 6 on the contrary are dealing with a full year.

In the study case number 4, the conditions of the reference case 2 are retained as a basis. The following modifications are brought

The year is split in three periods: Summer (4 months) Intermediate (4 months) and Winter (4 months) in order to base the study on the 3 seasons load model, It also allows to take into account different rates of unavailability for lines and transformers according to the season.

Availability rates of lines and transformers is adapted according to the period: slightly increased in winter and slightly reduced in the summer and intermediate seasons.

Capacity of thermal units are derated in order to include maintenance outages.

1.3.5. CASE 5: Complete year analysis with network improvements

Study Case 5 is similar to 4 except that network improvements are taken into account.

1.3.6. CASE 6: Special case with correlation of exports

This study case six is strictly identical to five, except that a correlation is introduced between exported shares of generation and corresponding generators. This simulation is described in the paragraph 2.5.2.

Export contracts link export to generation. Each exportation corresponds to a share of a specific generator. When the shared generator is not available, the export should be interrupted. In the standard exercises export is never interrupted. Not interrupting export when corresponding generators are not available exposes NBP system to very severe situations. Situations where a shared generator is unavailable are severe for two reasons:

- NBP has to meet usual demand with reduced generation capacities.
- NBP still has to meet export requirements when there is a lack of generation.

Neglecting to interrupt the export of a shared generator when unavailable will very likely induce an over estimation of the failure expectation.

2. MODELLING THE N.B.P. SYSTEM WITH THE MEXICO PROGRAM

An interface program has been developed in order to provide data appropriate to MEXICO from the generic data supplied by NBP. The interface program is based on the following modelling principles:

2.1. Demand

Whilst MEXICO considers only one category of load, the generic system data of NBP power system consider a full variety of loads:

- fixed consumptions, constant throughout the year,
- season-related consumptions,
- mixed consumptions: a fixed part and a variable part,
- time-related consumption (assistance to foreign consumers),
- interruptible loads which are constant throughout the year but may be switched off in case of emergency.

MEXICO does not enable direct acknowledgement of several types of demands: the total consumption is modulated by applying the load duration curve principle but consumption at buses will vary accordingly and automatically. However there is one way to define a constant load: forcing negative generation. Generation can be imposed, and a negative generation is equivalent to a consumption.

Only 2 types of demand are discriminated by the MEXICO interface: loads connected at NBP buses and loads connected at external buses representing neighbouring companies.

- Loads connected at internal NBP buses are all considered as common load; they regroup all kinds of loads of the given data. These common loads follow the modulation of the load duration curve. This modelization induces 2 side upshots:

. Loads defined as fixed in the given set of data will vary and follow the variation of the load curve, loads initially defined as variable will still vary but within a narrower range. The global distortion may induce a small increase or decrease of the network failure. The (+ or -) sign of the global impact is unpredictable but the magnitude is certainly very small.

. Interruptible loads will also follow the load curve. The fictitious generators included in the generic data will simulate the interruptions. However there will be a minor bias due to the fact that the rating of the fictitious generators will not follow the load curve and thus may produce more power than necessary to compensate the interrupted load. This distortion may slightly reduce the global network failure.

- Loads connected at external buses correspond to export contracts; the level of these loads is kept constant throughout the year. These loads for MEXICO are described by the means of generators with forced negative output.

2.2. Load curve

The yearly assessment of the adequacy of an electric system with MEXICO is usually performed with a one year simulation, based on a one year load curve. This approach is valid as long as the stochastic parameters of the system are constant throughout the year. Several parameters which should be considered as constant according to usual the EDF planning practices are not constant throughout the year in the reliability CIGRE exercises. The maintenance of generators varies with the season according to a fixed plan. Forced outage rate of transmission equipment varies with adverse weather which itself is correlated with seasons. These considerations lead to the decision to split the year in several periods and to compute the global yearly results by adding the relevant results of the different periods.

A major issue is the definition of an average solution regarding the time span so that it permits the acknowledgement of a sufficient number of data varying with time while enabling easy aggregation of the results per year.

For increased accuracy, the use of a one-week time span would be ideal. But, unfortunately, this is not feasible since it would require 52 weekly simulations to be made for a single yearly result which would make the computation time too costly (not to mention the working out of 52 sets of data).

Another modelling possibility in which data were aggregated for three typical seasons (summer, off-season and winter) provides easy access to yearly results while taking account of most changes met with the diverse parameters.

This is the retained solution for MEXICO runs. The load model number II of the generic data, with 3 seasons: summer, intermediate and winter, is selected. However the load model II is modified for MEXICO, a correction is brought to incorporate fixed loads in the load duration curve.

2.3. Unavailabilities

2.3.1. Unavailability of transmission lines

In this respect, "normal" and "bad" weathers are the key parameters since the dipole failure probability is much higher in the case of bad weather. This factor cannot be directly taken into account within MEXICO since stochastic parameters cannot be modified as the simulation progresses. The ratio of adverse versus normal weather being given for each season, transmission failure rate are averaged for each season. In this way, the availability rate of transmission equipment is considered constant during each season.

2.3.2. Availability of generators

The data supplied by the CIGRE working group state that generator maintenance is strictly planned on an annual basis.

The simulations with MEXICO could not take these forced shut-downs into account as the characteristics of generating units do not include a maintenance plan. However the impact of unavailability of each generator during the period of maintenance had to be taken into account in the simulation. Therefore the solution retained is the following: the maximum capacity of each generator is derated in proportion to the duration of maintenance. This calculation is performed for NBP generators as well as for external generators. The computation of derating is performed for each of the 3 seasons.

2.4. Hydro generation

EDF and NBP do not approach the management of hydro resources in the same manner. A satisfactory compromise therefore had to be found for the hydro plant model.

The data supplied on hydroelectricity do not address output modulation. An estimate of the total annual generation in GWh is provided for each facility together with monthly output duration curves.

MEXICO processes hydro generation in a completely different manner. So-called "zero-cost" hydro generation, which is based on global generation estimates, is performed automatically and remains unchanged throughout the simulation period. A cost will be allocated to any additional hydro generation.

For the MEXICO runs, an adaptation was made on the basis of the "thermal equivalent hydro model" of the exercises's generic data and also of the hydro generation power proposed for the peak analysis. The principle is to modulate the power level of peak analysis according to the seasons and to split it in two shares:

- "base zero cost" power,
- "modulation" power.

The hydro modulation is given the cost provided with the thermal equivalent.

2.5. Exchanges with neighbouring COMPANIES

2.5.1. Exports: Standards study cases

The levels of export are set constant and established according to the figures of the contracts. Within study cases 1 to 5, an export is not interrupted when the corresponding shared generator happens to be unavailable.

2.5.2. Correlating exports and shared generators: study case 6

A more accurate modelization of export is possible with MEXICO. Fictitious generators are attached at the boundary buses. This modelization is selected for the special study case, number 6.

A fictitious generator is associated to each export, it is given the same power level as the corresponding export. The following table gives the list of these fictitious generators:

| <u>Fictitious Generator</u> | <u>Purchaser</u> | <u>Facility</u> | <u>Power purchased (MW)</u> | <u>Power generated (MW)</u> |
|-----------------------------|------------------|-----------------|-----------------------------|-----------------------------|
| A | New England | Pt Lepreau | 210 | 427 |
| B | New England | Belledune | 20 | 410 |
| C | P.E. Island | Dalhousie 02 | 20 | 183 |
| D | P.E. Island | Pt Lepreau | 20 | 427 |
| E | P.E. Island | Belledune | 20 | 410 |

The availability of such fictitious generators is exactly opposite to the one of the corresponding shared generator. When a shared generator happens to be available in one situation, as a result of the random drawing, then the related fictitious generators are unavailable. On the opposite if a shared generator is drawn unavailable, then the related fictitious generators are then available and cover directly the exports which are to be met at the same buses.

Thus, actually, with the help of these anticorrelated fictitious generators, when during a random situation, one of the following generators is unavailable: Pt LEPREAU, BELLEDUNE or DALHOUSIE2, the exported shares of generation are automatically stopped.

2.6. Value of failure cost

A number of parameters required by MEXICO for simulation were not provided by New Brunswick. The values selected had to be as accurate as possible.

One of the most important is the cost of failure. In order to solve the MEXICO linear program, a cost must be allocated to failure. The exact value is of little importance but the order of magnitude must be far higher than total generation costs.

The value selected is \$1,200/MWh, which corresponds to approximately FFr5/kWh, an average value often selected in France. In comparison, the most costly generation resources total \$120/MWh.

2.7. Dividing the country into regions

MEXICO allows discrimination of up to 8 regions within the network studied. Local results can then be obtained especially for generation, failures and management costs. It should however be noted that the management of the whole network by MEXICO will in no case be modified.

This possibility has been extensively used in our example so as to delineate the problems more easily. The idea was primarily to consider these regions as identical with the countries under consideration ie: New Brunswick and the neighbouring regions.

Since this gave only 6 regions, New Brunswick has been divided into 3 characteristic portions. In conclusion, the following eight regions have been established:

- [1] the middle of New Brunswick
- [2] New Scotland
- [3] Prince Edward Island
- [4] The Province of Quebec
- [5] The Maine (public service only)
- [6] The Maine (private companies)
- [7] New Brunswick South, in the vicinity of St John, Coleson Cove, Point Lepreau and Courtenay Bay plants
- [8] New Brunswick North, in the vicinity of Bathurst and Eel River, Belledune, Dahlousie and Cowans Creeks plants.

3. THE SIMULATION RESULTS

3.1. Tables of result

Six study cases were performed:

- Case 1: HL1 equivalent
one run of 8000 situations
- Case 2: Peak load analysis - reference case
one run of 8000 situations
- Case 3: Peak load analysis - with network improvements
one run of 8000 situations
- Case 4: Complete year analysis
without network improvements
3 runs of 5000 situations, one for each season
- Case 5: Complete year analysis - with network improvements
3 runs of 5000 situations, one for each season
- Case 6: Complete year analysis
special case with correlation of export
3 runs of 5000 situations, one for each season

The results are regrouped according to their types. They are displayed in the four following tables:

- Expected Energy Not Served
- Loss Of Load Expectation
- Marginal Gain on Overloaded Lines
- Load Point Curtailment on buses

Remarks

Load point curtailment is edited by MEXICO, only in the studies dealing with particular hour points. Therefore they were not available for study cases 4,5 and 6.

CIGRE TASK FORCE 38.03.10 Results of MEXICO runs Expected Energy Not Served

| Items | HL1 | Peak Load Analysis | | Year Analysis | | Year Anal with correlati Expor-Gen |
|----------------------|------|--------------------|----------------|-------------------|----------------|------------------------------------|
| | | without Net Imprv | with Net Imprv | without Net Imprv | with Net Imprv | |
| Case no | 1 | 2 | 3 | 4 | 5 | 6 |
| EPNS (MW) Generatio | 1.7 | 1.7 | 1.7 | | | |
| EPNS (MW) Network | 0.0 | 6.2 | 0.2 | | | |
| EENS (GHh) Generatio | 15.2 | 15.2 | 15.2 | 0.8 | 0.8 | 0.2 |
| EENS (GWh) Network | 0.0 | 53.9 | 1.3 | 5.4 | 2.3 | 2.5 |
| EENS (GWh) total | 15.2 | 69.1 | 16.6 | 6.1 | 3.1 | 2.7 |

**CIGRE TASK FORCE 38.03.10
Results of MEXICO runs**

**LOSS OF LOAD EXPECTATION
in hours per year**

| Items | HL1 | Peak Load Analysis | | Year Analysis | | Year Anal with correlati Expor-Gen |
|---------------------|-------|----------------------|-------------------|---|-------------------|---|
| | | without Net Imprv | with Net Imprv | without Net Imprv | with Net Imprv | |
| Case no | 1 | 2 | 3 | 4 | 5 | 6 |
| LOLE due generation | | | | | | |
| Freq % | 1.08 | 1.08 | 1.08 | NOT MENTIONNED IN MEXICO PRINTOUTS FOR A ONE YEAR STUDY | | |
| LOLE | 95 | 95 | 95 | | | |
| LOLE due to network | | | | | | |
| Level 1 | | | | 0.622 | 0.117 | 0.116 |
| Level 2 | | | | 0.409 | 0.072 | 0.069 |
| Level 3 | | | | 0.283 | 0.258 | 0.257 |
| Level 4 | | | | 0.265 | 0.131 | 0.136 |
| Level 5 | | | | 0.006 | 0.005 | 0.006 |
| Freq % | 0.000 | 20.110 | 0.490 | 0.018 | 0.007 | 0.007 |
| LOLE | 0.0 | 1761.6 | 42.9 | 1.6 | 0.6 | 0.6 |
| Global LOLE | | | | | | |
| Freq % | 1.08 | 21.03 | 1.46 | NOT MENTIONNED IN MEXICO PRINTOUTS FOR A ONE YEAR STUDY | | |
| LOLE | 94.6 | 1842.2 | 127.9 | | | |

NOTE

For year analysis LOLE is computed for each level of the load curve.

**CIGRE TASK FORCE 38.03.10
Results of MEXICO runs**

Marginal EENS gain and ranking for overloaded lines

| Items | Peak Load Analysis | | Year Analysis | | Year Anal with correlati Expor-Gen |
|--------------------------------------|----------------------|-------------------|----------------------|-------------------|---|
| | without Net Imprv | with Net Imprv | without Net Imprv | with Net Imprv | |
| Case no | 2 | 3 | 4 | 5 | 6 |
| LINE 1837-1860 from C.COVI to MILD47 | | | | | |
| Gain MWh/MW | 3234.2 | 29.8 | 183.7 | 3.7 | 3.7 |
| rank | 1 | 1 | 1 | 2 | 2 |
| LINE 1807-1969 from NEWCA1 to MILBK1 | | | | | |
| Gain MWh/MW | 59.6 | 13.1 | 2.6 | 0.6 | 0.2 |
| rank | 2 | 2 | 5 | 3 | 3 |

**CIGRE TASK FORCE 38.03.10
Results of MEXICO runs**

Load Point Energy of Curtailment and ranking

| Items | Peak Load Analysis | |
|-------------------|----------------------|-------------------|
| | without Net Imprv | with Net Imprv |
| Case no | 2 | 3 |
| bus 1860 : MILD47 | | |
| EENS GWh | 36 | 1 |
| rank | 1 | 1 |
| bus 1813 : C.BAY1 | | |
| EENS GWh | 17 | 0 |
| rank | 2 | 0 |

NOTE

Bus load curtailment is computed only for peak analysis.

3.2. Comments on the results

The reliability of the New Brunswick Power system is high. The study identifies a significant level of failure in one area only. This area is located where the actual existing phase shifter transformer should be included. The transformer is missing from the generic data.

Modelisation for Peak load exercises, study cases 1 to 3, are specified in such a way that they are applicable to MEXICO without distortion. Results may be directly compared with other model results.

On the contrary, the modelization of the system for the complete year analysis brought particular challenges. The options selected to cope with the modelization peculiarities may explain some distortion in the results.

4. CONCLUSIONS OF THE STUDY

This study of the New Brunswick generation-transmission system reliability was an opportunity for the MEXICO software programme to be tested on a foreign network.

All the simulations provided consistent results which we briefly recall:

- The yearly failure is low and due mainly to transmission. Generation failure is very low around 200 MWh with an accurate modelling of export, ie: if the contractual exports are stopped when shared generators are unavailable.
- The study of lines under constraint shows that most of the problems are due to a very reduced number of lines.
- In all cases, system interconnection with neighbouring countries are particularly advantageous for New Brunswick electric system adequacy as evidenced by a comparison of the failure values.

To get a better estimate of the adequacy of the network NBP needs a model including an accurate modelling of phase shifter transformers.

REFERENCES

- 1- J.C. DODU, A. MERLIN
"An application of linear programming to the planning of large scale power systems: the Mexico model"
5th PSCC, Cambridge, 1975.
- 2- A. MERLIN, Ph. OGER
"Application of variance reducing techniques to a Monte Carlo simulation model of power transmission system"
EPRI Whorkshop on Power System Reliability, WS 77-60, 1978
- 3- J.C. DODU, A. MERLIN
"Recent improvements of the MEXICO model for probabilistic planning studies"
Electrical Power and Energy Systems 1979
- 4- J.C. DODU, A. MERLIN
"New probabilistic approach taking into account reliability and operation security in EHV power system planning at EDF"
PICA, 1985

APPENDIX VII
UNIVERSITY OF MANCHESTER REPORT

Studies of the New Brunswick Power System using UMIST's COMPASS and RELACS Programs

R.N.Allan, M.R.Bhuiyan, S.Skuletic, H.M.Al-Maghraby, E.L.Del Carpio Munoz, J.Roman Ubeda

Electrical Energy and Power Systems Group
Department of Electrical Engineering and Electronics
UMIST
Manchester
England

1. INTRODUCTION

The reliability of the electric power system is becoming an increasingly important issue for utility planners because of the recent increase in load demand growth and the limited amount of new generation that is currently planned. The primary function of an electric utility is to provide energy to satisfy the system load demand as economically as possible while maintaining a reasonable level of reliability. This assessment can be made, in part, by the use of reliability evaluation techniques. There are two basic reliability evaluation methods; the analytical approach and the stochastic simulation approach. Both approaches are used at UMIST and a brief description of the programs (COMPASS and RELACS) are described in this Appendix. Simulation techniques, often known as Monte Carlo simulation because they involve random numbers, can themselves be divided into two categories; nonsequential (or random) and sequential. A nonsequential simulation process considers each hour to be independent of every other hour. Consequently, nonsequential simulation cannot model issues that involve time correlations. The sequential approach which examines each basic interval of the simulated period in chronological order can take into account virtually all contingencies inherent in the system.

2. COMPASS

2.1 General

The COMPOSITE system Assessment using Sequential Simulation (COMPASS) program is based on a sequential Monte Carlo simulation technique. Although the NBP system does not contain hydro units, COMPASS can simulate efficiently mixed hydro-thermal systems with special reference to the operating policy, management of water and randomness associated with reservoir water. Models associated with hydro systems are not described in this report.

2.2 Simulation Procedure

The concepts of Monte Carlo simulation used in COMPASS are based on:

- (a) the multiplicative congruent method for generating pseudo-random numbers
- (b) the inverse transform method for converting these to the relevant probability distribution
- (c) the sequential simulation approach in order to represent the time dependent process and to obtain the density estimates associated with each indices.

The system operation is simulated over a long period of time which is subdivided into reference periods of one year. Each year is divided into basic time intervals during which the state of the system is assumed to be constant. The present model works on an hourly basis which means that changes in the system are assumed to occur at the beginning of every hour. In this sequential simulation procedure the power system reliability evaluations are performed as follows:

- for every simulated hour the availability state of all system elements, such as generating units and lines, are checked
- times to fail or repair are produced by sampling the appropriate probability distributions
- other random conditions, such as uncertainty of the load, are also modelled by random variates sampled from their associated probability functions
- components and their operations are represented by mathematical models
- the combined operation of the power system is then assessed. Deficiencies are recorded in magnitude and frequency. Each deficiency is stored as an independent sample. These deficiencies are also grouped by simulated years
- indices are obtained from the above records together with their frequency distributions

- the simulation is performed for a period of simulated time long enough to include most of the events of interest.

2.3 Availability Model

The model used to represent the forced outages and repair states is the same for generating units, transmission lines and transformers. This assumes that the time between forced outages and the outage duration are independent and exponentially distributed. A forced outage of a generating unit causes the total loss of the unit, the forced outage of a line causes the loss of the corresponding capacity, repair is undertaken as soon as an element fails. Repair time is independent of any other repairs or failures and repair is always successful and restores the component to as good as new states.

2.4 Operating Policy

The operating policy model recognises the factors affecting the actual dispatch of generating units, e.g. fuel costs, and it classifies the thermal generation into four different types:

- THA: Base generation
- THB: Economic generation
- THC: Expensive generation
- THD: Peaking generation

The actual dispatch is performed in the following order:

- G1: THA (Base generation) (all THA units)
- G2: THB (Economic generation) (all THB units plus G1)
- G3: THC (Expensive generation) (all THC units plus G2)
- G4: THD (Peaking generation) (all THD units plus G3)

Each thermal unit is type-specified and dispatched according to a merit order list within each type. For the NBP system all the 38 generating units are grouped together within a type and dispatched according to their increasing incremental fuel cost.

2.5 Sequential Load Flow

A load flow is performed for every simulated hour of the operation of the system. The flow through the lines are calculated and corrective actions are performed if a transmission constraint is violated. A linearised load flow is used to represent the transmission system. This classical representation only takes into account active power flows and change of bus voltages are not considered. Load flow is performed using the impedance matrix and line flows are obtained by multiplying the distribution factor matrix by the vector of load and generation injections.

Generation is allocated for every simulated hour according to demand, available generating units and a merit order list. Demand changes proportionally with time at all load buses, therefore, the contribution of the loads to the line flows are recalculated at every hour. Whenever there is a change of generation of any unit, the contribution of generation to the line flows are calculated again.

2.6 Overload Relief Procedures

The simulation of a composite system must include models for relieving transmission overloads. The methods implemented in COMPASS are based on the sensitivity of global system overload to busbar injections. The basic concepts and algorithms are outlined in what follows. In the case of an overload, generation redispatch is attempted first then, if necessary, load is shed at the most sensitive bus and a new redispatch is attempted if the overload persists. This process, redispatch/load shedding, is repeated until the overload has finally been eliminated.

2.7 Sensitivity Of Overloads To Busbar Injections

Each bus of the system in a linearised representation contributes to the flow in a line proportionally to its distribution factor and its net power injection. Similarly, if a line is overloaded, each bus contributes to that overload proportionally to its distribution factor and its net power injection. Therefore, the contribution to the system overload by bus n is:

$$C_n = \sum_l D_{nl} (-1)^k$$

where:

$k=0$ if $F_l > 0$ or $=1$ if $F_l < 0$

F_l = power flow through line l

D_{nl} = distribution factor of bus n for line l

C_n = unitary contribution of bus n to global system overload

The summation is extended only to overloaded lines.

If C is positive, positive injections at bus n create overloads in the system and vice versa. However, if C is negative, positive injections reduce the overload of the system and vice versa. Therefore, there will be buses where a generation decrease will reduce the overload and others where an increase will produce the same effect. The reverse occurs in the case of loads. Therefore, the value of C can be used to select the most sensitive buses for generation redispatch or load shedding. A line is considered to be overloaded when its power flow is larger than its capacity limit. On the other hand, a certain margin (tolerance) of overload can be tolerated in each line. The NBP system is simulated without any tolerance for the transmission lines.

2.8 Redispatch For Overload Relief

During the simulation of each simulated hour, a generation dispatch is performed according to the demand, available generating units and finally a merit order list. This dispatch is done before any restrictions from the transmission system are considered. Therefore, overloaded lines may appear when the load flow is performed.

The overload may be reduced by modifying the original generation dispatch. It is not always possible to reduce the overload of the system by redispatch, so it is important to know whether a redispatch will reduce the overload or not. The first

condition for a redispatch is the existence of generation reserve, the second condition is that the generation reserve must exist at buses where an increase of generation will produce a reduction of the system overload.

The method implemented consists of successively selecting pairs of buses according to their unitary contribution to the global system overload. The bus K_{re} with the largest positive contribution and positive injection, and the bus K_{in} with the largest negative contribution and positive generation reserve are selected. If the difference between the contribution of bus K_{in} and bus K_{re} is positive, then it is not possible to reduce the system overload by means of generation redispatch. If the difference is negative, then an increase of generation at K_{in} and a reduction at K_{re} will reduce the system overload.

If a redispatch is beneficial, the amount of generation to be exchanged is calculated. The maximum amount of generation exchanged between a pair of buses is given by the minimum value among the generation at bus K_{re} (for generation reduction), the reserve available at bus K_{in} (for generation increase) and the quantity that makes at least one line change its overloaded status, i.e.:

$$GE = \min(G_{K_{re}}, GR_{K_{in}}, d)$$

where

GE = amount of generation to be exchanged

$G_{K_{re}}$ = amount of generation at bus K_{re}

$GR_{K_{in}}$ = generation reserve available at bus K_{in}

d = quantity that overcomes overload of a line.

All lines must be checked to select d and this should be the minimum value found.

For every exchange of generation that is performed, the unitary contribution of buses must be calculated, a pair of buses selected, the feasibility of the redispatch checked, the amount of generation exchanged chosen and the new flows through the lines computed. This procedure continues until the system overload has been eliminated or the redispatch becomes infeasible.

2.9 Load Shedding For Overload Relief

Load shedding procedures can be applied, in a similar manner to redispatch. The K_{re} bus will reduce its generation while the K_{in} bus (which is now a load bus) will reduce its load (a reduction of load is equivalent to an increase of generation). The amount of load to be shed is chosen so that only one line at a time changes its overload status, ensuring minimum load shed. Load shedding procedures are always possible and certainly eliminate the overload of the system.

During the redispatch and load shedding procedures only the bus generations are reassigned in order to eliminate line overflows. To obtain the individual unit energy production and hence the cost of energy generation these bus generations are reallocated to specific generating units.

2.10 Indices Evaluated

A wide range of system and load point indices are evaluated

representing measures of a reliability and energy production. These consist of expected values, standard deviations, confidence limits and the complete frequency (probability) distributions.

The indices include:

FOI: frequency of interruption (int/yr)

FOI_g : frequency of interruption due to insufficient generation

FOI_t : frequency of interruption due to transmission inadequacies

LOEE: loss of energy expectation (MWh/yr)

$LOEE_g$: loss of energy expectation due to insufficient generation

$LOEE_t$: loss of energy expectation due to transmission inadequacies

LOLE: loss of load expectation (h/yr)

$LOLE_g$: loss of load expectation due to insufficient generation

$LOLE_t$: loss of load expectation due to transmission inadequacies

EIR: energy index of reliability

AWE: average water used to produce electric energy (Hm³/yr)

EAW: average energy produced from AWE (GWh/yr)

AWS: average water spilled (Hm³/yr)

EAWS: average energy production lost due to water spillage (GWh/yr)

AWP: average water pumped (Hm³/yr)

EAWP: average energy used to pump water (GWh/yr)

AEHG: average energy produced by all hydro plants (GWh/yr)

FEHG: fraction of total energy demand supplied by hydro generation (%)

3. RELACS

3.1 Introduction

RELACS is based on the analytical approach and has been developed to perform Reliability Analysis of Composite (generation and transmission) systems. This is achieved by considering generating units and circuit outages and assessing their impact on the power system operation subjected to predetermined load levels. The system operation can either be modelled by linear or by non-linear load flow equations. The impact, in turn, is quantitatively measured by the probability of encountering the system in a certain condition, either a failure or a non-failure state, or in a state where remedial action is required in order to maintain a satisfactory operation. The techniques embedded in RELACS are based on those described in References [1] and [2].

3.2 State Enumeration

The number of states analysed by RELACS is established by choosing one of two available state selection methods.

- (a) Probability Truncation - allows a state to be analysed only if its probability of occurrence is higher than a specified value (probability tolerance).
- (b) Component Combination - where it is possible to prespecify the maximum number of generators, of lines and of components (generators and lines, together) that will be considered on outage.

3.3 Component Outages

The program simulates three different outage modes. These are independent, common mode and station originated outages.

It is important to note that, irrespective of their failure modes, a state is analysed only once. The probability of occurrence is, however, altered accordingly.

3.4 Generation Dispatch

For reliability studies the generation dispatch algorithm needs to be reasonably realistic but not very exact nor time consuming. Therefore, two very straightforward routines are implemented in the program. The first, based on the merit order rule, allocates the required active generation accordingly in order to achieve minimum generating costs. The second distributes the generation requirements among every generator available observing an equal percentage reserve.

3.5 Load Characteristic

The program can either assume a peak load value (1.0 pu) throughout the period of study or adopt a variable load. In this case, the load consists of a set of different levels and is simulated by the frequency and duration method.

3.6 Load Flow

RELACS contains the necessary algorithms for using AC (Fast Decoupled Method) and DC load flows.

3.7 Insufficient Generation

An algorithm detects states without enough generation to meet the load. Such a condition can be caused by generator or line outages. One of two load shedding routines can be used to overcome this system malfunction. These two different routines are called distributed and geographical depending on the method of selecting busbars at which load is to be interrupted. In the distributed routine the load to be shed is distributed among every load busbar on an equal percentage. The geographical routine sheds the load at appropriate busbars near to where the disturbance occurs.

3.8 Overloaded Lines

After the load flow simulation, every circuit flow is compared against its maximum rating. If there is an overload, generation redispatch routines can be employed in an attempt to alleviate it. If the overload condition persists, one of five different load shedding algorithms can be selected to completely overcome the malfunction. These five algorithms are called, depending on the procedure for selecting busbars at which load is to be shed and on the method for evaluating this load:

- optimum
- closest-busbar
- proportional
- generalised
- localised.

(i) Optimum Load Shedding

This procedure seeks to curtail load at the minimum number of busbars in the system. It also seeks to shed the minimum load. Load curtailment is not the only problem involved in alleviating

an overload. Generation must also be reduced when load is shed. Therefore, generation and load busbars are affected. Distribution factors are used as measures of the sensitivity or impact a change of load in a given busbar has on the receiving end busbar of the overloaded line. They also measure the effect a change in injected power at a generation busbar has on the sending end busbar of the overloaded line. Therefore, they can be used to near-optimize the load curtailment.

(ii) Closest Busbar Load Shedding

This load shedding procedure also curtails load and reduces generation at the minimum number of busbars in the system but, this time, tries to constrain the effect to busbars in the immediate neighbourhood of the overloaded line. The concept of distribution factors is still used to estimate the amount of load and generation to be shed. However, the busbars at which load curtailment takes place are the closest technically to the malfunction.

(iii) Proportional Load Shedding

This routine selects the load busbar in a similar way to the one used in the closest-busbar, i.e. the nearest technically possible. The load to be shed is determined using proportional factors.

The generalised and localised load shedding techniques are dependent on the definition of geographical areas. These are defined as follows:

- (a) AREA 1 is the set of busbars comprising the receiving end of the overloaded line and those busbars lying one line away from it.
- (b) AREA 2 is the set of busbars including AREA 1 and those busbars lying one line away from it.
- (c) AREA 3 is the set of busbars including AREA 2 and those busbars lying one line away from it.

The simulation of geographical areas can be adapted to suit the characteristics of the system under study for load shedding purposes. Load shedding can be simulated progressively starting in AREA 1. A wider area is affected when insufficient load exists in the previous area. Flexibility is introduced in defining the size of the first area in which load shedding is applied. This can start in AREA 1, AREA 2 or AREA 3, thus creating Geographical Divisions of the system where:

- (a) Division 1 - when load shedding starts in AREA 1
- (b) Division 2 - when load shedding starts in AREA 2
- (c) Division 3 - when load shedding starts in AREA 3

Therefore, three different divisions can be adopted. Characteristics of the system will dictate their use. This will enable the simulation of the effect of load shedding in different size of geographical areas.

(iv) Localised Load Shedding Technique

The principle of the load shedding technique is as follows. Load is shed proportionately at all the busbars of the pre-specified geographical area with direct influence on the overloaded line. It first sheds only the curtailable load in the area. Firm load, in the same area, is then shed if there is insufficient curtailable load, however, in the event of insufficient total load in this geographical area, load shedding is continued using the same

pattern at the additional busbars of the next size of geographical area. If necessary, this process continues until it affects all of the system. The total amount of load to be curtailed is evaluated using the concepts of distribution factors.

(v) Generalised Load Shedding Technique

The generalised load shedding technique is a slight modification of the previous localised shedding one. The procedure allows a variation in the policy of load curtailment carried out by utilities. The principle involved is that the curtailable load is shed, area by area as required, in the whole of the system before starting to shed any firm load. This differs from the localised load shedding technique in which all load is shed in each area before any load is shed in the next area. The simulation and philosophy of load shedding is carried out using the same concepts developed for the localised load shedding technique.

The last two routines shed load by geographical areas. Areas closer to the malfunction are first affected.

3.9 Voltage Profiles

This feature is only applicable to non-linear assessment. This uses a full AC load flow model allowing common power system components, such as LTC transformers, reactors or shunt capacitors, to be easily represented. An identification of voltage violations and MVAR out-of-limit conditions is performed. A straightforward load shedding routine is used for voltage problems and MVAR violations are alleviated by setting new voltage levels at the controlled busbars.

3.10 Busbar Isolation

Line outages can split the power network into two or more areas of different sizes. For these events, the system is assumed to be divided into a main section and one or more subsections. Each are analysed separately.

3.11 Reliability Indices

RELACS produces a complete set of load point, line and system reliability indices. All these indices represent valuable information about the system under study. An important complement to these figures are a set of maximum and expected values which are presented together with annualised system indices. Both groups of indices give an overall picture of the system reliability.

An alternative to the above indices, is to evaluate probability bounds instead of exact calculation of the probability of system failure as given by the reliability indices. It avoids the need of having to analyse every single state and, thus, it may reduce the overall computational effort. These probability bounds (upper and lower) are the second optional output of RELACS.

4. ANALYSIS OF NEW BRUNSWICK POWER SYSTEM

4.1 General

A summary of results obtained from COMPASS and RELACS are given in the main body of this report. The following information represents additional results obtained from COMPASS which, in particular, highlights the large values of standard deviation associated with the reliability indices and the wide ranges observed in the confidence intervals.

The indices quoted in these results are:

- LOEE - loss of energy expectation
- LOLE - loss of load expectation
- LCY - load curtailed per year
- FOI - frequency of interruptions

4.2 Data and Results

In all cases, a period of 200 years was simulated each made up of 8736 (= 52 x 7 x 24) hours.

The data used is that defined for the NBPS. In addition, a modified annual load model was used because the sequential / chronological relationship of load was needed. This load model is shown in Tables 1 and 2.

The results are shown in Tables 3 to 10 in which:

Tables 3/4: fixed peak load without transmission improvement

Tables 5/6: fixed peak load with transmission improvement

Tables 7/8: with load model without transmission improvement

Tables 9/10: with load model with transmission improvement

5. REFERENCES

- [1] Billinton, R. and Allan, R.N. "Reliability Evaluation of Power Systems". Plenum Publishing, New York, 1984.
- [2] Billinton, R. and Allan, R.N. "Reliability Assessment of Large Electric Power Systems". Kluwer Academic Publishers, Boston, 1988.

Table 1 - NBP Load Model Used In COMPASS

| month | peak load (MW) | number of weeks |
|-------|----------------|-----------------|
| JAN | 3986.7 | 5 |
| FEB | 3787.1 | 4 |
| MAR | 3712.7 | 4 |
| APR | 3249.2 | 4 |
| MAY | 3022.1 | 5 |
| JUN | 2750.1 | 4 |
| JUL | 2571.9 | 5 |
| AUG | 2660.5 | 4 |
| SEP | 2770.5 | 4 |
| OCT | 3011.9 | 5 |
| NOV | 3369.4 | 4 |
| DEC | 3739.2 | 4 |

These peak loads include system loads, support to neighbouring systems and system losses.

Table 2 - Chronological Weekly Load Model

| hr | day number | | | | | | |
|----|------------|-----|-----|-----|-----|-----|-----|
| | 1 | 2 | 3 | 4 | 5 | 6 | 7 |
| 1 | 3.0 | 3.0 | 2.0 | 2.0 | 2.0 | 1.0 | 1.0 |
| 2 | 3.0 | 3.0 | 2.0 | 2.0 | 2.0 | 1.0 | 1.0 |
| 3 | 3.0 | 3.0 | 2.0 | 2.0 | 2.0 | 1.0 | 1.0 |
| 4 | 3.0 | 3.0 | 2.0 | 2.0 | 2.0 | 1.0 | 1.0 |
| 5 | 3.0 | 3.0 | 2.0 | 2.0 | 3.0 | 1.0 | 1.0 |
| 6 | 4.0 | 4.0 | 3.0 | 3.0 | 3.0 | 1.0 | 1.0 |
| 7 | 4.0 | 4.0 | 3.0 | 3.0 | 3.0 | 1.0 | 1.0 |
| 8 | 4.0 | 4.0 | 5.0 | 5.0 | 5.0 | 1.0 | 1.0 |
| 9 | 6.0 | 6.0 | 5.0 | 5.0 | 5.0 | 2.0 | 1.0 |
| 10 | 6.0 | 6.0 | 5.0 | 5.0 | 5.0 | 2.0 | 2.0 |
| 11 | 6.0 | 6.0 | 5.0 | 5.0 | 5.0 | 2.0 | 2.0 |
| 12 | 5.0 | 5.0 | 4.0 | 4.0 | 5.0 | 3.0 | 2.0 |
| 13 | 5.0 | 5.0 | 4.0 | 4.0 | 4.0 | 3.0 | 3.0 |
| 14 | 5.0 | 5.0 | 4.0 | 4.0 | 4.0 | 3.0 | 3.0 |
| 15 | 5.0 | 5.0 | 4.0 | 4.0 | 4.0 | 2.0 | 2.0 |
| 16 | 5.0 | 5.0 | 4.0 | 4.0 | 4.0 | 2.0 | 2.0 |
| 17 | 5.0 | 5.0 | 4.0 | 4.0 | 4.0 | 2.0 | 2.0 |
| 18 | 5.0 | 5.0 | 4.0 | 4.0 | 4.0 | 2.0 | 2.0 |
| 19 | 6.0 | 6.0 | 5.0 | 5.0 | 5.0 | 2.0 | 2.0 |
| 20 | 6.0 | 6.0 | 5.0 | 5.0 | 5.0 | 2.0 | 2.0 |
| 21 | 4.0 | 4.0 | 5.0 | 5.0 | 5.0 | 2.0 | 2.0 |
| 22 | 4.0 | 4.0 | 5.0 | 5.0 | 5.0 | 3.0 | 3.0 |
| 23 | 4.0 | 4.0 | 3.0 | 3.0 | 3.0 | 3.0 | 3.0 |
| 24 | 4.0 | 4.0 | 3.0 | 3.0 | 3.0 | 3.0 | 3.0 |

Table 3 Fixed Peak Load - Without Transmission Improvement

(a) global results

| | LOEE (MWh/yr) | LOLE (h/yr) | LCI (MW/int) | FOI (int/yr) |
|----------------------|------------------|----------------|-----------------|-----------------|
| average value | 75320 | 2048 | 29.88 | 63.92 |
| std deviation | 22050 | 326 | 44.87 | 7.38 |
| confidence intervals | | | | |
| level | lower upper | lower upper | lower upper | lower upper |
| 95% | 72270 78380 | 2002 2093 | 29.10 30.65 | 62.90 64.93 |
| 99% | 71300 79350 | 1988 2107 | 28.85 30.90 | 62.57 65.27 |

(b) generation system results

| | LOEE (MWh/yr) | LOLE (h/yr) | LCI (MW/int) | FOI (int/yr) |
|----------------------|------------------|----------------|-----------------|-----------------|
| average value | 15690 | 92.77 | 128.7 | 6.77 |
| std deviation | 14810 | 64.15 | 104.8 | 3.46 |
| confidence intervals | | | | |
| level | lower upper | lower upper | lower upper | lower upper |
| 95% | 13640 17740 | 83.87 101.7 | 123.1 134.3 | 6.29 7.25 |
| 99% | 12990 18390 | 81.06 104.5 | 121.3 138.1 | 6.14 7.40 |

(c) transmission system results

| | LOEE (MWh/yr) | LOLE (h/yr) | LCI (MW/int) | FOI (int/yr) |
|----------------------|------------------|----------------|-----------------|-----------------|
| average value | 59630 | 2000 | 21.07 | 61.84 |
| std deviation | 16440 | 323 | 19.95 | 7.41 |
| confidence intervals | | | | |
| level | lower upper | lower upper | lower upper | lower upper |
| 95% | 57350 61910 | 1955 2045 | 20.71 21.42 | 60.81 62.86 |
| 99% | 56630 62630 | 1941 2059 | 20.60 21.53 | 60.48 63.19 |

Table 4 Fixed Peak Load - Without
Transmission Improvement

| Bus number | ENSB (MWh/yr) |
|------------|---------------|
| 1860 | 30730.35 |
| 1813 | 27247.16 |
| 1812 | 1468.37 |
| 1807 | 1147.07 |
| 1971 | 1132.32 |
| 1679 | 1089.29 |
| 0700 | 923.97 |
| 9996 | 804.29 |
| 1869 | 803.47 |
| 1712 | 696.28 |
| 1810 | 643.30 |
| 1861 | 640.60 |
| 1910 | 624.39 |
| 1717 | 584.03 |
| 1677 | 546.04 |
| 1806 | 524.27 |
| 1909 | 492.92 |
| 1681 | 448.42 |
| 1948 | 437.08 |
| 2496 | 357.94 |
| 2498 | 276.79 |
| 1863 | 275.01 |
| 1834 | 253.32 |
| 1844 | 253.27 |
| 2499 | 241.04 |
| 1847 | 220.95 |
| 1776 | 212.40 |
| 2497 | 208.90 |
| 1930 | 202.07 |
| 0158 | 201.26 |
| 1824 | 187.20 |
| 1811 | 185.60 |
| 1800 | 157.08 |
| 0167 | 126.49 |
| 2495 | 119.32 |
| 0183 | 108.00 |
| 1852 | 99.75 |
| 1843 | 88.38 |
| 1846 | 88.30 |
| 1845 | 87.88 |
| 1809 | 83.16 |
| 1805 | 63.88 |
| 1832 | 62.71 |
| 1804 | 61.87 |
| 0157 | 56.78 |
| 1945 | 30.29 |
| 1946 | 30.17 |
| 1854 | 19.85 |
| 1865 | 8.44 |

Table 5 Fixed Peak Load - With
Transmission Improvement

| Bus number | ENSB (MWh/yr) |
|------------|---------------|
| 1812 | 1459.49 |
| 1807 | 1116.36 |
| 1813 | 1021.28 |
| 0700 | 924.24 |
| 1869 | 803.70 |
| 9996 | 803.70 |
| 1712 | 704.37 |
| 1810 | 642.96 |
| 1910 | 624.57 |
| 1677 | 546.20 |
| 1717 | 535.09 |
| 1806 | 524.42 |
| 1909 | 493.07 |
| 1861 | 483.19 |
| 1948 | 437.21 |
| 1679 | 422.33 |
| 2496 | 358.05 |
| 1971 | 313.83 |
| 2498 | 276.87 |
| 1863 | 275.35 |
| 1844 | 247.27 |
| 1834 | 246.51 |
| 2499 | 241.11 |
| 1847 | 221.02 |
| 1776 | 212.81 |
| 2497 | 208.96 |
| 1930 | 202.13 |
| 0158 | 201.32 |
| 1824 | 187.26 |
| 1811 | 185.65 |
| 1800 | 157.13 |
| 1860 | 156.73 |
| 1681 | 132.31 |
| 0167 | 126.18 |
| 2495 | 119.35 |
| 0183 | 108.68 |
| 1852 | 98.80 |
| 1843 | 88.41 |
| 1846 | 87.67 |
| 1845 | 87.11 |
| 1809 | 83.18 |
| 1805 | 63.89 |
| 1832 | 62.98 |
| 1804 | 61.76 |
| 0157 | 55.98 |
| 1946 | 29.99 |
| 1945 | 29.89 |
| 1854 | 19.48 |
| 1865 | 8.44 |

Table 6 Fixed Peak Load - With Transmission Improvement

(a) global results

| | LOEE (MWh/yr) | LOLE (h/yr) | LCI (MW/int) | FOI (int/yr) | | | | |
|----------------------|------------------|----------------|-----------------|-----------------|-------|-------|-------|-------|
| average value | 16770 | 253.4 | 44.78 | 20.14 | | | | |
| std deviation | 15220 | 96.51 | 84.20 | 5.29 | | | | |
| confidence intervals | | | | | | | | |
| level | lower | upper | lower | upper | lower | upper | lower | upper |
| 95% | 14660 | 18880 | 240.1 | 266.8 | 42.19 | 47.38 | 19.41 | 20.87 |
| 99% | 13990 | 19550 | 235.8 | 271.0 | 41.37 | 48.20 | 19.17 | 21.11 |

(b) generation system results

| | LOEE (MWh/yr) | LOLE (h/yr) | LCI (MW/int) | FOI (int/yr) | | | | |
|----------------------|------------------|----------------|-----------------|-----------------|-------|-------|-------|-------|
| average value | 15690 | 92.77 | 128.7 | 6.77 | | | | |
| std deviation | 14810 | 64.15 | 104.8 | 3.46 | | | | |
| confidence intervals | | | | | | | | |
| level | lower | upper | lower | upper | lower | upper | lower | upper |
| 95% | 13640 | 17740 | 83.87 | 101.7 | 123.1 | 134.3 | 6.29 | 7.25 |
| 99% | 12990 | 18390 | 81.06 | 104.5 | 121.3 | 136.1 | 6.14 | 7.40 |

(c) transmission system results

| | LOEE (MWh/yr) | LOLE (h/yr) | LCI (MW/int) | FOI (int/yr) | | | | |
|----------------------|------------------|----------------|-----------------|-----------------|-------|-------|-------|-------|
| average value | 1079 | 192.7 | 4.94 | 16.35 | | | | |
| std deviation | 2321 | 83.15 | 10.53 | 5.10 | | | | |
| confidence intervals | | | | | | | | |
| level | lower | upper | lower | upper | lower | upper | lower | upper |
| 95% | 757.4 | 1400 | 181.2 | 204.2 | 4.58 | 5.30 | 15.64 | 17.06 |
| 99% | 655.6 | 1502 | 177.5 | 207.9 | 4.47 | 5.42 | 15.42 | 17.28 |

Table 7 With Load Model - Without Transmission Improvement

(a) global results

| | LOEE (MWh/yr) | LOLE (h/yr) | LCI (MW/int) | FOI (int/yr) | | | | |
|----------------------|------------------|----------------|-----------------|-----------------|-------|-------|-------|-------|
| average value | 794.0 | 56.85 | 12.24 | 19.85 | | | | |
| std deviation | 1075 | 21.96 | 30.23 | 6.39 | | | | |
| confidence intervals | | | | | | | | |
| level | lower | upper | lower | upper | lower | upper | lower | upper |
| 95% | 645 | 943 | 53.80 | 59.89 | 11.30 | 13.18 | 18.96 | 20.74 |
| 99% | 597 | 990 | 52.84 | 60.85 | 11.00 | 13.48 | 18.68 | 21.02 |

(b) generation system results

| | LOEE (MWh/yr) | LOLE (h/yr) | LCI (MW/int) | FOI (int/yr) | | | | |
|----------------------|------------------|----------------|-----------------|-----------------|-------|-------|-------|-------|
| average value | 121 | 0.84 | 135.4 | 0.38 | | | | |
| std deviation | 384 | 2.03 | 143.4 | 0.88 | | | | |
| confidence intervals | | | | | | | | |
| level | lower | upper | lower | upper | lower | upper | lower | upper |
| 95% | 68 | 174 | 0.56 | 1.12 | 103.1 | 167.6 | 0.26 | 0.50 |
| 99% | 51 | 192 | 0.47 | 1.21 | 92.96 | 177.8 | 0.22 | 0.54 |

(c) transmission system results

| | LOEE (MWh/yr) | LOLE (h/yr) | LCI (MW/int) | FOI (int/yr) | | | | |
|----------------------|------------------|----------------|-----------------|-----------------|-------|-------|-------|-------|
| average value | 672 | 56.29 | 9.86 | 19.62 | | | | |
| std deviation | 936 | 21.82 | 16.08 | 6.30 | | | | |
| confidence intervals | | | | | | | | |
| level | lower | upper | lower | upper | lower | upper | lower | upper |
| 95% | 542 | 802 | 53.26 | 59.31 | 9.35 | 10.36 | 18.74 | 20.48 |
| 99% | 501 | 843 | 52.31 | 60.27 | 9.19 | 10.52 | 18.47 | 20.77 |

Table 8 With Load Model - Without
Transmission Improvement

| Bus number | ENSB (MWh/yr) |
|------------|---------------|
| 1860 | 323.70 |
| 1813 | 286.44 |
| 1812 | 28.18 |
| 1971 | 16.30 |
| 1679 | 14.07 |
| 1807 | 10.65 |
| 1776 | 8.13 |
| 0700 | 7.07 |
| 1681 | 6.92 |
| 1717 | 6.84 |
| 9996 | 6.20 |
| 1869 | 6.15 |
| 1712 | 6.01 |
| 1810 | 4.91 |
| 1910 | 4.75 |
| 1834 | 4.31 |
| 1677 | 4.17 |
| 1861 | 4.15 |
| 1806 | 4.01 |
| 1909 | 3.77 |
| 1948 | 3.35 |
| 2496 | 2.74 |
| 1863 | 2.48 |
| 2498 | 2.12 |
| 1844 | 1.95 |
| 2499 | 1.85 |
| 1847 | 1.69 |
| 2497 | 1.60 |
| 1930 | 1.55 |
| 0158 | 1.54 |
| 0183 | 1.45 |
| 1824 | 1.43 |
| 1811 | 1.42 |
| 1852 | 1.34 |
| 1800 | 1.20 |
| 0167 | 0.97 |
| 2495 | 0.91 |
| 0157 | 0.84 |
| 1846 | 0.70 |
| 1843 | 0.68 |
| 1845 | 0.68 |
| 1809 | 0.64 |
| 1946 | 0.55 |
| 1805 | 0.49 |
| 1804 | 0.48 |
| 1832 | 0.48 |
| 1945 | 0.45 |
| 1854 | 0.15 |
| 1865 | 0.06 |

Table 9 With Load Model - With
Transmission Improvement

| Bus number | ENSB (MWh/yr) |
|------------|---------------|
| 1812 | 27.92 |
| 1807 | 11.41 |
| 1813 | 9.76 |
| 1776 | 9.33 |
| 1679 | 7.27 |
| 0700 | 7.16 |
| 9996 | 6.27 |
| 1869 | 6.23 |
| 1717 | 5.58 |
| 1971 | 5.08 |
| 1712 | 5.07 |
| 1810 | 4.97 |
| 1910 | 4.80 |
| 1677 | 4.23 |
| 1834 | 4.10 |
| 1806 | 4.06 |
| 1861 | 3.83 |
| 1909 | 3.82 |
| 1948 | 3.39 |
| 2496 | 2.78 |
| 1863 | 2.13 |
| 2498 | 2.15 |
| 1844 | 1.87 |
| 2499 | 1.87 |
| 1860 | 1.77 |
| 1847 | 1.71 |
| 2497 | 1.62 |
| 1681 | 1.58 |
| 1930 | 1.57 |
| 0158 | 1.56 |
| 0183 | 1.45 |
| 1824 | 1.45 |
| 1811 | 1.44 |
| 1800 | 1.22 |
| 0167 | 0.98 |
| 2495 | 0.93 |
| 1852 | 0.90 |
| 1846 | 0.71 |
| 1843 | 0.69 |
| 1845 | 0.68 |
| 1809 | 0.64 |
| 0157 | 0.62 |
| 1805 | 0.50 |
| 1804 | 0.49 |
| 1832 | 0.48 |
| 1946 | 0.45 |
| 1945 | 0.29 |
| 1854 | 0.15 |
| 1865 | 0.07 |

Table 10 With Load Model - With Transmission Improvement

(a) global results

| | LOEE (MWh/yr) | LOLE (h/yr) | LCI (MW/int) | FOI (int/yr) | | | | |
|----------------------|------------------|----------------|-----------------|-----------------|-------|-------|-------|-------|
| average value | 169 | 6.46 | 23.77 | 2.39 | | | | |
| std deviation | 752 | 8.69 | 75.73 | 2.28 | | | | |
| confidence intervals | | | | | | | | |
| level | lower | upper | lower | upper | lower | upper | lower | upper |
| 95% | 65 | 273 | 5.26 | 7.67 | 16.98 | 30.56 | 2.07 | 2.71 |
| 99% | 32 | 306 | 4.87 | 8.05 | 14.83 | 32.71 | 1.97 | 2.81 |

(b) generation system results

| | LOEE (MWh/yr) | LOLE (h/yr) | LCI (MW/int) | FOI (int/yr) | | | | |
|----------------------|------------------|----------------|-----------------|-----------------|-------|-------|-------|-------|
| average value | 121 | 0.84 | 135.4 | 0.38 | | | | |
| std deviation | 384 | 2.03 | 143.4 | 0.88 | | | | |
| confidence intervals | | | | | | | | |
| level | lower | upper | lower | upper | lower | upper | lower | upper |
| 95% | 68 | 175 | 0.56 | 1.12 | 103.2 | 167.6 | 0.26 | 0.50 |
| 99% | 51 | 192 | 0.47 | 1.21 | 92.96 | 177.8 | 0.22 | 0.54 |

(c) transmission system results

| | LOEE (MWh/yr) | LOLE (h/yr) | LCI (MW/int) | FOI (int/yr) | | | | |
|----------------------|------------------|----------------|-----------------|-----------------|-------|-------|-------|-------|
| average value | 47 | 5.81 | 3.13 | 2.13 | | | | |
| std deviation | 572 | 8.31 | 19.18 | 2.12 | | | | |
| confidence intervals | | | | | | | | |
| level | lower | upper | lower | upper | lower | upper | lower | upper |
| 95% | 0 | 127 | 4.70 | 7.01 | 1.31 | 4.96 | 1.83 | 2.42 |
| 99% | 0 | 152 | 4.34 | 7.37 | 0.73 | 5.53 | 1.74 | 2.51 |

APPENDIX VIII
NATIONAL GRID COMPANY REPORT

THE ANALYSIS OF THE NEW BRUNSWICK POWER SYSTEM USING ESCORT

-by-

P.T.Manning
National Grid Company
National Grid House
Sumner Street
London SE1 9JU

1. Introduction

This paper describes an analysis of the New Brunswick Power System using NGC's software ESCORT (1),(2),(3). This is part of the CIGRE WG 38.03 exercise on comparative software for Power System analysis.

2. Adequacy and security

Most reliability software undertakes what is termed an adequacy analysis (4). This allows generators and circuits to undergo random breakdown, but does not cover the operational requirement for the system to be secure. This operational requirement is for the system to be robust against certain defined faults. In effect an adequacy analysis assumes that, in the event of a fault, redispatch of generation (or, in extremis, load shedding) can be undertaken before cascade failure occurs.

A security analysis takes into account the requirement for the system to be robust against these defined failures.

3. The ESCORT program

ESCORT is a piece of software designed to model a Power System. It has been specifically designed to undertake a security analysis, i.e. the Power System is modelled with security constraints. The usual forms of these constraints can be expressed as "No single circuit outage must result in any other transmission circuit being overloaded". ESCORT has been designed as a planning tool rather than an operational one, and hence does not include any dynamic aspects, e.g. the requirement to have sufficient reserve on the system.

As such ESCORT is more powerful than the majority of pieces of software considered in this comparative exercise. Nevertheless, by giving ESCORT (as data) no contingency constraints, the effect of an adequacy analysis can be mimicked.

The analysis of the New Brunswick system did not require any software modifications to be made to ESCORT.

3.1 Limitations of ESCORT

The major limitations of ESCORT are two-fold:-

- i) It only undertakes a d.c. load flow analysis. Accordingly problems associated with reactive power shortfalls are not addressed.
- ii) No allowance is made for possible post-fault action (e.g. switching)

4. Modelling of the New Brunswick system

ESCORT requires 7 input files of data. Appendix 1 shows part of each of these input files; full details are not provided due to space limitations. These files are discussed below.

4.1 Network data.

The Network data file contains all transmission elements (irrespective of voltage level, or whether they are lines, transformers or cables.) The parameters are R and X (measured in % on 100MVA base), together with their rating (which can vary by season). In addition, the terminal end-points of each line are required, together with a unique alphanumeric identifier (for the New Brunswick system the code of L for line and X for transformer has been adopted).

For the New Brunswick exercise, the data supplied gave two transmission ratings. It has been assumed that the lower rating is used in the adequacy analysis (i.e. that which assumes immediate post-fault redispatch of generation) and the higher rating has been used in the security analysis. In other words, the low rating reflects normal operation, but in emergency conditions, i.e. immediately after a transmission fault, a higher or emergency rating can be accepted.

ESCORT was written to give a comparison between two different networks (generally before and after reinforcement). This is done in the Network file by having most circuits of type C (for constant), but a few circuits are type V (for Variable). Variable circuits are present in a network if there is a T (for True); absent if they are F (False). This has the great advantage that identical sets of random outages can be applied to each network, so that one is genuinely examining the effect of a reinforcement (and there is less danger of statistical freaks making it difficult to calculate the benefit of a reinforcement).

4.2 Generator data.

ESCORT allows generation to be modelled in two different ways. The first way is as a simple probabilistic generator, with certain probabilities of being available - similar to the treatment used in most other software. The second way is as a deterministic generator - i.e. its running regime can be pre-specified. This can be particularly relevant to energy-constrained hydro plants, for example, where ESCORT would allow them to be scheduled during the day but not the night.

The generator data is as supplied by New Brunswick Power, with the exception of Point Lepreau. In order to deal with the participation sale, Point Lepreau and its associated American load, has been modelled as a deterministic generator. For 21.12 hours a day (i.e. 88% of the time) Point Lepreau generates 657MW with a 230MW load at the appropriate USA busbar; for 2.88 hours/day (i.e. 12% of the time) there is no generation at Point Lepreau and no load at the USA busbar.

For certain analyses, discussed below, this was modified so that the 230MW load was present for 100% of the time.

Each generator has the usual parameters - name, node, production cost, breakdown rate, etc. Note in particular that each generator has an overhaul pattern (this can be used to downrate generators in the overhaul season if a specific maintenance schedule is not used) and a fuel type. This latter is purely for ease of tabulating output (e.g. ESCORT will give details of how much energy is supplied from each different fuel).

4.2.1 Phantom Generators

If the generation is insufficient to supply the demand then the software will label the case as infeasible (i.e. there is no feasible solution). In order to correctly analyse this case, a number of 'phantom' generators were placed on the system at strategic places. These generators were all given fuel type "Disconnection" and a very high cost, so that they would only be scheduled if there was no real plant which could supply the load. The expected energy not supplied is then equal to the total energy produced by these phantom generators.

In a similar fashion, curtailable load was also modelled as a generator (of type IL, for Interruptible Load) at an appropriate price.

4.3 Demand Data

The nodal demand data was as provided by New

Brunswick Power. Loads were split into three categories :-

- i) NB Industrial loads which would be constant throughout the year (Area N.B.IND)
- ii) NB ordinary loads which would vary by season (Area N.B.Power)
- iii) Four other areas representing Hydro-Quebec, Nova Scotia, Maine Power and Prince Edward Island

The way in which the load varies throughout the year is given in the Period data (see below)

4.4 Period Data

The year was split into 5 periods, as follows:-

- i) Peak period
- ii) Winter
- iii) Spring/Fall
- iv) Summer
- v) Point Lepreau maintenance period.

The Point Lepreau maintenance period was modelled separately in order to correctly model the effect of the participation sale.

Each period was then divided into a number of demand levels, each lasting for a specified time, in order to model the New Brunswick load curve. A total of 28 demand levels were used to model the whole year.

The nodal demands (see 3.3 above) were scaled separately in each demand block. New Brunswick industrial loads (see section 4.3 above) were not scaled, while other NB demands were scaled by the appropriate factor to give the correct overall load shape.

4.5 Outage Data

This file contains the probabilistic line outage data for the transmission circuits. Each circuit is referred to by its unique code (see Network data). It is possible here to define multiple (common-mode) outages.

4.6 Contingencies

This file lists all the contingencies which ESCORT (in its security-constrained form) will consider. For the New Brunswick system all single circuit outages that did not split the system were

considered to be credible contingencies, with the exception of the circuit at Eel River connecting busbars 1805 and 1948. ESCORT has the capability to have multiple circuit contingencies, although this facility was not utilised in this exercise.

4.7 Maintenance data

In this file a maintenance schedule is given. ESCORT can maintain both circuits and generators, although for this exercise only generator maintenance has been included.

5. Modelling issues

There are three important aspects whereby ESCORT has to make assumptions about how the system will be operated in practice. These areas are :

- How energy-limited hydro plant is modelled
- How a system split is modelled
- How post-fault operator action is modelled.
- How load-point indices are calculated

These are each considered in turn.

5.1 Modelling of energy limited hydro plant.

There are two ways in which energy-limited hydro plant can be modelled. The first (and the commonest method in reliability software) is to pre-determine the output schedule. The hydro plant is modelled as, for example, at 100% output during the day, 80% output during the evening and 20% output during the night. This method ensures that the energy constraint is satisfied; however, it is rather pessimistic as it does not allow any freedom for the operator. In particular it will not allow the operator to use hydro plant as reserve, and may come to the stage where demand is modelled as being disconnected when in practice there is unused hydro capacity available.

The second way is to model the hydro plant as if it were thermal plant, but to put in a cost which will ensure that it is only scheduled during part of the day. In New Brunswick this will probably mean allocating a 'cost' midway between coal and oil. Provided the cost is correctly determined, the energy constraints will be met while the pessimism of method one above is eliminated.

For the New Brunswick system the hydro plant was allocated the costs given in Table 1. These differ from the costs given in the data, which were not found to give the correct overall energy supplied. The resultant energy utilisation is also shown in table 1 (as the ESCORT utilisation value), where it

may be compared with the actual energy deemed available; it can be seen that the figures used actually gave a total over-utilisation of approximately 4%

Table 1 Costs allocated to Hydro Plants (in \$Cdn/MWhr)

| | | | | Utilisation | |
|-------------|--------|----------|--------|-------------|--------|
| | Winter | Spr/Fall | Summer | NB Value | ESCORT |
| Beechwood | 35.7 | 32.3 | 32.3 | 478 | 580 |
| Grand Falls | 32.5 | 32.5 | 32.5 | 210 | 225 |
| Mactaquac | 37.5 | 34.5 | 34.5 | 1609 | 1592 |
| | | | Total | 2297 | 2397 |

5.2 System Splits

There are a number of outages that split the system. Sometimes these are cases where a load is connected by a single circuit only; clearly loss of that circuit will result in the load being isolated. Secondly, there are a number of cases where a larger scale system split can occur (e.g. loss of the circuit from Edmundston to St. Andre).

In common with much other reliability software, the treatment of system splits need to be handled carefully. ESCORT makes the following assumptions:-

- 1) If an outage splits the system then it is logged as an infeasible case and the simulation is ignored.
- 2) If a contingency would split the system, then it is ignored.

These assumptions would give rise to a considerable optimism in the New Brunswick case, which is poorly interconnected. (ESCORT was designed for a more closely meshed system, where system splits are much less likely). Accordingly two measures were taken to ensure that ESCORT did not give optimistic results:-

- 1) In cases where line outages were likely to give rise to a system split, a dummy line with a high reactance and low capability was put in parallel with the real line. This dummy line was given 100% reliability. This meant that, if the relevant line was outaged, the network would still be connected.

2) In addition, a phantom ('disconnection') generator was placed at the node likely to be disconnected. In the event that the critical outage occurred, this phantom generator would be run and give rise to energy not supplied.

This modelling is shown in Figure 1.

5.3 Post-fault Operator Action

The New Brunswick system contains a number of normally open circuit breakers which can be closed in an emergency. Typically this would happen in the event of certain outages. ESCORT, in common with most other software, can only handle this in clearly defined circumstances (e.g. if there is a very simple rule of the sort "close circuit breaker X if generator G is unavailable).

5.4 Load Point Indices

This report does not give load point indices (i.e. identifying individual buses where load is curtailed).

The reason for this is part of the philosophy of ESCORT. Because ESCORT is an optimising program, it will optimise (i.e. minimise) costs. The way that ESCORT operates mean that the implicit load-curtailement strategy adopted will be to curtail load at the most effective bus-bars; as ESCORT takes losses into account this will be included within the strategy as a second order effect. In particular, therefore, if there is a shortfall in generation then load will be curtailed at the bus-bar which minimises system losses, and not uniformly (as would normally be assumed).

Because this load-curtailement strategy is unrealistic (in practice the load to be curtailed will normally be evenly spread so that every load point suffers equally) load point indices are not published.

6. Results

6.1 Results of Winter Peak only analysis, adequacy analysis, participation sale ignored

The first task was to provide some comparisons between ESCORT and the other items of software. For this exercise, ESCORT was run in the following mode, with 4000 simulations:-

1) No contingencies

ii) The participation sale was not modelled; 230 MW of Maine Power demand was assumed constant whether Point Lepreau was available or not.

iii) Only winter peak demand level was considered; this demand level was assumed to last throughout the year.

Results for Energy not supplied are as follows:-

| | <u>Base Case</u> | <u>Improvement</u> |
|---|------------------|--------------------|
| Energy not supplied due to generation | 13.1 | 13.0 |
| Energy not supplied due to transmission | 80.3 | 2.4 |
| Total | 93.4 | 15.4 (TWhrs) |

ESCORT also gives, as output, details of the limiting circuits. The following circuits were limiting (i.e. if the circuit rating had been increased, then a more economic dispatch was available). Note that this does not mean that the Expected Energy Not Supplied would have decreased.

Limiting circuits (in decreasing order of activity, expressed as hours/year for which the circuit is limiting) are as follows:-

| | <u>Base Case</u> | <u>Improvement</u> | |
|------------------|------------------|--------------------|------------|
| CC1837 to MI1860 | 1954 | 264 | hours/year |
| NC1807 MB1969 | 1913 | 2037 | hours/year |
| MQ1809 DO1861 | 101 | 99 | hours/year |
| IR1681 CB1813 | 17 | 0 | hours/year |
| CC1837 CC1836 | 10 | 0 | hours/year |
| NO1901 TP1776 | 6 | 6 | hours/year |
| TP1928 MB1969 | 2 | 2 | hours/year |
| KE1827 NA1846 | 2 | 2 | hours/year |
| RI1712 MN1812 | 2 | 2 | hours/year |
| IR1681 NO1901 | 0 | 8 | hours/year |

It should be noted that the effect of the transmission improvement is to dramatically reduce the proportion of time for which the line from CC1837 to MI1860 is restrictive (although it has not completely eliminated the restriction). However, the transmission constraints on some other lines (e.g. from IR1681 to NO1901) now become active; previously they were hidden, but the transmission improvement has allowed them to become visible. Values of marginal gains (i.e. the benefit of increasing the circuit rating by 1 MW) are shown in Table 10.3 of the main document, and are not repeated here. It

should be noted that the marginal gains are actually defined in ESCORT as the financial saving (in \$Cdn) per extra MW of capacity. In the main report the assumption is made that the marginal gain is entirely due to a saving in energy not supplied (costed here at an arbitrary \$500Cdn/MWhr) whereas in reality a component of the marginal gain may be due to a more economic dispatch (typically a saving of \$30Cdn/MWhr). The effect of this assumption is not considered significant.

6.1.1 Effect of Participation Sale.

A subsidiary run was done to evaluate the effect of modelling the participation sale "properly". This gave the following results:-

| | Base Case | Improvement |
|---|-----------|-------------|
| Energy not supplied due to generation | 5 | 5 |
| Energy not supplied due to transmission | 82 | 3 |
| Total | 87 | 8 (TWhr) |

The two major restricting circuits displayed active restrictions for the following durations:-

| | Base Case | Improvement |
|---------------|-----------|-----------------|
| NC1807 MB1969 | 2533 | 2221 hours/year |
| CC1837 MI1860 | 1137 | 59 hours/year |

It can be seen that the effect of modelling the participation sale 'properly' is to reduce the EENS due to generation; a comparatively small effect on transmission is seen.

6.2 Effect of Transmission Contingencies

For this run, winter peak only again was studied, with the participation sale modelled 'correctly'. Only 50 simulations were used, which is inadequate for convergence; hence there is a degree of uncertainty in the figures below. Line limits were the higher values (see section 4.1). The following results for energy not supplied were obtained:-

| | Base Case | Improvement |
|--------------------------|-----------|-------------|
| EENS due to generation | 2.2 | 2.2 |
| EENS due to transmission | 187 | 1.2 |
| Total | 189 | 3.4 (TWhr) |

The following transmission outages were constraining the system. The figures show the proportion of time for which the constraint was active (expressed in hours/year):-

| Failing circuit | Overloaded circuit |
|-----------------|--------------------|
|-----------------|--------------------|

| | | |
|-----------------|-------------------------------|-----------------|
| CC1836 - NO1900 | IR1681 - CB1813 (base case) | 5296 hours/year |
| | IR1681 - CC1837 (improvement) | - hours/year |
| NS168 - SA1850 | NS158 - NS167 (base case) | 3975 hours/year |
| | (improvement) | 1951 hours/year |
| ER1805 - ER1948 | ER1805 - ER1830 (base case) | 6335 hours/year |
| | (improvement) | 6685 hours/year |
| CC1836 - CC1837 | CC1836 - CC1837 (base case) | 7377 hours/year |
| | (improvement) | 21 hours/year |
| ST1868 - ER1866 | GF1802 - TP1804 (base case) | - hours/year |
| | (improvement) | 21 hours/year |

Of these, the first and fourth outages represents the weakness that the transmission improvement is designed to rectify. The second is actually a weakness within the Nova Scotia system and might represent a modelling deficiency rather than a weakness in the system. The third outage (at Eel River) is a short line between two sub-stations that subsequent discussion indicates should not be considered a credible failure. The fifth overload occurred when the circuit KE1803-ST1868 was faulted.

The effectiveness of the transmission reinforcement in the 'improvement' case is self-evident.

6.3 All Year round analysis

This part of the document deals with the results when the system is modelled all year round. It should be noted that generator maintenance was included, but not transmission line maintenance; the circuit ratings given were assumed to apply all year round.

As part of the ESCORT output, a thorough analysis of demand and generation is provided. A summary of the New Brunswick energy balance is given below.

Energy Utilised

| | |
|----------------------------------|-------------|
| New Brunswick - Ordinary Loads | 9.90 (TWhr) |
| New Brunswick - Industrial Loads | 5.85 |
| P.E.I. | 0.52 |
| Maine Power Corp. | 2.02 |
| Hydro-Quebec | 0.17 |
| Losses | 0.33 |
| Total | 18.79 |

and this energy was supplied by the following fuels:-

| | |
|---------|------|
| Nuclear | 4.68 |
|---------|------|

| | |
|------------------------------|------|
| Coal | 5.88 |
| Oil | 5.34 |
| Gas Turbines | 0.08 |
| Hydro | 2.75 |
| Imports | 0.04 |
| Interruptible load curtailed | 0.01 |
| Normal load curtailed | 0.01 |
| Total 18.79 TWhr | |

| | | |
|-----------------|------|---------------|
| US700 to LP1843 | 16.3 | 16.4 GWhrs/yr |
| RH1712 NC1807 | 12.5 | 12.3 |
| KE1803 LP1843 | 10.8 | 11.1 |
| MN1812 GL1811 | 21.3 | 20.9 |
| CC1836 NO1900 | 21.4 | 21.1 |
| CC1837 MI1860 | 11.5 | 6.7 |
| CC1837 MI1862 | 11.3 | 6.4 |

The Maine Power demand represents a continuous demand of 230MW, i.e. it assumes that the New Brunswick system is supplying 230MW to Maine whether Pt. Lepreau is available or not.

6.3.1 Financial Benefit of Transmission Improvement

The primary task of ESCORT is to determine the benefit of a proposed transmission reinforcement. The transmission improvement case here shows the following benefits:-

| | |
|--------------------------------------|--------------|
| Reduction in energy not supplied :- | 9.5 GWhrs/yr |
| Reduction in economic dispatch costs | \$1.7M Cdn |
| Reduction in system losses | \$0.5M Cdn |

The reduction in economic dispatch costs is largely derived from the ability to run more generation at Coleson Cove, with a reduction in more expensive generation elsewhere on the system. The transmission system is preventing the generation from being dispatched economically while retaining system security.

At an effective cost of energy not supplied of \$1000Cdn/MWhr this would give a total economic benefit of \$12M Cdn per year, which would need to be compared with the capital cost of the transmission reinforcement. It should, however, be emphasised that this economic benefit is that as seen by the ESCORT model; in many cases the savings can be achieved by, for example, operational action without requiring extra capital expenditure.

6.3.2 System Losses

An often neglected part of system planning is the minimisation of transmission losses. In the New Brunswick system, ESCORT demonstrates that losses total 333 GWhrs per year. The following circuits have annual losses exceeding 10 GWhrs/year:-

| | |
|------------------|------------------|
| <u>Base Case</u> | Improvement Case |
|------------------|------------------|

In some cases the losses represent high power flows, and in other cases they represent particularly long circuits; however this indicates the areas where the largest components of losses occur.

The largest value occurs on the 87 km long circuit between Coleson Cove and Norton. A histogram of the line flows on that circuit is shown in Figure 2. This shows the proportion of time the line flow lies within each 10% band (on an all-year-round basis).

7. Conclusions

ESCORT has been successfully applied to the New Brunswick system. It has overcome a number of modelling problems inherent in that system, in particular the modelling of a participation sale and the dispatch of energy-limited hydro generation. The benefits of the transmission improvement case are quantified, although ESCORT cannot say if it is economic as the costs of the improvement are not known.

REFERENCES

- 1) Dunnett R.M. and Berry P.E., Contingency constrained economic dispatch algorithm for transmission planning, Proc IEE Part C, Vol 136, No. 4 (1989)
- 2) Manning P.T. and Plumtre P.H., Reliability Modelling of the CEGB's Power system incorporates economic optimisation while remaining fault tolerant, Reliability '89, Brighton, U.K. (1989)
- 3) Dunnett R.M. and Macqueen J.F., Transmission Planning by Monte-Carlo optimisation. 10th Power Systems Computational Conference, Graz, Austria (1990)
- 4) Manning P.T. and Plumtre P.H., The practical use of reliability analysis in system planning, CIGRE symposium on electric power systems reliability, Montreal, Canada (1991)

Figure 1

MODELLING OF CIRCUITS WHICH COULD SPLIT THE SYSTEM





Figure 2: All year round line flows on the Coleson Cove - Norton circuit



APPENDIX 1

ESCORT Input Data for the New Brunswick System

This Appendix gives a partial listing of the input data for the New Brunswick system. Omitted is the file giving details of output controls, random number seeds, number of simulations and a number of other options; in addition, in the interests of space saving, only a partial listing is given of most of the data files. Full listings are available from the author.

///

FILE: APPENDIX NB A1 CMS RELEASE 5.0 FOR NATIONAL GRID COMPANY

 * FILE 1 NETWORK DATA *

PAGE 00001

PROPOSALS
 NEW BRUNSWICK
 COLESON COVE

| ----- | | | | | | | | | |
|---------|--------------------|--------|--------|--------|-----|------|------|---|------|
| (| LINE DATA (ESCORT) | | | | | | | | |
| (| | | | | | | | | |
| (| | | | | | | | | |
| NETWORK | | | | | | | UVWX | | |
| | | | | | DJF | EFGH | PQRS | | |
| L1175A | GF1802 | TP1804 | 000.05 | 000.17 | 230 | 230 | 230 | I | C |
| L1111B | GF1802 | TP1817 | 001.43 | 005.73 | 230 | 230 | 230 | I | C |
| L2002 | KE1803 | CC1836 | 000.41 | 003.87 | 950 | 950 | 950 | I | C |
| L3003 | KE1803 | LP1843 | 000.47 | 004.47 | 950 | 950 | 950 | I | C |
| L3011 | KE1803 | ST1868 | 000.51 | 004.84 | 950 | 950 | 950 | I | C |
| L1175B | TP1804 | ST1849 | 000.94 | 003.45 | 230 | 230 | 230 | I | C |
| L1115A | ER1805 | TP1824 | 002.88 | 011.92 | 230 | 230 | 230 | I | C |
| L1107 | ER1805 | DA1826 | 0.21 | 1.86 | 478 | 478 | 478 | I | C |
| L1130A | ER1805 | TP1865 | 1.65 | 6.16 | 230 | 230 | 230 | I | C |
| ERBUS | ER1805 | ER1948 | 0.0000 | 000.01 | 280 | 280 | 280 | I | C |
| L1115B | BA1806 | TP1824 | 002.36 | 009.74 | 230 | 230 | 230 | I | C |
| L1106A | BA1806 | TP1928 | 001.38 | 005.70 | 230 | 230 | 230 | I | C |
| L1127 | BA1806 | BM2497 | 001.62 | 006.54 | 230 | 230 | 230 | E | C |
| L1105A | NC1807 | TP1832 | 002.41 | 010.29 | 230 | 230 | 230 | I | C |
| L1106C | NC1807 | MB1969 | 000.87 | 003.61 | 230 | 230 | 230 | I | C |
| L1133 | MQ1809 | KE1827 | 000.33 | 002.86 | 478 | 478 | 478 | I | C |
| L1134 | MQ1809 | KE1827 | 000.33 | 002.86 | 478 | 478 | 478 | I | C |
| L1174A | MQ1809 | DO1861 | 001.11 | 005.19 | 478 | 478 | 478 | I | C |
| L1102 | MV1810 | GL1811 | 002.99 | 012.37 | 230 | 230 | 230 | I | C |
| L1103A | MV1810 | NA1845 | 000.32 | 001.34 | 230 | 230 | 230 | I | C |
| L1112A | MV1810 | NA1846 | 000.32 | 001.27 | 230 | 230 | 230 | I | C |
| L1174B | MV1810 | DO1861 | 000.52 | 001.92 | 230 | 230 | 230 | I | C |
| L1101 | GL1811 | MN1812 | 005.78 | 024.14 | 230 | 230 | 230 | I | C |
| L1105B | GL1811 | TP1832 | 004.69 | 020.06 | 230 | 230 | 230 | I | C |
| L1148 | MN1812 | SA1839 | 000.91 | 003.76 | 230 | 230 | 230 | I | C |
| L1151 | MN1812 | SA1839 | 000.91 | 003.76 | 230 | 230 | 230 | I | C |
| L1190C | MN1812 | TP1945 | 000.53 | 002.00 | 230 | 230 | 230 | I | C |
| L1124B | MN1812 | TP1946 | 000.53 | 002.00 | 230 | 230 | 230 | I | C |
| L1122 | CB1813 | RO2496 | 000.04 | 000.17 | 230 | 230 | 230 | E | C |
| L1147A | CB1813 | MI1860 | 0.58 | 2.39 | 190 | 190 | 190 | I | C |
| L1165B | CB1813 | MI1862 | 0.58 | 2.39 | 190 | 190 | 190 | I | C |
| TEST1 | IR1681 | CC1837 | 1.81 | 8.48 | 140 | 140 | 140 | I | V FT |
| TEST2 | IR1681 | NO1901 | 3.06 | 12.65 | 140 | 140 | 140 | I | V FT |
| L1144 | TP1817 | US1896 | 0.43 | 1.78 | 230 | 230 | 230 | I | C |
| L2130A | BA1829 | MB1964 | 000.82 | 004.68 | 478 | 478 | 478 | I | C |

 * FILE 2 GENERATOR DATA *

(NATIONAL DEMANDS AND OTHER PERIOD DATA

(3274 MW - ACS DEMAND TO SCALE TO FOR WHOLE STUDY
 (5, 6, 4 - NUMBER OF PERIODS, AREAS, OUTSIDE SOURCES
 (INDIVIDUAL PERIOD DATA FOLLOWS:

(PEAK PERIOD
 (-----
 2 DAY TYPES
 DJF RATING PERIOD
 (NO. BLKS
 (DAYS
 (LEPR 1.76 1
 LEPR 1 1

PEAK
 DURATION 21.12
 OUTPUT T
 NATIONAL 100.0
 N.B.POWER 2427
 N.B.IND 669
 N.S.POWER 118
 P.E.I. 60
 HYDRO QUE 0.1
 M.P.S. 0.1

(
 HYDRO-Q1 -200
 HYDRO-Q2 -200
 LEPREAU 657
 US-PS -230
 (

 NOLP 1 1

PEAK
 DURATION 2.88
 OUTPUT T
 NATIONAL 100.0
 N.B.POWER 2427
 N.B.IND 669
 N.S.POWER 118
 P.E.I. 60
 HYDRO QUE 0.1
 M.P.S. 0.1

(
 HYDRO-Q1 -200
 HYDRO-Q2 -200
 LEPREAU 0.0
 US-PS 0.0
 (

 WINTER PERIOD

224

* FILE 5 OUTAGE DATA *

Table with 6 columns (1-6) and rows for CLASS: random, L1152, L1116, L1149A, L1109 TEST9, TEST1, TEST2, L1118, L1114, L1149B, L1199B, L1199A, L1111A L1111B, L1125A. Values are probabilities ranging from 0.0 to 0.027.

* FILE 6 CONTINGENCY DATA *

CONTINGENCY OUTAGE LIST FOR SAMPLE PROBLEM
Table with 6 columns (1-6) and rows for LNS2, L3006, TEST1, L1109, L1199A, L1111B, L1175B, L1105A, L1103A, L1174B, LNS4, L3001, TEST2, L1118, L1199B, L2002, L1115A, L1106C, L1112A, L1101, L3006, L3016, TEST3, L1114, L1111A, L3003, L1130A, L1133, L1105B, L1148, L1152, L1192, L1149A, L1149B, L1125A, L1176, L3011, L1115B, L1106A, L1134, L1174A, L1126A, L1175A, L1102.

* FILE 7 MAINTENANCE DATA *

MAINTENANCE SCHEDULE DATA
PERIOD DATA (PER IN COL 1-3 INDICATES START OF THIS BLOCK)

APPENDIX IX

UNIVERSITY OF SASKATCHEWAN REPORT

COMPOSITE SYSTEM RELIABILITY EVALUATION PROGRAM
(COMREL)

COMREL was developed at the University of Saskatchewan as a result of extensive work done in the area of composite or bulk power system adequacy assessment. The program is based on a failure modes and effects analysis procedures provided through the contingency enumeration approach. Some important features of the program are as follows:

1. The program is suitable for evaluating the adequacy indices of moderately sized power systems. It calculates individual load point as well as system indices. A comprehensive list of the indices calculated is given in Reference [1].
2. The program considers simultaneous independent outages of generating units (up to 4th level), of transformers/transmission lines (up to 3rd level) and of generating units AND lines/transformers (up to 3rd level). Common mode outages of transmission lines/transformers and station-initiated outages can also be considered. Data for common mode outages is included in the same input file as that for generators/lines/transformers and buses, etc. Outage events due to station outages are evaluated using a separate computer program and are included in the form of a separate input data file while executing COMREL.
3. The program is equipped with three solution techniques, namely linear network flow method, DC load flow technique and fast decoupled AC load flow method. The network flow model can be used to examine the continuity of power supply at various load centers. The DC load flow technique is quite simple to apply and is fast and free of convergence problems but only provides an estimate of the line power flows without including any estimate of the bus voltages and the reactive power limits of the generating units, etc. If the quality of the power supply, i.e., proper voltage levels and generating units MVAR limits are an integral part of the adequacy criteria, then more accurate AC load flow methods such as the fast decoupled load flow method should be used. Any one of these three methods can be selected by the user for evaluating the system performance.
4. The base case load flow values are used as initial estimates for 1st level outages. Similarly the values for the load flow quantities at an outage level are used as the initial estimates for the next outage level contingencies. This procedure results in a faster convergence of the load flow for the outage events.
5. Computational time is reduced by:
 - a. sorting identical generating unit contingencies such that the indices for only one identical unit are calculated.
 - b. restricting the calculation of higher level outages (5th or more for generators and 4th or more for lines/transformers) by modifying the probability and the frequency of the highest level outages considered, and
 - c. not solving those contingencies which have a frequency of occurrence less than a prespecified cut-off limit [2].
6. Any given set of selected generating unit and/or line contingencies can also be evaluated.
7. Load at each bus is classified into two categories, curtailable (some percentage of the total bus load) and firm (remaining load). In the case of a capacity deficiency, curtailable load is interrupted first followed by the interruption of firm load if necessary. The load curtailment philosophy utilized in COMREL is quite flexible. The load interruption may be localized in the neighbourhood of a disturbance or it can be distributed over a wider system area. This provision has been made in the load

curtailment algorithm by defining three load curtailment passes [3]. Proportional load is interrupted at those buses which are covered by the pass specified. Line overloads are alleviated by generation rescheduling and load shedding at appropriate buses which is governed by the number of load curtailment passes (1, 2 or 3) selected by the user.

8. If a generating unit outage at a generation bus results in capacity shortfall at that bus, then the generation at other generation buses having reserve capacity is increased to meet the deficiency. If, however, the system remains deficient even after supplying all the available system spinning reserve, then load is curtailed at the buses covered by the load curtailment pass specified.
9. Additional features associated with using the AC load flow through COMREL are:
 - a. In case of bus isolation due to line(s) outages AC load flow is conducted for the remaining buses and lines in the system.
 - b. In case of a line outage causing a split network condition, the network flow method is used to check the adequacy of the split networks.
 - c. Voltage violation cases and non-convergent situations are corrected by injecting reactive power and rescheduling the generating units. Heuristic algorithms have been developed for solving such cases [4].

Methods/Philosophies Used for the N.B. System

Generating unit outages up to 4th level, transmission line/transformer outages up to 2nd level and combined generator and line/transformer outages up to 2nd level were considered. Sorting of identical generating units was done. Three load curtailment passes

were used. Effects due to higher level unit and/or line outages were not considered. A frequency cut-off limit of 0.1E-09 was used. Curtailable load was selected as 5% and the remaining 95% was used as firm load. The base case load flow was conducted using the AC load flow method and the contingencies were solved using the DC load flow technique (unless otherwise specified). Common mode and/or station outages were not considered.

References

1. Billinton, R. and Allan, R.N., Reliability Evaluation of Power Systems, Pitman Books, New York and London, 1984.
2. Billinton, R. and Kumar, S., "Effects of Higher-Level Independent Generator Outages in Composite System Adequacy Evaluation", IEE Proceedings, Vol. 134, Part C, pp. 17-26, Aug., 1986.
3. Billinton, R. and Kumar., "Pertinent Factors in the Adequacy Assessment of a Composite Generation and Transmission System", Transactions of the Engineering & Operating Division, Canadian Electrical Association Vol. 25, Part 3, No. 86-SP-141, 1986.
4. Kumar, S. and Billinton, R., "Low Bus Voltage and Ill-Conditioned Network Situations in a Composite System Adequacy Evaluation", IEEE Transaction on Power Apparatus and System, Vol. PWR-2, August 1987, pp. 652-659.

MECORE COMPUTER PROGRAM

MECORE is a computer program developed at the University of Saskatchewan for composite generation and transmission system adequacy assessment. This program is based on a combination of Monte Carlo simulation and the enumeration approach. A Monte Carlo simulation method is used to calculate the annualized indices and a hybrid method utilizing an enumeration approach for aggregated load states is used to calculate the annual indices. This program includes many system considerations such as generating unit derated states, transmission line common cause outages, regional weather effects and bus load

uncertainty and correlation, etc. A brief description of the MECORE program is as follows [1-3]:

1. A multi-step load model is created which eliminates the chronology and aggregates the load states using hourly load records during one year. The number of load level steps depends on the sensitivities of the composite system adequacy indices to load variation. It is necessary to use many steps in the case of sensitive composite systems and fewer steps in the case of non-sensitive systems. Annualized indices are calculated first by using only the single peak load level and expressed on a base of one year. A set of ratios of generation-transmission adequacy indices can be obtained from the annualized indices based on the peak load level and used to judge sensitivities of composite systems to load variation. All load level steps are considered successively and the resulting indices for each load level are weighed by their probabilities to obtain the annual indices.

2. The system states at a particular load level are selected by using Monte Carlo simulation techniques. This procedure includes the following:

a. Generating unit states are modeled using multi-state random variables. The MECORE program can therefore recognize multi-derated-states of generating units. A user has three options for a generating unit: (a) two-state model; (b) three-state model; and (c) four-state model.

b. Transmission line states are modeled using two-state (up and down) random variables. The transmission line forced outage rates and repair times are determined using a method for recognizing regional weather

effects. A uniformly distributed random number is sampled to select a transmission line state according to the calculated weather-related forced outage rates. Transmission line common causes outages are simulated by separate random numbers. A user has the following options: (a) no weather effect; (b) entire system in common weather; (c) recognition of regional weather; and (d) common cause outage plus (a) or (b) or (c).

c. Bus load uncertainty and correlation are modeled using a correlative normal distribution random vector. A tabulating technique of normal distribution sampling and a correlation sampling technique are used to select bus load states. A user has three options: (a) independence between bus loads; (b) complete dependence between bus loads; and (c) different degrees of correlation between bus loads.

3. A direct analytical approach of system analysis, which is based on DC load flow relationship, is used to judge if a drawn system state definitely creates no load curtailment. A minimization model is solved only for the relatively few contingency states which may lead to load curtailment.

4. A linear programming model is used to reschedule generation, alleviate line overloads and avoid load curtailment if possible or to minimize total load curtailment if unavoidable. The load curtailment philosophy is incorporated in this minimization model to calculate realistic bus indices. Loads of each bus are divided into several parts according to importance. When load curtailment is unavoidable, the least important part is curtailed first, then the next least important and at last the most important part.

REFERENCES

1. R. Billinton and Li Wenyuan, "Hybrid Approach for Reliability Evaluation of Composite Generating and Transmission Systems Using Monto-Carlo Simulation and Enumeration Technique", IEE Proceedings-C, Vol. 138, No. 3 May, 1991
2. Li Wenyuan and R. Billinton, "Effect of Bus Load Uncertainty and Correlation in Composite System Adequacy Evaluation", IEEE/PES 1991 Winter Meeting, 91 WM 175-0 PWRs, New York, Feb. 1991
3. R. Billinton and Li Wenyuan, "A Novel Method of Incorporating Weather Effects in Composite System Adequacy Evaluation", IEEE/PES 1991 Winter Meeting, 91 WM 191-7 PWRs, New York, Feb. 1991.

CIGRE EENS System Indices

HLI Evaluation

| | |
|--|--------------------|
| Segmentation Method | EENS=16.215 GWh/yr |
| F&D Method | EENS=14.661 GWh/yr |
| Monte Carlo Simulation GWh/yr Method | EENS=15.522 |

HLII Evaluation Using COMREL

| | |
|---|--------------------|
| Constrained Case: Base Case | EENS=46.696 GWh/yr |
| Constrained Case: Trans. Improvement Case | EENS=20.566 GWh/yr |
| Constrained Case: Base Case CPU Time | 2 hrs, 48 min. |
| Constrained Case: Trans. Improvement case CPU time | 2 hrs, 05 min. |

MLII CONSTRAINED: BASE CASE STUDY RESULTS (ANNUALIZED)

SYSTEM INDICES

NUMBER OF LOAD BUSES INCLUDED IN INDICES= 49
 TOTAL INSTALLED CAPACITY= 3512.800
 TOTAL LOAD AT BUSES INCLUDED IN INDICES= 3987.30
 BULK POWER SUPPLY DISTURBANCES= 148.53984
 PROBABILITY OF ALL ELEMENTS IN SERVICE = 0.043100125641534

IEEE INDICES

BULK POWER INTERRUPTION INDEX= 1.32487 MW/MW-YR
 EXPECTED ENERGY NOT SUPPLIED= 44695.58984 MWH/YR
 BULK POWER ENERGY CURTAILMENT INDEX= 11.71108 MWH/MW-YR
 BULK POWER SUPPLY AVERAGE MW CURTAILMENT INDEX= 40.98433 MW/DISTURBANCE
 SEVERITY INDEX= 702.465 SYSTEM-MINUTES
 MODIFIED BULK POWER ENERGY CURTAILMENT INDEX= 0.00133688

SYSTEM INDICES: AVERAGE VALUES

AV. % OF LOAD CURTAILMENTS/LOAD PT./YEAR= 5.97625
 AV. % OF VOLTAGE VIOLATIONS/LOAD PT./YEAR= 0.00000 BEFORE REACTIVE COMP. ADDED
 AV. % OF VOLTAGE VIOLATIONS/LOAD PT./YEAR= 0.00000 AFTER REACTIVE COMP. ADDED
 AV. LOAD CURTAILED/LOAD PT./YEAR= 124.24700 MW
 AV. ENERGY CURTAILED/LOAD PT./YEAR= 752.97119 MWH
 AV. % OF HRS OF LOAD CURTAILMENT/LOAD PT./YEAR= 46.37336 HRS

SYSTEM INDICES: MAXIMUMS

MAX. LOAD CURTAILED= 482.06 FOR CONTINGENCY N81= 7 N82= 0 N83= 0 N84= 0 LOUT1= 31 LOUT2= 0 LOUT3= 0 L1= 14
 PROB.=0.00000017 FREQ 0.00045318
 MAX. ENERGY CURTAILED= 3672.97 FOR CONTINGENCY N81= 0 N82= 0 N83= 0 N84= 0 LOUT1=113 LOUT2=114 LOUT3= 0 L1= 0
 PROB.=0.00000005 FREQ 0.00003712

MLII CONSTRAINED: BASE CASE STUDY RESULTS (ANNUALIZED)

| BUS | FAILURE PROB | FAILURE FREQ | 99% CURTAILMENTS | | TOTAL LOAD SHED | | TOTAL ENERGY CURTAILED | | TOTAL DURATION | |
|------------|--------------|--------------|------------------|----------|-----------------|----------|------------------------|----------|----------------|----------|
| | | | (ANNUALIZED) | | (ANNUALIZED) | | (ANNUALIZED) | | (ANNUALIZED) | |
| | | | TOTAL | ISOLATED | TOTAL | ISOLATED | TOTAL | ISOLATED | TOTAL | ISOLATED |
| | | | | MW | MW | MWH | MWH | HRS | HRS | |
| 2 ORRING | 0.00028911 | 0.36648574 | 0.37 | 0.00 | 4.90 | 0.30 | 47.44 | 0.00 | 2.53 | 0.00 |
| 3 MURRCR | 0.00000044 | 0.00149824 | 0.00 | 0.00 | 0.03 | 0.00 | 0.10 | 0.00 | 0.01 | 0.00 |
| 4 MABMYO | 0.00024842 | 0.29746795 | 0.30 | 0.00 | 18.14 | 0.13 | 131.47 | 0.98 | 2.18 | 0.00 |
| 6 EELHYD | 0.00001494 | 0.02208431 | 0.02 | 0.00 | 0.88 | 0.00 | 5.91 | 0.00 | 0.15 | 0.00 |
| 8 BEECHM | 0.00000000 | 0.00000944 | 0.00 | 0.00 | 0.30 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 |
| 11 CARAGT | 0.00005550 | 0.06477308 | 0.04 | 0.00 | 1.81 | 0.00 | 13.55 | 0.00 | 0.49 | 0.00 |
| 12 MEVCA1 | 0.00108401 | 1.31074789 | 1.31 | 0.00 | 14.97 | 0.00 | 108.33 | 0.00 | 9.50 | 0.00 |
| 13 GRLAKE | 0.00017244 | 0.21992309 | 0.22 | 0.00 | 0.44 | 0.00 | 3.20 | 0.00 | 1.51 | 0.00 |
| 14 MOWCTM | 0.00030047 | 0.38271755 | 0.38 | 0.00 | 14.47 | 0.00 | 125.72 | 0.00 | 2.43 | 0.00 |
| 15 C.BAY1 | 0.11323867 | 128.91479382 | 128.92 | 0.00 | 2612.18 | 0.00 | 19738.66 | 0.00 | 1009.51 | 0.00 |
| 18 LEPRAU | 0.00112304 | 1.39901173 | 1.40 | 0.00 | 14.47 | 0.00 | 102.79 | 0.00 | 9.84 | 0.00 |
| 19 112372 | 0.00000009 | 0.00011891 | 0.00 | 0.00 | 0.00 | 0.00 | 0.01 | 0.00 | 0.00 | 0.00 |
| 20 IRGQUB | 0.00009308 | 0.10798372 | 0.11 | 0.01 | 5.54 | 1.44 | 38.51 | 4.91 | 0.82 | 0.05 |
| 22 CELRA1 | 0.00000445 | 0.01705279 | 0.02 | 0.00 | 1.45 | 0.00 | 4.95 | 0.00 | 0.04 | 0.00 |
| 25 PENFLD | 0.00028051 | 0.31344974 | 0.31 | 0.12 | 13.92 | 4.10 | 122.27 | 14.00 | 2.44 | 0.39 |
| 26 MACCAN | 0.00000047 | 0.00151190 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.01 | 0.00 |
| 27 ONSLO1 | 0.00018411 | 0.23749183 | 0.24 | 0.00 | 1.08 | 0.00 | 7.45 | 0.00 | 1.43 | 0.00 |
| 28 ONSLO2 | 0.00018411 | 0.23748899 | 0.24 | 0.00 | 1.00 | 0.00 | 20.59 | 0.00 | 1.43 | 0.00 |
| 29 SPRNGH | 0.00011993 | 0.15053087 | 0.15 | 0.00 | 0.30 | 0.00 | 2.29 | 0.00 | 1.05 | 0.00 |
| 30 LANCAST | 0.00118807 | 1.40873204 | 1.41 | 0.03 | 29.74 | 1.05 | 211.35 | 10.44 | 10.41 | 0.14 |
| 31 IRVREF | 0.00032725 | 0.36729273 | 0.37 | 0.00 | 7.21 | 0.00 | 44.71 | 0.00 | 2.87 | 0.00 |
| 32 RICHBT | 0.00017944 | 0.41747427 | 0.42 | 0.00 | 9.92 | 0.00 | 34.24 | 0.01 | 1.57 | 0.00 |
| 33 114943 | 0.00028814 | 0.28409924 | 0.29 | 0.00 | 1.54 | 0.00 | 13.08 | 0.00 | 2.52 | 0.00 |
| 35 114981 | 0.00065842 | 0.82007390 | 0.82 | 0.00 | 3.00 | 0.00 | 20.94 | 0.00 | 5.77 | 0.00 |
| 37 117562 | 0.00000349 | 0.00429578 | 0.00 | 0.00 | 0.04 | 0.00 | 0.44 | 0.00 | 0.03 | 0.00 |
| 38 EELRV1 | 0.00019539 | 0.25710878 | 0.24 | 0.00 | 2.90 | 0.00 | 19.25 | 0.00 | 1.71 | 0.00 |
| 39 BATHS1 | 0.00087204 | 1.09827828 | 1.10 | 0.00 | 25.39 | 0.00 | 177.77 | 0.00 | 7.44 | 0.00 |
| 40 MARTSV | 0.00017244 | 0.22001015 | 0.22 | 0.00 | 3.63 | 0.00 | 24.90 | 0.00 | 1.51 | 0.00 |
| 42 111528 | 0.00017480 | 0.25930404 | 0.24 | 0.00 | 2.37 | 0.00 | 14.01 | 0.00 | 1.72 | 0.00 |
| 48 110553 | 0.00017345 | 0.22224095 | 0.22 | 0.00 | 0.34 | 0.00 | 2.43 | 0.00 | 1.52 | 0.00 |
| 49 OAKBAY | 0.00078051 | 1.13299990 | 1.13 | 0.15 | 23.14 | 9.17 | 93.00 | 31.32 | 4.84 | 0.31 |
| 54 MASH03 | 0.00083045 | 1.03713393 | 1.04 | 0.00 | 1.41 | 0.00 | 11.14 | 0.00 | 7.27 | 0.00 |
| 55 MASH12 | 0.00082997 | 1.03584972 | 1.04 | 0.00 | 1.59 | 0.00 | 11.04 | 0.00 | 7.27 | 0.00 |
| 59 110871 | 0.00004848 | 0.08740249 | 0.09 | 0.00 | 0.10 | 0.00 | 0.47 | 0.00 | 0.40 | 0.00 |
| 60 HARDBD | 0.00000084 | 0.00195414 | 0.00 | 0.00 | 0.00 | 0.00 | 0.01 | 0.00 | 0.01 | 0.00 |
| 61 MILB47 | 0.12997470 | 145.99433897 | 145.99 | 0.00 | 3243.80 | 0.00 | 25391.99 | 0.00 | 1138.42 | 0.00 |
| 62 BQAKST | 0.00000119 | 0.00315147 | 0.00 | 0.00 | 0.08 | 0.00 | 0.24 | 0.00 | 0.01 | 0.00 |
| 64 119042 | 0.00004849 | 0.08743503 | 0.09 | 0.00 | 0.29 | 0.00 | 2.02 | 0.00 | 0.40 | 0.00 |
| 65 111034 | 0.00000447 | 0.01711137 | 0.02 | 0.00 | 0.03 | 0.00 | 0.10 | 0.00 | 0.04 | 0.00 |
| 73 IRGQUB | 0.00009324 | 0.10844374 | 0.11 | 0.00 | 5.10 | 0.21 | 33.00 | 0.70 | 0.82 | 0.01 |
| 77 11248P | 0.00083041 | 1.03710455 | 1.04 | 0.00 | 3.83 | 0.00 | 24.70 | 0.00 | 7.28 | 0.00 |
| 78 119024 | 0.00022703 | 0.30763397 | 0.31 | 0.00 | 0.37 | 0.00 | 1.54 | 0.00 | 1.99 | 0.00 |
| 79 112408 | 0.00021084 | 0.24674733 | 0.27 | 0.00 | 0.10 | 0.00 | 0.41 | 0.00 | 1.83 | 0.00 |
| 81 NBIFC1 | 0.00017090 | 0.22542033 | 0.23 | 0.00 | 0.39 | 0.00 | 2.43 | 0.00 | 1.50 | 0.00 |
| 82 ROTHWR | 0.00011243 | 0.15147554 | 0.15 | 0.00 | 1.84 | 0.00 | 11.94 | 0.00 | 0.98 | 0.00 |
| 83 BRNINE | 0.00067537 | 0.84738412 | 0.85 | 0.00 | 2.92 | 0.00 | 20.33 | 0.00 | 5.92 | 0.00 |
| 84 NBIFC2 | 0.00072604 | 0.90424919 | 0.90 | 0.00 | 4.18 | 0.00 | 28.71 | 0.00 | 4.31 | 0.00 |
| 88 CONSBM | 0.00013840 | 0.18090084 | 0.18 | 0.00 | 0.54 | 0.00 | 3.65 | 0.00 | 1.21 | 0.00 |

MLII CONSTRAINED: TRANSMISSION IMPROVEMENT CASE STUDY RESULTS (ANNUALIZED)

SYSTEM INDICES

NUMBER OF LOAD BUSES INCLUDED IN INDICES= 49
 TOTAL INSTALLED CAPACITY= 3312.800
 TOTAL LOAD AT BUSES INCLUDED IN INDICES= 3987.30
 BULK POWER SUPPLY DISTURBANCES= 225.23421
 PROBABILITY OF ALL ELEMENTS IN SERVICE = 0.043082482580175

IEEE INDICES

BULK POWER INTERRUPTION INDEX= 0.44137 MW/MW-YR
 EXPECTED ENERGY NOT SUPPLIED= 20544.43945 MWH/YR
 BULK POWER ENERGY CURTAILMENT INDEX= 5.15799 MWH/MW-YR
 BULK POWER SUPPLY AVERAGE MW CURTAILMENT INDEX= 11.35467 MW/DISTURBANCE
 SEVERITY INDEX= 309.479 SYSTEM-MINUTES
 MODIFIED BULK POWER ENERGY CURTAILMENT INDEX= 0.00058881

SYSTEM INDICES: AVERAGE VALUES

AV. # OF LOAD CURTAILMENTS/LOAD PT./YEAR= 4.74713
 AV. # OF VOLTAGE VIOLATIONS/LOAD PT./YEAR= 0.00000 BEFORE REACTIVE COMP. ADDED
 AV. # OF VOLTAGE VIOLATIONS/LOAD PT./YEAR= 0.00000 AFTER REACTIVE COMP. ADDED
 AV. LOAD CURTAILED/LOAD PT./YEAR= 52.19077 MW
 AV. ENERGY CURTAILED/LOAD PT./YEAR= 419.72327 MWH
 AV. # OF HRS OF LOAD CURTAILMENT/LOAD PT./YEAR= 40.39619 HRS

SYSTEM INDICES: MAXIMUMS

MAX. LOAD CURTAILED= 431.70 FOR CONTINGENCY N#1= 34 N#2= 0 N#3= 0 N#4= 0 LOUT1= 89 LOUT2= 0 LOUT3= 0 I_L1= 0
 PROB.=0.00000107 FREQ 0.00123439
 MAX. ENERGY CURTAILED= 3204.29 FOR CONTINGENCY N#1= 34 N#2= 0 N#3= 0 N#4= 0 LOUT1= 89 LOUT2= 0 LOUT3= 0 I_L1= 0
 PROB.=0.00000107 FREQ 0.00123439

MLII CONSTRAINED: TRANSMISSION IMPROVEMENT CASE (ANNUALIZED)

BUS INDICES

| BUS | FAILURE PROB | FAILURE FREQ | # OF CURTAILMENTS (ANNUALIZED) | | TOTAL LOAD SHED (ANNUALIZED) | | TOTAL ENERGY CURTAILED (ANNUALIZED) | | TOTAL DURATION (ANNUALIZED) | |
|-----------|--------------|--------------|--------------------------------|----------|------------------------------|-------------|-------------------------------------|--------------|-----------------------------|--------------|
| | | | TOTAL | ISOLATED | TOTAL MW | ISOLATED MW | TOTAL MWH | ISOLATED MWH | TOTAL HRS | ISOLATED HRS |
| 2 ORRING | 0.00108448 | 1.35425047 | 1.35 | 0.00 | 20.87 | 0.00 | 145.54 | 0.00 | 9.52 | 0.00 |
| 3 RURRCR | 0.00000000 | 0.00000000 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 |
| 4 HADNYG | 0.00023367 | 0.27844304 | 0.28 | 0.00 | 14.20 | 0.13 | 118.04 | 0.98 | 2.05 | 0.00 |
| 4 EELMYG | 0.00001442 | 0.02133407 | 0.02 | 0.00 | 0.44 | 0.00 | 3.11 | 0.00 | 0.15 | 0.00 |
| 11 CARAGT | 0.00003021 | 0.07984471 | 0.08 | 0.00 | 3.09 | 0.00 | 14.43 | 0.00 | 0.44 | 0.00 |
| 12 NEWCAL | 0.21093490 | 223.27947998 | 223.28 | 0.00 | 2355.42 | 0.00 | 19291.30 | 0.00 | 1847.93 | 0.00 |
| 13 ORLAKE | 0.00015439 | 0.19790131 | 0.20 | 0.00 | 0.43 | 0.00 | 2.94 | 0.00 | 1.37 | 0.00 |
| 14 MONCTN | 0.00018449 | 0.23244045 | 0.23 | 0.00 | 4.20 | 0.00 | 42.99 | 0.00 | 1.43 | 0.00 |
| 15 C.BAY1 | 0.00010529 | 0.13380705 | 0.13 | 0.00 | 14.50 | 0.00 | 100.04 | 0.00 | 0.92 | 0.00 |
| 18 LEFRAU | 0.00108448 | 1.35425047 | 1.35 | 0.00 | 14.42 | 0.00 | 102.40 | 0.00 | 9.52 | 0.00 |
| 19 112572 | 0.00000000 | 0.00000000 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 |
| 20 IRGQUB | 0.00009304 | 0.10800394 | 0.11 | 0.01 | 5.54 | 1.44 | 38.49 | 4.91 | 0.82 | 0.05 |
| 25 PENFLB | 0.00007507 | 0.15003948 | 0.15 | 0.12 | 4.12 | 4.10 | 14.15 | 13.99 | 0.44 | 0.39 |
| 26 MACCAN | 0.00001511 | 0.01735095 | 0.02 | 0.00 | 0.22 | 0.00 | 1.71 | 0.00 | 0.13 | 0.00 |
| 27 GNSLO1 | 0.00011055 | 0.14045347 | 0.14 | 0.00 | 0.40 | 0.00 | 4.14 | 0.00 | 0.97 | 0.00 |
| 28 GNSLO2 | 0.00018470 | 0.23472331 | 0.23 | 0.00 | 2.75 | 0.00 | 18.98 | 0.00 | 1.42 | 0.00 |
| 29 SPRNSH | 0.00012571 | 0.15784354 | 0.16 | 0.00 | 0.59 | 0.00 | 4.34 | 0.00 | 1.10 | 0.00 |
| 30 LANCSH | 0.00011570 | 1.03203644 | 1.03 | 0.03 | 19.74 | 3.05 | 126.24 | 10.43 | 7.15 | 0.10 |
| 31 IRVREF | 0.00003928 | 1.04713431 | 1.05 | 0.00 | 3.59 | 0.00 | 38.78 | 0.00 | 7.35 | 0.00 |
| 32 RICHBT | 0.00017809 | 0.41440439 | 0.41 | 0.00 | 9.45 | 0.00 | 33.08 | 0.01 | 1.54 | 0.00 |
| 33 114943 | 0.00042814 | 0.78113323 | 0.78 | 0.00 | 5.15 | 0.00 | 34.30 | 0.00 | 5.50 | 0.00 |
| 35 114981 | 0.00042814 | 0.78113304 | 0.78 | 0.00 | 1.85 | 0.00 | 13.01 | 0.00 | 5.50 | 0.00 |
| 37 117542 | 0.00000000 | 0.00000000 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 |
| 38 EELRV1 | 0.00018734 | 0.23773091 | 0.24 | 0.00 | 2.45 | 0.00 | 14.91 | 0.00 | 1.44 | 0.00 |
| 39 BATHS1 | 0.00044483 | 0.82704955 | 0.83 | 0.00 | 18.28 | 0.00 | 127.44 | 0.00 | 5.84 | 0.00 |
| 40 HARTSV | 0.00015441 | 0.19795398 | 0.20 | 0.00 | 2.90 | 0.00 | 20.04 | 0.00 | 1.37 | 0.00 |
| 42 111528 | 0.00071148 | 0.88390905 | 0.88 | 0.00 | 2.78 | 0.00 | 19.33 | 0.00 | 4.23 | 0.00 |
| 48 110353 | 0.00015440 | 0.19791415 | 0.20 | 0.00 | 0.28 | 0.00 | 1.94 | 0.00 | 1.37 | 0.00 |
| 49 DAKBAY | 0.00074044 | 1.00145797 | 1.00 | 0.15 | 21.59 | 9.17 | 82.33 | 31.31 | 4.49 | 0.51 |
| 54 NASHO3 | 0.00078980 | 0.98411045 | 0.98 | 0.00 | 1.03 | 0.00 | 7.24 | 0.00 | 4.92 | 0.00 |
| 55 NASH12 | 0.00078980 | 0.98411179 | 0.98 | 0.00 | 1.03 | 0.00 | 7.24 | 0.00 | 4.92 | 0.00 |
| 59 110871 | 0.00004784 | 0.08581577 | 0.09 | 0.00 | 0.08 | 0.00 | 0.53 | 0.00 | 0.59 | 0.00 |
| 60 HARDRD | 0.00000034 | 0.00053448 | 0.00 | 0.00 | 0.00 | 0.00 | 0.01 | 0.00 | 0.00 | 0.00 |
| 61 MILB47 | 0.00083929 | 1.04714384 | 1.05 | 0.00 | 4.41 | 0.00 | 30.59 | 0.00 | 7.35 | 0.00 |
| 62 DOAKST | 0.00000000 | 0.00000001 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 |
| 64 119042 | 0.00000295 | 0.10314457 | 0.10 | 0.00 | 0.37 | 0.00 | 2.40 | 0.00 | 0.73 | 0.00 |
| 65 111034 | 0.00014418 | 0.20840851 | 0.21 | 0.00 | 0.05 | 0.00 | 0.37 | 0.00 | 1.44 | 0.00 |
| 73 IRGQUA | 0.00009322 | 1.00481148 | 0.11 | 0.00 | 3.11 | 0.21 | 32.99 | 0.70 | 0.82 | 0.01 |
| 77 1124MP | 0.00078980 | 0.98411314 | 0.98 | 0.00 | 2.49 | 0.00 | 17.48 | 0.00 | 4.92 | 0.00 |
| 78 119024 | 0.00020874 | 0.24149887 | 0.24 | 0.00 | 0.08 | 0.00 | 0.51 | 0.00 | 1.83 | 0.00 |
| 79 112408 | 0.00020842 | 0.24094377 | 0.24 | 0.00 | 0.07 | 0.00 | 0.49 | 0.00 | 1.83 | 0.00 |
| 81 NBIFC1 | 0.00014983 | 0.19019435 | 0.19 | 0.00 | 0.29 | 0.00 | 1.99 | 0.00 | 1.31 | 0.00 |
| 82 RSTNPR | 0.00010529 | 0.13380705 | 0.13 | 0.00 | 0.88 | 0.00 | 4.10 | 0.00 | 0.92 | 0.00 |
| 83 BRNINE | 0.00044483 | 0.82704410 | 0.83 | 0.00 | 2.13 | 0.00 | 15.20 | 0.00 | 5.84 | 0.00 |
| 84 NBIFC2 | 0.00049713 | 0.84550234 | 0.87 | 0.00 | 2.99 | 0.00 | 21.09 | 0.00 | 4.11 | 0.00 |
| 88 CONSD4 | 0.00012093 | 0.14193414 | 0.14 | 0.00 | 0.44 | 0.00 | 3.23 | 0.00 | 1.04 | 0.00 |

CIGRE EENS SYSTEM INDICES
(in GWh/year)

by using MECORE (Monte Carlo simulation program)

Basic System Evaluation

| | HL1 | | HL2 Constrained | | | HL2 Unconstrained | | |
|--------------------------|------------|---------|-----------------|---------|-------|-------------------|---------|-------|
| | Annualized | Annual | Gen. | Network | Total | Gen. | Network | Total |
| EENS | 14.68 | 0.20 | 14.68 | 38.26 | 52.94 | 0.20 | 0.94 | 1.14 |
| Coefficient of variation | 0.056 | 0.048 | 0.053 | | | 0.035 | | |
| CPU time | 31.0 sec. | 4.9min. | 16.4 min. | | | 1 h 6 min. | | |
| Number of Samples | 80000 | 720000 | 8000 | | | 8000 x 10 | | |

Note : 10 step model of annual load curve is used in HL2 unconstrained case.

Transmission Improvement Evaluation

| | HL1 | | HL2 Constrained | | | HL2 Unconstrained | | |
|--------------------------|------------|---------|-----------------|---------|-------|-------------------|---------|-------|
| | Annualized | Annual | Gen. | Network | Total | Gen. | Network | Total |
| EENS | 14.68 | 0.20 | 14.68 | 1.68 | 16.36 | 0.20 | 0.30 | 0.50 |
| Coefficient of variation | 0.056 | 0.048 | 0.063 | | | 0.031 | | |
| CPU time | 31.0 sec. | 4.9min. | 29.5 min. | | | 4 h 6 min. | | |
| Number of Samples | 80000 | 720000 | 40000 | | | 40000 x 10 | | |

Note : 10 step model of annual load curve is used in HL2 unconstrained case.

20-JUN-1991 12:03:14.08

Output Results of HLI Evaluation
(by Monte Carlo simulation)

1. Annualized indices using annual peak load plus network loss

LOLE= 85.06680 (hour/year)
EENS= 14680.99512 (MWh/year)

VARIANCE COEFFICIENT OF EENS IS

0.05600

CPU TIME IS (in second):

31.00980

2. Annual indices using a 10 step model of the annual load curve

LOLE= 1.33753 (hour/year)
EENS= 199.75185 (MWh/year)

VARIANCE COEFFICIENT OF EDNS IS

0.04814

CPU TIME IS (in second):

291.60001

20-JUN-1991 11:39:11.71

Output Results of Basic System Evaluation
(HL2 Constrained Case)

SYSTEM INDICES

| | |
|---|-------------|
| Expected number of load curtailments (1/year) | |
| ENLC= | 237.11395 |
| Average duration of load curtailment (hrs/disturbance) | |
| ADLC= | 6.59953 |
| Expected duration of load curtailment (hrs/year) | |
| EDLC= | 1564.83594 |
| Probability of load curtailments | |
| PLC = | 0.17912 |
| Expected demand not supplied (mw) | |
| EDNS= | 6.05994 |
| Expected energy not supplied (mwh/year) | |
| EENS= | 52939.66797 |
| Bulk Power-interruption Index (MW/MWyear) | |
| BPII= | 2.28647 |
| Bulk Power/energy Curtailment Index (MWh/MWyear) | |
| BECI= | 13.27574 |
| Bulk Power-supply average MW curtailment Index (MW/disturbance) | |
| BPACI= | 38.45306 |
| Modified Bulk/energy curtailment Index | |
| MBECI= | 0.00152 |
| Severity Index (system minutes) | |
| SI= | 796.54437 |

Variance coefficient of EDNS is:
0.0529576
Square root deviation of EDNS is:
0.3209199

CPU Time is (in seconds):
985.84003

THE LOAD BUS INDICES

| No. Bus | PLC | ENLC | ELC | EDNS | EENS |
|---------|---------|-----------|------------|---------|-------------|
| 2 | 0.00013 | 0.25254 | 11.86361 | 0.00587 | 51.29976 |
| 3 | 0.00088 | 1.56244 | 17.20669 | 0.00941 | 82.21280 |
| 4 | 0.00050 | 0.85554 | 27.19781 | 0.01659 | 144.91583 |
| 8 | 0.00013 | 0.25254 | 2.01681 | 0.00100 | 8.72096 |
| 10 | 0.00050 | 0.92701 | 3.91942 | 0.00211 | 18.46791 |
| 12 | 0.00200 | 3.43360 | 107.64028 | 0.06382 | 557.50836 |
| 13 | 0.00138 | 2.40610 | 22.70495 | 0.01298 | 113.35016 |
| 14 | 0.00200 | 3.59779 | 221.54387 | 0.12163 | 1062.58240 |
| 15 | 0.07337 | 100.85837 | 2589.63867 | 1.85132 | 16173.16797 |
| 18 | 0.00100 | 1.88067 | 8.45082 | 0.00449 | 39.25547 |
| 19 | 0.00113 | 2.08376 | 22.39705 | 0.01201 | 104.95868 |
| 20 | 0.00138 | 2.39193 | 77.03756 | 0.04454 | 389.09088 |
| 22 | 0.00100 | 1.78892 | 39.75444 | 0.02222 | 194.13614 |
| 25 | 0.00275 | 4.56423 | 67.86791 | 0.03643 | 318.24176 |
| 26 | 0.00213 | 3.99100 | 10.27109 | 0.00547 | 47.77569 |
| 27 | 0.00238 | 4.38958 | 40.32598 | 0.02145 | 187.39087 |
| 28 | 0.00225 | 4.18232 | 26.51571 | 0.01428 | 124.75204 |
| 29 | 0.00238 | 4.38958 | 21.15922 | 0.01145 | 100.01219 |
| 30 | 0.00325 | 5.43011 | 166.93770 | 0.08462 | 739.25995 |
| 31 | 0.01475 | 22.31729 | 145.41991 | 0.09587 | 837.55524 |
| 32 | 0.00450 | 8.32390 | 199.10399 | 0.11067 | 966.82251 |
| 33 | 0.01513 | 23.34126 | 561.38184 | 0.36446 | 3183.89380 |
| 35 | 0.00375 | 6.69767 | 62.01711 | 0.03496 | 305.41443 |
| 37 | 0.00288 | 4.93877 | 14.46786 | 0.00844 | 73.71017 |
| 38 | 0.00263 | 4.46094 | 14.48732 | 0.00852 | 74.47387 |
| 39 | 0.00275 | 4.81457 | 118.81192 | 0.06722 | 587.22522 |
| 40 | 0.00388 | 7.02958 | 204.66577 | 0.11381 | 994.23029 |
| 42 | 0.00313 | 5.40237 | 50.55440 | 0.02914 | 254.55632 |
| 48 | 0.00475 | 8.12010 | 25.09470 | 0.01466 | 128.07767 |
| 49 | 0.00512 | 8.64183 | 162.70244 | 0.08002 | 699.01532 |
| 54 | 0.00400 | 7.04252 | 30.06347 | 0.01708 | 149.17082 |
| 55 | 0.00412 | 7.41804 | 31.66651 | 0.01761 | 153.83241 |
| 59 | 0.00487 | 8.47429 | 37.90637 | 0.02181 | 190.50058 |
| 60 | 0.00462 | 8.06234 | 7.90436 | 0.00453 | 39.61233 |
| 61 | 0.17375 | 226.92542 | 1122.95081 | 0.83476 | 7292.44385 |
| 62 | 0.00412 | 6.94654 | 165.53589 | 0.09764 | 853.01825 |
| 64 | 0.00487 | 8.44379 | 113.48229 | 0.06552 | 572.37128 |
| 65 | 0.00350 | 5.78746 | 2.48240 | 0.00150 | 13.11490 |
| 73 | 0.00425 | 7.02869 | 166.41953 | 0.10081 | 880.71429 |
| 77 | 0.00425 | 7.03402 | 69.66682 | 0.04197 | 366.63129 |
| 78 | 0.00562 | 9.63862 | 12.99342 | 0.00758 | 66.24359 |
| 79 | 0.00562 | 9.63862 | 12.99342 | 0.00758 | 66.24359 |
| 81 | 0.00400 | 6.57034 | 39.85739 | 0.02427 | 211.97949 |
| 82 | 0.10337 | 144.43820 | 1983.50439 | 1.37862 | 12043.60645 |
| 83 | 0.00425 | 7.10674 | 71.48469 | 0.04278 | 373.68378 |
| 84 | 0.00500 | 8.03941 | 104.99180 | 0.06496 | 567.48322 |
| 85 | 0.00525 | 8.57673 | 100.69724 | 0.06146 | 536.88074 |

Note:

- PLC-----probability of load curtailments
- ENLC-----expected number of load curtailments (1/year)
- ELC-----expected load curtailed(mw/year)
- EENS-----expected energy not supplied(mwh/year)
- EDNS-----expected demand not supplied(mw)

20-JUN-1991 13:23:32.18

Output Results of Basic System Evaluation
(HL2 Unconstrained Case, 10 Step Load Model)

SYSTEM INDICES

| | |
|---|------------|
| Expected number of load curtailments (1/year) | |
| ENLC= | 7.06903 |
| Average duration of load curtailment (hrs/disturbance) | |
| ADLC= | 4.93379 |
| Expected duration of load curtailment (hrs/year) | |
| EDLC= | 34.87706 |
| Probability of load curtailments | |
| PLC = | 0.00399 |
| Expected demand not supplied (mw) | |
| EDNS= | 0.13029 |
| Expected energy not supplied (mwh/year) | |
| EENS= | 1138.25696 |
| Bulk Power-interruption Index (MW/MWyear) | |
| BPII= | 0.08204 |
| Bulk Power/energy Curtailment Index (MWh/MWyear) | |
| BECI= | 0.34702 |
| Bulk Power-supply average MW curtailment Index (MW/disturbance) | |
| BPACI= | 35.74510 |
| Modified Bulk/energy curtailment Index | |
| MBECI= | 0.00004 |
| Severity Index (system minutes) | |
| SI= | 20.82140 |

Variance coefficient of EDNS is:
0.0352200
Square root deviation of EDNS is:
0.0045890

CPU Time is (in seconds):
3979.96997

THE LOAD BUS INDICES

| No. Bus | PLC | ENLC | ELC | EDNS | EENS |
|---------|---------|---------|----------|---------|-----------|
| 2 | 0.00000 | 0.00144 | 0.06762 | 0.00003 | 0.29241 |
| 3 | 0.00001 | 0.02022 | 0.22453 | 0.00012 | 1.01539 |
| 4 | 0.00003 | 0.04133 | 1.35607 | 0.00083 | 7.28916 |
| 8 | 0.00000 | 0.00144 | 0.01150 | 0.00001 | 0.04971 |
| 10 | 0.00000 | 0.00528 | 0.02234 | 0.00001 | 0.10527 |
| 12 | 0.00006 | 0.10161 | 2.53897 | 0.00137 | 11.98174 |
| 13 | 0.00003 | 0.05602 | 0.49351 | 0.00027 | 2.33017 |
| 14 | 0.00003 | 0.06281 | 3.75514 | 0.00201 | 17.52470 |
| 15 | 0.00140 | 2.08554 | 51.66110 | 0.03354 | 292.97421 |
| 18 | 0.00001 | 0.01072 | 0.04817 | 0.00003 | 0.22376 |
| 19 | 0.00001 | 0.01188 | 0.12766 | 0.00007 | 0.59826 |
| 20 | 0.00007 | 0.10993 | 2.28221 | 0.00139 | 12.11508 |
| 22 | 0.00001 | 0.01020 | 0.22660 | 0.00013 | 1.10658 |
| 25 | 0.00030 | 0.73771 | 8.37626 | 0.00336 | 29.31237 |
| 26 | 0.00002 | 0.03287 | 0.08231 | 0.00004 | 0.38714 |
| 27 | 0.00002 | 0.03514 | 0.32434 | 0.00017 | 1.52469 |
| 28 | 0.00002 | 0.03396 | 0.21036 | 0.00011 | 0.99723 |
| 29 | 0.00002 | 0.03514 | 0.16511 | 0.00009 | 0.78514 |
| 30 | 0.00032 | 0.82510 | 47.76628 | 0.01695 | 148.10957 |
| 31 | 0.00020 | 0.34345 | 2.02091 | 0.00116 | 10.12976 |
| 32 | 0.00006 | 0.11055 | 2.69495 | 0.00146 | 12.75441 |
| 33 | 0.00021 | 0.40229 | 6.91416 | 0.00391 | 34.14355 |
| 35 | 0.00003 | 0.05911 | 0.45331 | 0.00025 | 2.21929 |
| 37 | 0.00002 | 0.03896 | 0.11246 | 0.00006 | 0.55593 |
| 38 | 0.00002 | 0.03623 | 0.11459 | 0.00007 | 0.56940 |
| 39 | 0.00002 | 0.03823 | 0.71503 | 0.00040 | 3.51858 |
| 40 | 0.00006 | 0.10345 | 2.46112 | 0.00133 | 11.58215 |
| 42 | 0.00004 | 0.07274 | 0.65228 | 0.00036 | 3.14963 |
| 48 | 0.00008 | 0.15158 | 0.42923 | 0.00024 | 2.05762 |
| 49 | 0.00049 | 1.36726 | 46.39380 | 0.01515 | 132.35974 |
| 54 | 0.00006 | 0.10288 | 0.41374 | 0.00023 | 1.98208 |
| 55 | 0.00006 | 0.10502 | 0.42287 | 0.00023 | 2.00865 |
| 59 | 0.00007 | 0.13313 | 0.56015 | 0.00031 | 2.67097 |
| 60 | 0.00007 | 0.13078 | 0.12047 | 0.00007 | 0.57321 |
| 61 | 0.00288 | 4.06247 | 17.60172 | 0.01205 | 105.23685 |
| 62 | 0.00006 | 0.10233 | 2.32590 | 0.00130 | 11.31731 |
| 64 | 0.00007 | 0.13295 | 1.68068 | 0.00092 | 8.02509 |
| 65 | 0.00004 | 0.07494 | 0.03056 | 0.00002 | 0.15130 |
| 73 | 0.00012 | 0.19261 | 3.22805 | 0.00193 | 16.87656 |
| 77 | 0.00006 | 0.09934 | 0.95220 | 0.00055 | 4.84010 |
| 78 | 0.00009 | 0.15706 | 0.19903 | 0.00011 | 0.97558 |
| 79 | 0.00009 | 0.15706 | 0.19903 | 0.00011 | 0.97558 |
| 81 | 0.00006 | 0.09669 | 0.55495 | 0.00032 | 2.83222 |
| 82 | 0.00179 | 2.68813 | 37.74915 | 0.02497 | 218.13657 |
| 83 | 0.00005 | 0.09139 | 0.89572 | 0.00051 | 4.47211 |
| 84 | 0.00007 | 0.12620 | 1.46343 | 0.00085 | 7.40192 |
| 85 | 0.00009 | 0.15671 | 1.58368 | 0.00092 | 8.01763 |

Note:

PLC-----probability of load curtailments
 ENLC-----expected number of load curtailments (1/year)
 ELC-----expected load curtailed(mw/year)
 EENS-----expected energy not supplied(mwh/year)
 EDNS-----expected demand not supplied(mw)

20-JUN-1991 11:51:33.12

Output Results of Transmission Improvement Evaluation
(HL2 Constrained Case)

SYSTEM INDICES

| | |
|---|-------------|
| Expected number of load curtailments (1/year) | |
| ENLC= | 22.87027 |
| Average duration of load curtailment (hrs/disturbance) | |
| ADLC= | 4.85114 |
| Expected duration of load curtailment (hrs/year) | |
| EDLC= | 110.94720 |
| Probability of load curtailments | |
| PLC = | 0.01270 |
| Expected demand not supplied (mw) | |
| EDNS= | 1.87239 |
| Expected energy not supplied (mwh/year) | |
| EENS= | 16357.16309 |
| Bulk Power-interruption Index (MW/MWyear) | |
| BPII= | 0.82623 |
| Bulk Power/energy Curtailment Index (MWh/MWyear) | |
| BECI= | 4.10190 |
| Bulk Power-supply average MW curtailment Index (MW/disturbance) | |
| BPACI= | 144.06377 |
| Modified Bulk/energy curtailment Index | |
| MBECI= | 0.00047 |
| Severity Index (system minutes) | |
| SI= | 246.11426 |

Variance coefficient of EDNS is:
0.0629750
Square root deviation of EDNS is:
0.1179134

CPU Time is (in seconds):
1771.15002

THE LOAD BUS INDICES

| No.Bus | PLC | ENLC | ELC | EDNS | EENS |
|--------|---------|----------|-----------|---------|------------|
| 2 | 0.00015 | 0.28375 | 10.26350 | 0.00528 | 46.09577 |
| 3 | 0.00057 | 0.99713 | 10.96113 | 0.00625 | 54.62639 |
| 4 | 0.00045 | 0.69844 | 35.95407 | 0.02374 | 207.43051 |
| 6 | 0.00010 | 0.19407 | 6.16732 | 0.00307 | 26.82921 |
| 8 | 0.00015 | 0.29009 | 2.31672 | 0.00120 | 10.46515 |
| 10 | 0.00035 | 0.64064 | 2.70864 | 0.00148 | 12.92754 |
| 11 | 0.00012 | 0.23877 | 5.37357 | 0.00285 | 24.87575 |
| 12 | 0.00262 | 4.43286 | 132.45197 | 0.07920 | 691.90338 |
| 13 | 0.00165 | 2.86836 | 25.93822 | 0.01493 | 130.46472 |
| 14 | 0.00182 | 3.20725 | 179.65259 | 0.10069 | 879.63983 |
| 15 | 0.00115 | 2.15599 | 86.72340 | 0.04623 | 403.89148 |
| 18 | 0.00083 | 1.51080 | 6.56504 | 0.00357 | 31.22466 |
| 19 | 0.00088 | 1.60412 | 16.64309 | 0.00906 | 79.15885 |
| 20 | 0.00140 | 2.43202 | 83.97110 | 0.04720 | 412.36005 |
| 22 | 0.00105 | 1.87629 | 38.47542 | 0.02148 | 187.63023 |
| 25 | 0.00182 | 3.43938 | 52.82640 | 0.02533 | 221.26726 |
| 26 | 0.00182 | 3.25409 | 8.33113 | 0.00467 | 40.83748 |
| 27 | 0.00172 | 3.08098 | 30.73864 | 0.01716 | 149.86621 |
| 28 | 0.00170 | 3.01831 | 19.06242 | 0.01074 | 93.80314 |
| 29 | 0.00190 | 3.35239 | 16.15962 | 0.00916 | 80.00975 |
| 30 | 0.00210 | 3.75023 | 96.00852 | 0.04785 | 418.06104 |
| 31 | 0.00187 | 3.30341 | 21.38655 | 0.01213 | 105.97794 |
| 32 | 0.00445 | 8.04854 | 198.61523 | 0.11242 | 982.11646 |
| 33 | 0.00260 | 4.58407 | 114.85380 | 0.06522 | 569.73999 |
| 35 | 0.00290 | 5.11066 | 46.95619 | 0.02662 | 232.55841 |
| 37 | 0.00252 | 4.44349 | 13.44395 | 0.00764 | 66.75932 |
| 38 | 0.00225 | 3.95035 | 12.82913 | 0.00731 | 63.83477 |
| 39 | 0.00245 | 4.31254 | 99.87029 | 0.05666 | 494.97714 |
| 40 | 0.00402 | 7.11950 | 209.52969 | 0.11837 | 1034.08533 |
| 42 | 0.00305 | 5.30030 | 49.11213 | 0.02825 | 246.75798 |
| 48 | 0.00530 | 9.06989 | 28.61725 | 0.01673 | 146.16942 |
| 49 | 0.00467 | 8.83014 | 194.40474 | 0.08471 | 740.06934 |
| 54 | 0.00442 | 7.66599 | 32.48170 | 0.01874 | 163.69638 |
| 55 | 0.00450 | 7.79992 | 32.89318 | 0.01903 | 166.25279 |
| 59 | 0.00487 | 8.34146 | 36.86211 | 0.02154 | 188.17982 |
| 60 | 0.00477 | 8.18466 | 8.02430 | 0.00468 | 40.89706 |
| 61 | 0.00482 | 8.34096 | 42.80047 | 0.02476 | 216.32248 |
| 62 | 0.00530 | 9.08101 | 204.23892 | 0.11905 | 1039.99841 |
| 64 | 0.00557 | 9.47506 | 125.60114 | 0.07384 | 645.07275 |
| 65 | 0.00450 | 7.59694 | 3.25854 | 0.00193 | 16.86199 |
| 73 | 0.00535 | 8.91182 | 214.21382 | 0.12702 | 1109.66406 |
| 77 | 0.00540 | 9.04185 | 89.16653 | 0.05312 | 464.05984 |
| 78 | 0.00632 | 10.62685 | 14.29215 | 0.00850 | 74.28622 |
| 79 | 0.00637 | 10.71316 | 14.31985 | 0.00852 | 74.38862 |
| 81 | 0.00520 | 8.67923 | 52.40993 | 0.03139 | 274.19348 |
| 82 | 0.00660 | 11.10436 | 190.83932 | 0.11347 | 991.24261 |
| 83 | 0.00577 | 9.50011 | 95.93953 | 0.05803 | 506.97464 |
| 84 | 0.00690 | 11.28545 | 149.11086 | 0.09107 | 795.58563 |
| 85 | 0.00697 | 11.42495 | 131.41228 | 0.08048 | 703.07635 |

Note:

PLC-----probability of load curtailments
 ENLC-----expected number of load curtailments (1/year)
 ELC-----expected load curtailed(mw/year)
 EENS-----expected energy not supplied(mwh/year)
 EDNS-----expected demand not supplied(mw)

20-JUN-1991 15:20:19.20

Output Results of Transmission Improvement Evaluation
(HL2 Unconstrained Case, 10 Step Load Model)

SYSTEM INDICES

| | |
|---|-----------|
| Expected number of load curtailments (1/year) | |
| ENLC= | 3.42331 |
| Average duration of load curtailment (hrs/disturbance) | |
| ADLC= | 3.19986 |
| Expected duration of load curtailment (hrs/year) | |
| EDLC= | 10.95414 |
| Probability of load curtailments | |
| PLC = | 0.00125 |
| Expected demand not supplied (mw) | |
| EDNS= | 0.05733 |
| Expected energy not supplied (mwh/year) | |
| EENS= | 500.85321 |
| Bulk Power-interruption Index (MW/MWyear) | |
| BPII= | 0.05142 |
| Bulk Power/energy Curtailment Index (MWh/MWyear) | |
| BECI= | 0.17419 |
| Bulk Power-supply average MW curtailment Index (MW/disturbance) | |
| BPACI= | 41.20952 |
| Modified Bulk/energy curtailment Index | |
| MBECI= | 0.00002 |
| Severity Index (system minutes) | |
| SI= | 10.45123 |

Variance coefficient of EDNS is:
0.0311736
Square root deviation of EDNS is:
0.0017872

CPU Time is (in seconds):
14783.37988

THE LOAD BUS INDICES

| No. Bus | PLC | ENLC | ELC | EDNS | EENS |
|---------|---------|---------|----------|---------|-----------|
| 2 | 0.00000 | 0.00162 | 0.05850 | 0.00003 | 0.26275 |
| 3 | 0.00001 | 0.01495 | 0.16478 | 0.00008 | 0.74250 |
| 4 | 0.00006 | 0.09370 | 2.95388 | 0.00207 | 18.08787 |
| 6 | 0.00000 | 0.00111 | 0.03515 | 0.00002 | 0.15293 |
| 8 | 0.00000 | 0.00165 | 0.01321 | 0.00001 | 0.05965 |
| 10 | 0.00001 | 0.01065 | 0.04201 | 0.00002 | 0.18470 |
| 11 | 0.00000 | 0.00136 | 0.03063 | 0.00002 | 0.14179 |
| 12 | 0.00004 | 0.07949 | 1.99883 | 0.00110 | 9.63147 |
| 13 | 0.00003 | 0.05105 | 0.41821 | 0.00023 | 1.99900 |
| 14 | 0.00003 | 0.05296 | 2.68312 | 0.00144 | 12.60460 |
| 15 | 0.00001 | 0.01686 | 0.70354 | 0.00037 | 3.19744 |
| 18 | 0.00001 | 0.01318 | 0.05066 | 0.00003 | 0.23662 |
| 19 | 0.00001 | 0.01122 | 0.11613 | 0.00006 | 0.55145 |
| 20 | 0.00012 | 0.22578 | 7.00566 | 0.00323 | 28.23071 |
| 22 | 0.00001 | 0.01699 | 0.30849 | 0.00017 | 1.48026 |
| 25 | 0.00021 | 0.61760 | 7.06122 | 0.00244 | 21.33429 |
| 26 | 0.00002 | 0.03606 | 0.08813 | 0.00005 | 0.41385 |
| 27 | 0.00002 | 0.03508 | 0.32811 | 0.00018 | 1.53252 |
| 28 | 0.00002 | 0.02814 | 0.17209 | 0.00009 | 0.81753 |
| 29 | 0.00002 | 0.03662 | 0.16823 | 0.00009 | 0.79521 |
| 30 | 0.00012 | 0.32977 | 19.42742 | 0.00661 | 57.78671 |
| 31 | 0.00002 | 0.03181 | 0.19387 | 0.00011 | 0.92971 |
| 32 | 0.00006 | 0.10682 | 2.56572 | 0.00141 | 12.28534 |
| 33 | 0.00003 | 0.05364 | 1.22735 | 0.00068 | 5.90497 |
| 35 | 0.00003 | 0.05911 | 0.49807 | 0.00027 | 2.37064 |
| 37 | 0.00003 | 0.04827 | 0.13978 | 0.00008 | 0.67613 |
| 38 | 0.00002 | 0.04341 | 0.13472 | 0.00007 | 0.65198 |
| 39 | 0.00002 | 0.04155 | 0.86737 | 0.00048 | 4.17193 |
| 40 | 0.00005 | 0.08489 | 2.36526 | 0.00129 | 11.29849 |
| 42 | 0.00003 | 0.05708 | 0.50957 | 0.00029 | 2.49336 |
| 48 | 0.00007 | 0.13144 | 0.38576 | 0.00021 | 1.87439 |
| 49 | 0.00070 | 2.03644 | 67.46552 | 0.02263 | 197.70990 |
| 54 | 0.00005 | 0.09375 | 0.37815 | 0.00021 | 1.83633 |
| 55 | 0.00006 | 0.10372 | 0.39759 | 0.00022 | 1.93463 |
| 59 | 0.00006 | 0.11385 | 0.46411 | 0.00026 | 2.26818 |
| 60 | 0.00006 | 0.11296 | 0.10444 | 0.00006 | 0.50954 |
| 61 | 0.00006 | 0.10297 | 0.50979 | 0.00029 | 2.49614 |
| 62 | 0.00006 | 0.11374 | 2.50324 | 0.00140 | 12.25708 |
| 64 | 0.00007 | 0.12476 | 1.55365 | 0.00087 | 7.60943 |
| 65 | 0.00005 | 0.09441 | 0.03853 | 0.00002 | 0.19148 |
| 73 | 0.00012 | 0.21838 | 5.48205 | 0.00270 | 23.56445 |
| 77 | 0.00007 | 0.11574 | 1.10462 | 0.00063 | 5.54715 |
| 78 | 0.00008 | 0.14469 | 0.18383 | 0.00010 | 0.91040 |
| 79 | 0.00008 | 0.14721 | 0.18491 | 0.00010 | 0.91544 |
| 81 | 0.00007 | 0.11640 | 0.65276 | 0.00037 | 3.26846 |
| 82 | 0.00009 | 0.15436 | 2.46547 | 0.00141 | 12.29553 |
| 83 | 0.00007 | 0.12069 | 1.17745 | 0.00068 | 5.93848 |
| 84 | 0.00009 | 0.15691 | 1.92970 | 0.00112 | 9.77015 |
| 85 | 0.00010 | 0.16431 | 1.76175 | 0.00102 | 8.92971 |

Note:

PLC-----probability of load curtailments
 ENLC-----expected number of load curtailments (1/year)
 ELC-----expected load curtailed (mw/year)
 EENS-----expected energy not supplied (mwh/year)
 EDNS-----expected demand not supplied (mw)

APPENDIX X

POWER TECHNOLOGIES INC. REPORT

APPLICATION OF PTI'S MAREL AND TPLAN PROGRAM FOR THE ADEQUACY ASSESSMENT OF THE NEW BRUNSWICK POWER SYSTEM

by

N. D. Reppen and W.R. Puntel
POWER TECHNOLOGIES, INC.
Schenectady, New York

(U.S.A.)

1.0 INTRODUCTION

PTI's evaluation of the New Brunswick Power test system involved the application of two software packages. The HL1 evaluation was performed using our Multi-area Reliability Evaluation Program, MAREL. The HL2 evaluation was performed using our Interactive Transmission System Planning Program, TPLAN.

MAREL incorporates an analytical approach to calculate multi-area LOLE and related indices [1,2]. A linear flow network model is employed to represent transmission constraints and the max-flow/min-cut algorithm is used to efficiently categorize failure and success states. In this study only a single area representation of the New Brunswick system is reported. A more detailed description of the MAREL package is provided in Appendix A.

TPLAN provides both a.c and d.c load flow models for bulk power transmission system analysis. It also incorporates a set of interactive activities to perform comprehensive contingency testing through enumeration and to calculate bulk power system reliability indices. TPLAN was applied to both the Peak Load and Enhanced Transmission models of the New Brunswick System. A description of the TPLAN package is provided in Appendix B.

2.0 HL1 RESULTS

HL1 results were calculated using a conventional, single area model of the New Brunswick system. Indices calculated included LOLE (hours/year), Expected Energy Not Served (EENS-GWH) and average MW's of load loss per event. The peak load model assumed that the peak load level existed for 8760 hours per year. Other approximations applied to meet study specifications included:

- No scheduled outages for unit maintenance.
- Addition of 690 MW to the load to represent contractual power transfers.

- Modeling of interruptible load as a 100% available generating unit (52 MW).
- Modeling of Hydro capacity as a 100% available generating unit (650 MW).
- Modeling of Nova Scotia, New England, and Hydro Quebec as two-unit equivalents and Maine Public Service and Prince Edward Island as single unit equivalents.

This representation produced the model parameters summarized in Table 2.1.

Table 2.1

Summary of NB Peak Load Model for HL1 Evaluation

| | |
|--|---------|
| Installed Capacity | 5374 MW |
| Peak Load | 3846 MW |
| Installed Reserves | 1528 MW |
| Reserves as Percent of Peak Load | 39.73 |
| Weighted Average Unit Forced Outage Rate | 8.89 |

Application of the MAREL program to this system representation produced the results shown in Table 2.2.

Table 2.2

HL1 Results for NB Peak System

| <u>LOLE (hrs/yr)</u> | <u>EENS (GWH)</u> | <u>AV. MW</u> |
|----------------------|-------------------|---------------|
| 80.8215 | 13.63 | 168.75 |

A summary of computer output for this evaluation is presented in Appendix C.

3.0 HL2 EVALUATION

The TPLAN HL2 evaluation was performed utilizing an a.c load flow model of the New Brunswick System. As a result, both overload and voltage problem indices were generated. TPLAN incorporates a contingency enumeration approach in combination with ranking and screening techniques to efficiently capture those events which cause problems in the system.

Investigations were performed on both the base transmission system and enhanced transmission system using peak load conditions. These systems were modeled as described in "NB Power Composite System Data For Reliability Evaluation" Summary prepared by CIGRE Task Force 38.03.10 at NB Power and dated November 1990. In each case, contingencies were tested involving up to three levels of generating unit outages, two levels of circuit outages, or various combinations of the two. A probability threshold of 1.0×10^{-7} was used to screen low probability events. An automatic, inertial redispatching scheme was employed to balance generation and load after a loss of generation. No attempt was made to relieve system problems by generation dispatch or load curtailment.

Using the statistics provided for circuit and unit outages, base indices were computed for the following failure conditions:

- Branch overloads (MVA flows greater than 100% of the "A" rating)
- High and low voltages (greater than 1.1 pu or less than 0.9 pu of nominal)
- Islanding (involving 1 MW or more of load loss)
- Voltage collapse

- Voltage Depression (low voltage involving 4 or more buses with less than 0.9 p.u. voltage)

These results are summarized in Table 3.1 for the base system and the improved system.

The frequencies shown are upper bound frequencies calculated by simple summation of the frequencies of individual outage events. This is a good assumption as long as all events are low probability transmission events. However, the presence of a large number of single and multiple generation outages that contribute to the failure indices may produce excessively high frequencies through double counting of independent overlapping events. Since this is the case in this sample calculation, the computed frequencies will be overstated significantly for the most frequent events; i.e., branch overloads. On the other hand, this sample study did not include the specification of common mode and substation dependent events. Inclusion of such events would have increased the calculated frequencies of the more severe, less frequent, events. Studies performed with TPLAN are normally transmission system oriented with emphasis on representation of single and dependent (common mode and substation/protection failures) multiple outages [3,4]. Independent overlapping transmission outages are normally ignored except when adverse weather conditions (failure bunching) are modelled.

Islanding Indices

Loss of load is only recorded when it is associated with transmission outages resulting in islanding. This occurs due to generation deficiencies within some of the islands. The load loss indices associated with these events are shown in Tables 3.2 and 3.3.

Table 3.1
Reliability Indices from TPLAN Studies

| | Base System | | Enhanced System | |
|--------------------|---------------------|---------------------|---------------------|---------------------|
| | Frequency Occ/Yr | Duration Hrs/Occ | Frequency Occ/Yr | Duration Hrs/Occ |
| Branch Overloads | 906.8 | 19.9 | 265.4 | 16.9 |
| Low Voltages | 6.2 | 5.0 | 5.8 | 4.7 |
| High Voltages | 0 | 0 | 0 | 0 |
| Islanding | 2.1 | 6.5 | 2.1 | 6.5 |
| Voltage Collapse | 0.0014 | 20.1 | 0.1264E-2 | 13.4 |
| Voltage Depression | 0.007 | 10.7 | 0.007 | 8.4 |

Table 3.2
Exact and Cumulative Load Interruption Indices

***** SYSTEM LOSS OF LOAD INDEX *****

| LOAD LOST (MW) | FREQUENCY (OC/YR) | DURATION (HR/OC) | POWER INTERRUPTED (MW/YR) | ENERGY CURTAILED (MWHR/YR) | CUM. FREQUENCY (OC/YR) | CUM. CURTAILED (MWHR/YR) |
|-------------------|----------------------|---------------------|---------------------------------|----------------------------------|------------------------------|--------------------------------|
| 8 - 28 | 8.651 | 4.8 | 8.88 | 8.88 | 2.891 | 493.94 |
| 21 - 48 | 8.625 | 18.4 | 28.67 | 288.89 | 1.448 | 493.94 |
| 41 - 68 | 8.593 | 4.8 | 35.78 | 171.33 | 8.814 | 285.85 |
| 61 - 88 | 8.888 | 8.8 | 8.88 | 8.88 | 8.221 | 114.53 |
| 81 - 108 | 8.854 | 5.8 | 5.31 | 26.64 | 8.221 | 114.53 |
| 101 - 128 | 8.112 | 4.8 | 11.48 | 55.85 | 8.168 | 87.88 |
| 121 - 148 | 8.855 | 4.8 | 6.88 | 32.83 | 8.855 | 32.83 |
| ** TOTAL ** | 2.891 | 6.47 | 79.88 | 493.94 | | |

Table 3.3
Load Interruption Indices by Bus

| *** RELIABILITY INDICES FOR BUS LOAD LOSS *** | | | | | | | | | |
|---|---------------|-------------|-------------------------|------------------------------|-------------------|----------------------|------------------|-------------------|------|
| TOTAL LOAD (MW) | FREQ. (OC/YR) | DUR (HR/OC) | POWER INTERPT. (MW/OCC) | BUS ENERGY CURTAIL. (MMW/YR) | LOSS INDEX (1/YR) | B.E.C. INDEX (HR/YR) | # OF FAIL. CONT. | WORST CONT. INDEX | |
| ** TOTAL ** | 3985 | 2.891 | 6.5 | 38.28 | 493.94 | 8.828 | 8.126 | 174 | 5448 |
| AREA 1 : 138- 345 KV BUSES | | | | | | | | | |
| 1869 MADHYQ 345 | 3985 | 2.891 | 6.5 | 64.17 | 1869.49 | 8.834 | 8.274 | 174 | 6581 |
| 1918 IROQU8 138 | 288 | 8.167 | 25.6 | 51.83 | 218.26 | 8.843 | 1.891 | 49 | 5358 |
| 1971 PENFLD 138 | 154 | 8.221 | 28.6 | 53.79 | 194.86 | 8.877 | 1.266 | 51 | 6581 |
| 1679 LANCST 138 | 59 | 8.458 | 4.8 | 33.78 | 74.18 | 8.263 | 1.264 | 38 | 5312 |
| 1834 OAKBAY 138 | 182 | 8.112 | 4.8 | 181.58 | 55.85 | 8.112 | 8.542 | 1 | 5226 |
| 1835 118421 138 | 68 | 1.244 | 4.8 | 68.28 | 359.37 | 1.244 | 5.978 | 82 | 5228 |
| 1867 EDMST3 345 | 8 | 8.651 | 4.8 | 8.88 | 8.88 | 8.888 | 8.888 | 42 | 5269 |
| 1987 EDMST1 138 | 8 | 8.167 | 25.6 | 8.88 | 8.88 | 8.888 | 8.888 | 49 | 5358 |
| 1988 114884 138 | 8 | 8.167 | 25.7 | 8.88 | 8.88 | 8.888 | 8.888 | 58 | 5358 |
| 1989 IROQUA 138 | 8 | 8.216 | 28.9 | 8.88 | 8.88 | 8.888 | 8.888 | 51 | 5358 |
| 1989 IROQUA 138 | 123 | 8.222 | 28.5 | 54.18 | 167.78 | 8.898 | 1.367 | 52 | 5448 |

Table 3.2 lists exact and cumulative indices by amount of load interrupted. Table 3.3 details load interruption by bus. The load interruption indices for the base system and the improved system are the same.

Overload Indices

Overload indices for the base system are displayed by branch in Table 3.4. The line reinforcements reduce the overload frequency on some of the most frequently overloaded lines by two orders of magnitude while other lines which are not directly paralleled by the reinforcements are less affected. A comparative summary of frequently overloaded lines is presented in Table 3.5.

The results above reveal that the transmission improvements of the enhanced system have a major effect in reducing the frequency and severity of overloads on the first three circuits which are paralleled by the reinforcements in the system. Figure 3.1 shows the cumulative frequency distributions of overload events as a function of degree of overload for the system and the C.Cov1-MILD47 circuit. These results were obtained by repeat application of TPLAN's reliability index activity to the results of the contingency analysis performed.

Bus Voltage Indices

Reliability indices for bus voltage violations in the Base System are shown in Table 3.6. Improvements obtained through the

Table 3.4
Reliability Indices for Overloads by Branch

| RELIABILITY INDICES FOR BRANCH OVERLOADS | | | | | | | | | |
|--|------------|--------------|----------|------------------|------------------|------------------|-------------------|--|--|
| | RATING MVA | FREQ (OC/YR) | DUR (HR) | AVG LOAD. (P.U.) | MAX LOAD. (P.U.) | # OF FAIL. CONT. | WORST CONT. INDEX | | |
| TOTAL | | 986.762 | 19.9 | 1.19 | 2.53 | 3485 | 5475 | | |
| AREA 1 : 138- 345 KV BUSES | | | | | | | | | |
| 158 ONSLO1 138 | 183 | 986.762 | 19.9 | 1.19 | 2.53 | 3485 | 5475 | | |
| 1677 CARAQT 138 | 1886 | 8.876 | 21.2 | 1.14 | 1.14 | 1 | 5153 | | |
| 1677 CARAQT 138 | 1886 | 8.894 | 4.4 | 1.85 | 1.85 | 13 | 1416 | | |
| 1681 IRVREF 138 | 1717 | 8.117 | 4.4 | 1.21 | 1.21 | 13 | 1291 | | |
| 1813 C.BAY1 138 | 1681 | 1.624 | 17.8 | 1.28 | 1.68 | 133 | 5475 | | |
| 1867 NEWCA1 138 | 1712 | 19.911 | 16.9 | 1.25 | 2.53 | 823 | 5475 | | |
| 1812 MONCTN 138 | 1712 | 1.793 | 4.5 | 1.53 | 1.57 | 65 | 6971 | | |
| 1717 114963 138 | 1712 | 3.583 | 4.4 | 1.57 | 1.67 | 145 | 5619 | | |
| 1747 NORPSR 138 | 1981 | 8.848 | 4.6 | 1.88 | 1.11 | 15 | 2321 | | |
| 1776 114981 138 | 1981 | 8.848 | 4.6 | 1.88 | 1.11 | 15 | 2321 | | |
| 1776 114981 138 | 1839 | 1.228 | 17.9 | 1.25 | 1.98 | 129 | 5688 | | |
| 1888 BEECHW 138 | 1884 | 1.279 | 17.7 | 1.55 | 2.25 | 135 | 5615 | | |
| 1882 GRFALL 138 | 1817 | 17.9 | 17.9 | 1.25 | 1.98 | 129 | 5688 | | |
| 1882 GRFALL 138 | 1817 | 1.228 | 17.9 | 1.25 | 1.98 | 129 | 5688 | | |
| 1884 117562 138 | 1849 | 1.279 | 17.7 | 1.55 | 2.25 | 135 | 5615 | | |
| 1882 GRFALL 138 | 1817 | 1.997 | 18.4 | 1.87 | 1.57 | 138 | 5635 | | |
| 1884 117562 138 | 1849 | 8.894 | 16.1 | 1.12 | 1.24 | 5 | 5535 | | |
| 1826 DALHOU 138 | 1885 | 8.818 | 38.2 | 1.83 | 1.89 | 4 | 5535 | | |
| 1889 MACTOC 138 | 1827 | 8.135 | 4.3 | 1.85 | 1.17 | 48 | 1369 | | |
| 1889 MACTOC 138 | 1827 | 8.135 | 4.3 | 1.85 | 1.17 | 48 | 1366 | | |
| 1889 MACTOC 138 | 1861 | 292.178 | 19.6 | 1.84 | 1.19 | 688 | 1664 | | |
| 1811 GRLAKE 138 | 1818 | 8.881 | 8.1 | 1.19 | 1.38 | 3 | 5875 | | |
| 1818 MARYSV 138 | 1845 | 8.821 | 4.3 | 1.89 | 1.16 | 2 | 1651 | | |
| 1818 MARYSV 138 | 1846 | 8.853 | 4.2 | 1.85 | 1.21 | 11 | 1651 | | |
| 1811 GRLAKE 138 | 1812 | 1.366 | 18.2 | 1.86 | 1.46 | 138 | 5616 | | |
| 1812 MONCTH 138 | 1839 | 8.481 | 4.4 | 1.83 | 1.18 | 73 | 1658 | | |
| 1812 MONCTH 138 | 1839 | 8.481 | 4.4 | 1.83 | 1.18 | 73 | 1657 | | |
| 1813 C.BAY1 138 | 1862 | 87.178 | 15.6 | 1.24 | 1.87 | 478 | 266 | | |
| 1813 C.BAY1 138 | 1845 | 449.818 | 19.7 | 1.28 | 2.84 | 991 | 264 | | |
| 1827 KESWK1 138 | 1846 | 8.629 | 4.4 | 1.87 | 1.32 | 188 | 1651 | | |
| 1827 KESWK1 138 | 1846 | 8.629 | 4.4 | 1.11 | 1.37 | 188 | 1651 | | |
| 1847 112572 138 | 1827 | 8.884 | 11.8 | 1.18 | 1.24 | 6 | 5591 | | |
| 1836 C.COV3 345 | 1988 | 8.882 | 17.3 | 1.11 | 1.16 | 2 | 5536 | | |
| 1837 C.COV1 138 | 1868 | 646.632 | 19.9 | 1.28 | 2.85 | 1497 | 266 | | |
| 1837 C.COV1 138 | 1862 | 458.745 | 19.7 | 1.28 | 2.84 | 994 | 264 | | |
| 1839 SALBR1 138 | 1945 | 1.699 | 4.4 | 1.85 | 1.13 | 231 | 1657 | | |
| 1839 SALBR1 138 | 1946 | 1.828 | 4.4 | 1.84 | 1.18 | 153 | 5838 | | |
| 158 ONSLO1 138 | 167 | 8.876 | 21.2 | 1.81 | 1.81 | 1 | 5153 | | |
| 1883 KESWK3 345 | 1828 | 8.881 | 13.4 | 1.19 | 1.31 | 2 | 5474 | | |
| 1838 EELRV2 238 | 1866 | 8.158 | 28.8 | 1.87 | 1.22 | 29 | 6811 | | |
| 1836 C.COV3 345 | 1837 | 8.463 | 52.6 | 1.26 | 1.65 | 91 | 5538 | | |
| 1836 C.COV3 345 | 1837 | 8.888 | 33.1 | 1.18 | 1.22 | 6 | 5528 | | |
| 1838 SALBR2 238 | 1839 | 8.881 | 13.4 | 1.18 | 1.18 | 2 | 5616 | | |
| 1839 SALBR1 138 | 1858 | 8.884 | 18.2 | 1.11 | 1.17 | 6 | 5832 | | |

Table 3.5
Most Frequently Overloaded Circuits

| Line | Frequency Occ/Year | Base System | | | Enhanced System | | | |
|----------------------------|--------------------|------------------|--------------------|--------------------|--------------------|------------------|--------------------|--------------------|
| | | Duration Hrs/Occ | Avg. Overload p.u. | Max. Overload p.u. | Frequency Occ/Year | Duration Hrs/Occ | Avg. Overload p.u. | Max. Overload p.u. |
| 1837 C.Cov1 1860 MILD47 | 646.6 | 19.9 | 1.20 | 2.05 | 5.29 | 14.5 | 1.14 | 1.56 |
| 1837 C.Cov1 1862 MILD65 | 450.7 | 19.7 | 1.20 | 2.04 | 2.00 | 15.5 | 1.08 | 1.46 |
| 1813 C.BAY7 1862 MILD65 | 449.0 | 19.7 | 1.20 | 2.04 | 1.97 | 15.4 | 1.08 | 1.46 |
| 1809 MACTQC 1861 DOAKST | 292.2 | 19.6 | 1.04 | 1.19 | 248.4 | 17.3 | 1.04 | 1.19 |




Figure 3.1.a
Cumulative Frequency Distribution of Overall Events for all Branches:
Graph shows frequency of exceeding p.u. overloads indicated on X-axis.




Figure 3.1.b
Cumulative Frequency Distribution of Overall Events
for Line C.Cov1(1837) - MILD47(1860):
Graph shows frequency of exceeding p.u. overloads indicated on X-axis.

Table 3.6
Reliability Indices for Bus Limit Violations for The Base System

| *** RELIABILITY INDICES FOR BUS VOLTAGE VIOLATIONS *** | | | | | | | |
|--|-----------------------|------------------|----------------------|----------------------|----------------------|------------------------|-------------------------|
| | VOLT LIMIT (PU) | FREQ. (OC/YR) | AVG. DUR. (HR) | AVG. VIO. (PU) | MAX. VIO. (PU) | # OF FAIL. CONT. | WORST CONT. INDEX |
| TOTAL | LOW: | 6.215 | 5.8 | 8.11 | 8.35 | 329 | 5619 |
| | HIGH: | 8.888 | 8.8 | 8.88 | 8.88 | 8 | 8 |
| AREA 1 : 138- 345 KV BUSES | LOW: | 6.215 | 5.8 | 8.11 | 8.35 | 329 | 5619 |
| | HIGH: | 8.888 | 8.8 | 8.88 | 8.88 | 8 | 8 |
| LOW BUS VOLTAGES: | | | | | | | |
| 168 ONSLO3 | 345 | 8.988 | 8.891 | 14.8 | 8.83 | 8.24 | 17 5616 |
| 1844 MURRCR | 138 | 8.988 | 8.883 | 11.6 | 8.86 | 8.25 | 5 5616 |
| 1677 CARAQT | 138 | 8.988 | 8.117 | 4.4 | 8.89 | 8.89 | 13 1291 |
| 1812 MONCTN | 138 | 8.988 | 8.884 | 9.7 | 8.85 | 8.21 | 6 5616 |
| 157 MACCAN | 138 | 8.988 | 8.885 | 18.3 | 8.86 | 8.26 | 7 5616 |
| 158 ONSLO1 | 138 | 8.988 | 8.883 | 8.5 | 8.89 | 8.27 | 4 5616 |
| 167 ONSLO2 | 238 | 8.988 | 8.843 | 11.9 | 8.83 | 8.26 | 14 5616 |
| 183 SPRNGH | 138 | 8.988 | 8.886 | 9.9 | 8.85 | 8.27 | 9 5616 |
| 1681 IRVREF | 138 | 8.988 | 8.848 | 4.6 | 8.18 | 8.12 | 15 2321 |
| 1712 RICHBT | 138 | 8.988 | 5.681 | 5.1 | 8.18 | 8.35 | 258 5619 |
| 1717 114963 | 138 | 8.988 | 8.449 | 4.5 | 8.83 | 8.11 | 54 2321 |
| 1747 NORPSR | 138 | 8.988 | 8.882 | 8.6 | 8.81 | 8.81 | 2 5476 |
| 1776 114981 | 138 | 8.988 | 8.883 | 8.8 | 8.81 | 8.83 | 4 5616 |
| 1825 MEMCOK | 138 | 8.988 | 8.883 | 11.6 | 8.87 | 8.24 | 5 5616 |
| 1838 SALBR2 | 238 | 8.988 | 8.323 | 15.2 | 8.82 | 8.23 | 49 5616 |
| 1839 SALBR1 | 138 | 8.988 | 8.881 | 16.2 | 8.87 | 8.19 | 3 5616 |
| 1858 SALBR3 | 345 | 8.988 | 8.887 | 9.2 | 8.85 | 8.25 | 9 5616 |
| 1852 118871 | 138 | 8.988 | 8.883 | 11.6 | 8.86 | 8.22 | 5 5616 |
| 1854 HARDRD | 138 | 8.988 | 8.883 | 11.6 | 8.87 | 8.25 | 5 5616 |
| 1863 119842 | 138 | 8.988 | 8.843 | 5.8 | 8.83 | 8.26 | 15 5616 |
| 1988 NOR TN3 | 345 | 8.988 | 8.883 | 11.7 | 8.82 | 8.84 | 5 5476 |
| 1981 NOR TN1 | 138 | 8.988 | 8.882 | 8.6 | 8.88 | 8.88 | 2 5476 |
| 1945 119824 | 138 | 8.988 | 8.883 | 11.6 | 8.86 | 8.22 | 5 5616 |
| 1946 112488 | 138 | 8.988 | 8.883 | 11.6 | 8.86 | 8.21 | 5 5616 |

Table 3.7
Comparison of Bus Voltage Reliability Indices
for the Base System and the Improved System for Selected Buses.

| | | Frequency Occ/Year | Duration Hrs/Occ | Average Violation p.u. | Worst Violation p.u. |
|------------------------|--------|-----------------------|---------------------|------------------------------|----------------------------|
| <u>Base System</u> | | | | | |
| RICHBT | (1712) | 5.601 | 5.1 | 0.18 | 0.35 |
| CARCT | (1677) | 0.117 | 4.4 | 0.09 | 0.09 |
| 114963 | (1717) | 0.449 | 4.5 | 0.03 | 0.11 |
| SALBR2 | (1838) | 0.323 | 15.2 | 0.02 | 0.23 |
| System | | 6.215 | 5.0 | 0.11 | 0.35 |
| <u>Improved System</u> | | | | | |
| RICHBT | (1712) | 5.585 | 4.6 | 0.20 | 0.35 |
| CARCT | (1677) | 0.122 | 4.4 | 0.09 | 0.09 |
| 114963 | (1717) | 0.021 | 4.3 | 0.02 | 0.11 |
| SALBR2 | (1838) | 0.076 | 11.7 | 0.02 | 0.14 |
| System | | 5.849 | 4.7 | 0.14 | 0.35 |

reinforcements are summarized for some of the buses in Table 3.7.

Using a non-diverging load flow solution technique, TPLAN also identifies contingencies for which there is no solution (Jacobian matrix is singular). These are classified as voltage collapse contingencies as indicated in Table 3.1. Table 3.8 shows details of one of the voltage collapse contingencies for the Base System: the loss of two 345 kV lines (St Andre-Eel

River and St. Andre-Keswick). The output from the non-divergent load flow in Table 3.8 indicates the collapse of the portion of the system normally supplied from the 345 kV buses at St. Andre and Edmundston and the 138 kV bus at Keswick. The loss of the two 345 kV lines connected to St. Andre would most likely occur either by the loss of one line when the other is out on maintenance or the simultaneous loss of both line because of substation or protection trouble. The voltage collapse indices in Table 3.1 would be significantly higher if such events were included in the analysis.

Table 3.8
Details of Contingency Causing Voltage Collapse

SUMMARY OF CONTINGENCIES
(OVLVD>1.00 RATING-A VOLT>1.10, VOLT<0.90, BUSES/ISLD)= 1)

| CONT # | SOLN | OVERLOADS | CONTINGENCY | 5533 | LOW VOLTAGE | SWING GEN | ITER | MISMATCH |
|---------|----------|-----------|--------------------------|-----------|-------------|-----------|--------|-------------------------|
| 5533 | VC | # - #.## | HIGH VOLTAGE # - #.## | 2# - #.## | (945, 363) | 7 | 1#32 | |
| OUTAGES | FROM BUS | | TO BUS | ID | BASE CASE | RATING-A | P.U.-A | |
| 1866 | EELRV3 | 345 | 1868 STAND3 | 345 1 | 69 | 700 | 0.10 | |
| 1803 | KESVK3 | 345 | 1868 STAND3 | 345 1 | 336 | 700 | 0.40 | |
| * AREA | 1 * | | | | | | | |
| VOLTAGE | BUS NAME | | MAX. | MIN. | BASE | CONT | DEV. | #.7 #.9 1.1 |
| 1869 | MADHYO | 345 | 1.100 | 0.900 | 0.968 | 0.034 | -0.934 | |
| 1896 | TINKER | 138 | 1.100 | 0.900 | 1.026 | 0.256 | -0.770 | |
| 1800 | 8EECHV | 138 | 1.100 | 0.900 | 1.022 | 0.327 | -0.695 | |
| 1802 | GRFALL | 138 | 1.100 | 0.900 | 1.027 | 0.256 | -0.771 | |
| 1847 | 112572 | 138 | 1.100 | 0.900 | 1.003 | 0.716 | -0.207 | |
| 1910 | IROOUB | 138 | 1.100 | 0.900 | 1.030 | 0.034 | -0.996 | |
| 1804 | 112562 | 138 | 1.100 | 0.900 | 1.027 | 0.001 | -1.026 | |
| 1810 | MARYSV | 138 | 1.100 | 0.900 | 0.997 | 0.093 | -0.104 | |
| 1817 | 111144 | 138 | 1.100 | 0.900 | 1.026 | 0.030 | -0.996 | |
| 1827 | KESWK1 | 138 | 1.100 | 0.900 | 1.014 | 0.089 | -0.125 | |
| 1845 | HASH03 | 138 | 1.100 | 0.900 | 1.000 | 0.091 | -0.109 | |
| 1846 | HASH12 | 138 | 1.100 | 0.900 | 1.000 | 0.091 | -0.109 | |
| 1849 | STAND1 | 138 | 1.100 | 0.900 | 1.024 | 0.016 | -1.008 | |
| 1865 | 111036 | 138 | 1.100 | 0.900 | 1.041 | 0.706 | -0.335 | |
| 1867 | EDMST3 | 345 | 1.100 | 0.900 | 0.973 | 0.032 | -0.941 | |
| 1868 | STAND3 | 345 | 1.100 | 0.900 | 0.996 | 0.026 | -0.970 | |
| 1907 | EDMST1 | 138 | 1.100 | 0.900 | 1.039 | 0.033 | -1.006 | |
| 1908 | 114084 | 138 | 1.100 | 0.900 | 1.036 | 0.033 | -1.003 | |
| 1909 | IROQUA | 138 | 1.100 | 0.900 | 1.035 | 0.033 | -1.002 | |
| 1930 | 1126MP | 138 | 1.100 | 0.900 | 1.003 | 0.410 | -0.593 | |
| VAR | | | | | | | | GENERATORS ON VAR LIMIT |
| 1802 | GRFALL | 138 | 15.5 | -35.0 | 7.8 | 3649.0 | 3641.2 | ++ |
| 1826 | DALHOU | 138 | 166.0 | -196.0 | 1.3 | 321.0 | 319.7 | ++ |
| 1847 | 112572 | 138 | 6.0 | -6.0 | -6.0 | -19.0 | -13.0 | -- |
| 1913 | BELDUN | 345 | 220.0 | -250.0 | 220.0 | 219.0 | -1.0 | + |
| 1948 | EELRA1 | 138 | 7.0 | -7.0 | 4.3 | 6.0 | 1.7 | + |
| 168 | ONSL03 | 345 | 100.0 | -150.0 | 100.0 | 100.0 | 0.0 | + |
| 1844 | MURRCR | 138 | 20.0 | 0.0 | 0.0 | 0.0 | 0.0 | - |
| 1896 | TINKER | 138 | 5.0 | -5.0 | 1.9 | 307.0 | 305.1 | ++ |

Even when there is a solution to the load flow, there may be a high risk of voltage collapse indicated by a widespread low voltage condition. To capture such events, TPLAN includes a voltage depression failure criterion defined by N or more buses being below a specified voltage level. Figure 3.2 shows the frequency of such events for the Base System and the Improved

System as a function of the number of buses (N) for a voltage limit of 0.9 per unit. Table 3.9 shows the frequency and duration of voltage depressions involving 4 or more buses for the base system. The table details reliability indices by bus affected by such events.




Figure 3.2
Cumulative Frequency for Voltage Depression Affecting N or more Buses

Table 3.9
Reliability Indices for Voltage Depression by Bus Affected

*** RELIABILITY INDICES FOR VOLTAGE DEPRESSION VIOLATIONS ***


CRITERION: (4) BUSES UNDER (8.988) P.U.

| | FREQ. (OC/YR) | AVG. DUR. (HR) | AVG. VIO. (PU) | MAX. VIO. (PU) | # OF FAIL. CONT. | WORST INDEX | V.COL. FREQ. (OC/YR) |
|----------------------------|------------------|----------------------|----------------------|----------------------|------------------------|----------------|----------------------------|
| TOTAL | 8.887 | 18.7 | 8.86 | 8.35 | 11 | 5619 | 8.881 |
| AREA 1 : 138- 345 KV BUSES | 8.887 | 18.7 | 8.86 | 8.35 | 11 | 5619 | 8.881 |
| BUSES: | | | | | | | |
| 168 ONSLO3 345 | 8.887 | 9.2 | 8.85 | 8.24 | 9 | 5616 | |
| 1844 MURRCR 138 | 8.883 | 11.6 | 8.86 | 8.25 | 5 | 5616 | |
| 1812 MONCTN 138 | 8.884 | 9.7 | 8.85 | 8.21 | 6 | 5616 | |
| 157 MACCAN 138 | 8.885 | 18.3 | 8.86 | 8.26 | 7 | 5616 | |
| 158 ONSLO1 138 | 8.883 | 8.5 | 8.89 | 8.27 | 4 | 5616 | |
| 167 ONSLO2 238 | 8.886 | 8.4 | 8.85 | 8.26 | 8 | 5616 | |
| 183 SPRNGH 138 | 8.886 | 9.9 | 8.85 | 8.27 | 9 | 5616 | |
| 1712 RICHTB 138 | 8.887 | 18.6 | 8.12 | 8.35 | 18 | 5619 | |
| 1747 NORPSR 138 | 8.882 | 8.6 | 8.81 | 8.81 | 2 | 5476 | |
| 1776 114981 138 | 8.882 | 9.6 | 8.82 | 8.83 | 3 | 5616 | |
| 1825 MEMCOK 138 | 8.883 | 11.6 | 8.87 | 8.24 | 5 | 5616 | |
| 1838 SALBR2 238 | 8.886 | 9.3 | 8.87 | 8.23 | 8 | 5616 | |
| 1839 SALBR1 138 | 8.881 | 16.2 | 8.87 | 8.19 | 3 | 5616 | |
| 1858 SALBR3 345 | 8.887 | 9.2 | 8.85 | 8.25 | 9 | 5616 | |
| 1852 118871 138 | 8.883 | 11.6 | 8.86 | 8.22 | 5 | 5616 | |
| 1854 HARDRD 138 | 8.883 | 11.6 | 8.87 | 8.25 | 5 | 5616 | |
| 1863 119842 138 | 8.886 | 9.9 | 8.85 | 8.26 | 9 | 5616 | |
| 1988 NORTN3 345 | 8.883 | 11.5 | 8.83 | 8.84 | 4 | 5476 | |
| 1981 NORTN1 138 | 8.882 | 8.6 | 8.88 | 8.88 | 2 | 5476 | |
| 1945 119824 138 | 8.883 | 11.6 | 8.86 | 8.22 | 5 | 5616 | |
| 1946 112488 138 | 8.883 | 11.6 | 8.86 | 8.21 | 5 | 5616 | |

4.0 REFERENCES

- [1] Pang, C.K., A.J. Wood, "Multi-Area Generation System Reliability Calculations," IEEE Transactions on Power Apparatus and Systems, Vol. PAS-94, No. 2, March/April 1975.
- [2] Hosseini, H., S.B. Dhar, W.R. Puntel, "Interconnected California Power Systems Transfer Capability and Reliability Study," 1981 Reliability Conference for the Electric Power Industry, Portland, OR, April, 1981.
- [3] Reppen, N.D., B.P. Lam, "Assessment of Power System Reliability Using the TPLAN Program," presented at the Canadian Electrical Association annual meeting, March, 1989, Toronto, Canada.
- [4] Reppen, N.D., T. Carlsen, I. Glende, B. Bostad and B.P. Lam, "Calculation of the Reliability of Electric Power Supply to a Major Industrial Complex," presented at the 10th Power System Computation Conference (PSCC), Graz, Austria, August 14-24, 1990.

interconnected and operating in a coordinated manner such as illustrated below.



In these situations, the reliability of the overall system and each utility area depends not only on area resources and load, but also on the ability of areas to share resources with one another over transmission ties.

System and area LOLE indices can differ significantly and are influenced by transmission limitations and reserve sharing policies. The proper evaluation of these interdependencies requires a technique that is more sophisticated than the traditional single-area approach.

A.2 PROGRAM CAPABILITIES

PTT's Multi-Area Reliability Evaluation Program, MAREL, provides the enhanced modeling capabilities needed to address today's more complicated reliability questions. It calculates both system and area LOLE indices for interconnected electric utility systems - fully recognizing the ability of areas to share reserves over transmission ties. MAREL's modeling capabilities provide a high degree of flexibility for the specification of system configurations and characteristics.

- Loads are modeled by area using distributions of daily peak loads. The chronological aspects of

APPENDIX I

MULTI-AREA RELIABILITY PROGRAM (MAREL) DESCRIPTION

A.1 INDUSTRY NEED

The loss-of-load expectation (LOLE) measure has gained widespread use in the electric utility industry for evaluating the adequacy of future generation additions. LOLE studies are traditionally based on single area models where generation and load are assumed connected to a single bus and where transmission effects are ignored.

In today's utility planning environment, generation additions are often evaluated on a regional basis, with several utilities

area load distributions can be retained so that the effects of load diversity among areas are fully incorporated in the study results.

- Generating units are specified by area and may be modeled with up to eight probabilistic outage states. Individual capacity/probability tables are constructed for each area to model the availability of generating capacity in that area.
- Planned maintenance outages are simulated by taking generating units out-of-service for specific maintenance periods. The outage periods may be specified by the user or scheduled automatically within MAREL by an algorithm designed to level available area generation reserves over the year. Maintenance period duration can be defined by the user depending on what is appropriate for the study.
- Transmission interconnections are represented by a linear flow network model which accommodates multi-state, probabilistic transfer limits between areas. This model places no restrictions on the network configuration or topology.
- Indices computed include system and area LOLE's, expected MW-days of load loss, average MW's of load loss, probability of limitations on transfer links and expected interchange between pairs of areas. In addition, four different policies for sharing reserves and load losses between areas are incorporated in the analysis. Indices are computed for each policy. LOLE and related indices are also calculated assuming that areas are not connected to one another. These "isolated" indices are useful for comparison and reference purposes.
- Program output reports include formatted summaries of study parameters, model inputs, and the results of the reliability analysis. These outputs are suitable for direct incorporation into study documents. The user may suppress the display of certain output summaries. Some samples are shown on page 4.
- Program controls may be set by the user to establish the fineness with which loads and capacity are represented and to save unnecessary computer effort and cost.

APPENDIX B

TPLAN DESCRIPTION

B.1 THE TPLAN PROGRAM

The TPLAN program, developed by Power Technologies, Inc. is an interactive computer program for long term planning and operations planning. The program is dimensioned for 4000 buses and has the following application functions:

- 1) Automatic contingency analysis using either AC or DC load flow models.

- 2) Probabilistic reliability assessment of power systems including transmission network effects and failures.
- 3) Parametric studies allowing the automatic determination of selected variables as a function of any systematic change in the network; e.g., automatic generation of curves that show voltage vs. power transfer to determine safe margin against voltage collapse.
- 4) Interactive transmission system expansion functions to help determine the most effective circuit additions for eliminating overload problems during base case and contingency conditions.
- 5) Corrective action function that determines generation redispatch and phase shifter action required to eliminate overloads on transmission circuits, with optional load shedding function.
- 6) Simulation of overload cascading events to help identify portions of the system that are vulnerable to islanding caused by overload cascading.
- 7) Power transfer limit determination based on circuit overloads during single and multiple contingencies.

These application functions all work on the same system data base and are mutually supportive. For example, the system created by the interactive expansion planning function can be tested with AC contingency analysis without any manual data preparation. A command language allows the automatic execution of complex studies without manual intervention.

The program provides two-way communication of load flow data with PTI's PSS/E program via formatted raw data files or binary save case files. Additional input data supports unit commitment/dispatch functions, ROW and line type data, outage statistics, etc.

B.2 RELIABILITY ANALYSIS WITH TPLAN

TPLAN provides the capability to compute reliability indices for specific system conditions. The computed indices are given in terms of frequencies and durations of the following system problems:

- Overload on transmission circuits
- Violation of bus voltage limits
- Voltage collapse conditions
- Isolation of individual buses or separation of a network into islands
- Indices expressing loss of load caused by interruptions of supply
- Indices expressing the severity of overloads and bus voltage violations
- Frequency deviations (computed based on generator droop settings) that exceed criterion high or low values when islands are formed

Indices can be computed by system, area, kV level, bus or branch as appropriate.

A TPLAN reliability study is carried out in the following steps (See Figure 1):

- 1) Prepare outage statistics for single generator and transmission units that may be tested either by themselves or as a part of

an independent multiple outage events.

- 2) Prepare outage data files that specifies and assigns outage statistics for the single and multiple dependent outages that shall be tested.
- 3) Perform contingency analysis using either an AC or a DC load flow model. All contingencies specified in (2) will be tested. In addition, the program will test single and independent overlapping generation and transmission unit

outages guided by ranking and screening processes. The results of the contingency analysis will be stored in a contingency results file as shown in Figure 1.

- 4) Calculate reliability indices based on the outage statistics given in the outage data files prepared under (1) and (2) and the contingency results existing in the contingency results file. This step can be repeated with different but compatible outage data files without recalculation of the contingency results.




Figure 1
Reliability Assessment Using TPLAN

APPENDIX C

MAREL RESULTS FOR
NB POWER SYSTEM HLI EVALUATION

--- SUMMARY ON CAPACITY AND PEAK LOAD BY AREA :

| AREA | AREA 1 NORTHE | AREA 2 SOUTHE |
|--|------------------|------------------|
| PEAK LOAD SEASON | 1 | 1 |
| INSTALLED CAPACITY (MW) AT ANNUAL PEAK | 5374 | 5374 |
| ANNUAL PEAK LOAD (MW) | 3846 | 3846 |
| INSTALLED RESERVES (MW) | 1528 | 1528 |
| RESERVES IN PERCENT OF ANNUAL PEAK LOAD | 39.73 | 39.73 |
| AREA WEIGHTED AVERAGE UNIT FOR (PERCENT) | 8.89 | 8.89 |
| AREA ANNUAL AVERAGE MAINTENANCE (PERCENT) | 0.00 | 0.00 |

(Note: Two-Area System was Modeled to Satisfy MAREL Requirements. Single Area "isolated" indices were reported.)

--- SUMMARY : EXPECTED AREA DEFICIENCIES FOR DIFFERENT POLICIES ---

| AREA | ISOLATED | WITH LLS | NO LLS | NEXT AREA | POOLING |
|-------------------------------------|----------|----------|--------|-----------|----------|
| 1 NORTHE | MW-DAY | 15.57 | 15.57 | 15.57 | 15.50 |
| | DAYS | 0.09 | 0.09 | 0.09 | 0.09 |
| | AV.MW | 168.75 | 168.75 | 168.75 | 168.00 |
| 2 SOUTHE | MW-DAY | 15.57 | 15.57 | 15.57 | 15.50 |
| | DAYS | 0.09 | 0.09 | 0.09 | 0.09 |
| | AV.MW | 168.75 | 168.75 | 168.75 | 168.00 |
| INTERCONNECTED SYSTEM LOLP (DAYS) - | | | | | 0.183672 |
| NOTE : LLS - LOAD LOSS SHARING | | | | | |

(Note: LOLE indices reflect results for 10 load levels. Values must be multiplied by 876.0 to produce annual hourly indices.)

Le CIGRÉ a apporté le plus grand soin à la réalisation de cette brochure thématique numérique afin de vous fournir une information complète et fiable.

Cependant, le CIGRÉ ne pourra en aucun cas être tenu responsable des préjudices ou dommages de quelque nature que ce soit pouvant résulter d'une mauvaise utilisation des informations contenues dans cette brochure.

Publié par le CIGRÉ
21, rue d'Artois
FR-75 008 PARIS
Tél. : +33 1 53 89 12 90
Fax : +33 1 53 89 12 99

Copyright © 2000

Tous droits de diffusion, de traduction et de reproduction réservés pour tous pays.

Toute reproduction, même partielle, par quelque procédé que ce soit, est interdite sans autorisation préalable. Cette interdiction ne peut s'appliquer à l'utilisateur personne physique ayant acheté ce document pour l'impression dudit document à des fins strictement personnelles.

Pour toute utilisation collective, prière de nous contacter à sales-meetings@cigre.org

The greatest care has been taken by CIGRE to produce this digital technical brochure so as to provide you with full and reliable information.

However, CIGRE could in any case be held responsible for any damage resulting from any misuse of the information contained therein.

*Published by CIGRE
21, rue d'Artois
FR-75 008 PARIS
Tel : +33 1 53 89 12 90
Fax : +33 1 53 89 12 99*

Copyright © 2000

All rights of circulation, translation and reproduction reserved for all countries.

No part of this publication may be produced or transmitted, in any form or by any means, without prior permission of the publisher. This measure will not apply in the case of printing off of this document by any individual having purchased it for personal purposes.

For any collective use, please contact us at sales-meetings@cigre.org